

## 22 US7 Removal

Mon 6/3 Sun 77

they tried to find tanks & all the did  
I was find an abandoned line -  
break a water line  
break the phone lines

The breaks were not the responsibility of Nozzle New  
they had no knowledge of the pipes in either  
area.

Tues 6/4 Sun 79

Nozzle New Removed tanks 81 82 & 83 @ bldg 1047  
they were 2000 gal non sand filled

they cleaned the tanks of Sludges they was  
no appreciable liquid in the tanks

The tanks did have some small holes in them  
& some ~~contaminated~~ contamination was found  
& excavated to a reading of under 10 on the p10  
& a visual clean hole  
They lined the hole with Vaqueen & back filled

The Job was Spec'd. with 3-1000 gal sand filled tanks  
with a deduct request for 3-1000 gal non sand filled tank  
∴ a deduct is in line

We also should have deducts for George Rd STP  
tank # 89, Geo. Rd fire Station tank # 88  
& telephone Bldg North & North East tank #s 86 & 87  
~~the~~ since no tanks were found @ these locations  
only some excavation costs should be ~~included~~ included  
@ these sites.