

(26)

TRANSFORMER RECORDS

A

8

X

LOCATION RAILROADS TAG NUMBER 44514
 POLE NUMBER RR/456 KVA CAPACITY 5 SERIAL NUMBER 298072
 SERVICE TO: RR SCALE HOUSE MANUFACTURER _____ LINE MATERIAL _____ STYLE _____
 TYPE R.W. FORM _____ PHASE 1 CYCLE 60 % IMP. 2.3 PRIV. 2400
 SEC. V 12-12-0 KIND OF SERVICE _____ OUTDOOR X INDOOR _____ SUBWAY _____
 ACCESSORIES: SEMAPHORE OIL GAGE THERMOMETER DRAIN VALVE

(FIELD/SCALE HOUSE)

QUARTERLY INSPECTIONS

	1987	1988	1989	1990	1991	1992
FEBRUARY		2-3-88 CSE,	2-16-89 RH	3-5-90 JY	2-4-91 JYP	3-6-92 DJ
MAY		25 May 88 SLC	6-13-89 RH	6-18-90 (S)	5-29-91 JY	5-20-92 REM,
AUGUST	8-27-87 JCS	8-15-88 RH	9-25-89 RH	7-17-90 JY	8-26-91 DJ	8-19-92 TB
X NOVEMBER	11-4-87 JY	11-7-88 RH	12-5-89 JY	11-29-90 JYP	12-3-91 DJ	
DATE	DEFICIENCIES		DATE	CORRECTIVE ACTION		
9-25-89	Rusty spots needs paint					
9-17-90	" @ "					
11-29-90	"					
2-4-91	"					
5-29-91	" OUT OF SERVICE			IN SERVICE		
11-3-92	Moved to Bldg 854 JY					