

C O N F I D E N T I A L

RAVENNA
Part I Section 9

DATA ON BUILDING

East Sub Station - Switch House

Total Area
Floor

25-27

		: Basement :	1st :	
1.	Total productive area	Sq. ft. :	0 :	0 :
2.	Total non-productive area	Sq. ft. :	0 :	1170 :
3.	Laboratory & testing area	Sq. ft. :	0 :	0 :
4.	Office area	Sq. ft. :	0 :	0 :
5.	Cafeteria capacity	Number	None	
6.	Toilet capacity			
	a. Men	Number	None	
	b. Women	Number	None	
7.	Locker capacity			
	a. Men	Number	None	
	b. Women	Number	None	
8.	Design & construction details			
	a. Floor construction - Reinforced concrete			
	b. Floor finish (general area) - Non-dusting			
	c. Structural frame - Brick			
	d. Wall construction - Brick			
	e. Clear height - 13'-3-1/2"			
	f. Design limits floor loads - 1000 lbs./sq.ft.			
	g. Type of heating - Unit heaters, electric			
	h. Type of cooling - None			
	i. Type of air filtration - None			
	j. Power distribution			
	1. Voltage - 24 k.v.			
	2. Type - Conduit cable			
	k. Type of lighting - Direct			
	l. Type of fire protection - None			
	m. Type of soil - Sandy clay			
	n. Type of foundations - Reinforced concrete			
	o. Design soil pressures - 6000 lbs./sq.ft.			
	p. Roof deck construction - Reinforced concrete			
	q. Roofing			
	1. Type - Composition			
	2. Guarantee - 20 years			
	r. Roof insulation - 1" Boards			
	s. Description of other process piping layouts - None			
9.	Notes of special features - None			