

C O N F I D E N T I A L

RAVENNA
Part I Section 9

DATA ON BUILDING

Sub-Station Type 28-28	Total Area	
	Basement	1st
1. Total productive area	Sq. ft. : 0	: 0
2. Total non-productive area	Sq. ft. : 0	: 964
3. Laboratory & testing area	Sq. ft. : 0	: 0
4. Office area	Sq. ft. : 0	: 0
5. Cafeteria capacity	Number	None
6. Toilet capacity		
a. Men	Number	None
b. Women	Number	None
7. Locker capacity		
a. Men	Number	None
b. Women	Number	None
8. Design & construction details		
a. Floor construction	- Reinforced concrete	
b. Floor finish (general area)	- Concrete	
c. Structural frame	- Steel	
d. Wall construction	- Brick	
e. Clear height	- 13'-3-1/2"	
f. Design limits floor loads	- 1000 lbs./sq.ft.	
g. Type of heating	- Unit heater, electric	
h. Type of cooling	- None	
i. Type of air filtration	- None	
j. Power distribution		
1. Voltage	- 24 k.v.	
2. Type	- Conduit & cable	
k. Type of lighting	- Direct	
l. Type of fire protection	- None	
m. Type of soil	- Gravel, sand, clay	
n. Type of foundations	- Reinforced concrete	
o. Design soil pressures	- 6000 lbs./sq.ft.	
p. Roof deck construction	- Reinforced concrete	
q. Roofing		
1. Type	- Composition	
2. Guarantee	- 20 years	
r. Roof insulation	- 1" board	
s. Description of other process piping layouts	- None	
9. Notes of special features	- None	

C O N F I D E N T I A L