

~~Mon 10/21 Sun 58~~

The amt of the Spill completely washed out all AC from this section & Ruined the new pavement.

Harold said that we will repair the asphalt during removal of the 157 piping & Gas Island.

Mon 10/21 Sun 58

Started excavation @ PH 4 (fuse & booster)

Found one of the three (3) transformers leaking

Informed Electrical Super

We removed the transformers & Pole completely for Hoyle New

Removed Existing tank Saddles just West of site & No. of small Elect. Sub Station

found the underground power line to sub. no problems it was C.R.C. encased

Tue 10/22 Sun 68

Encountered Ground Water in the Tank excavation
We had them sample the water.

Wed 10/23 Sun 73

The water is now determined to be run off & not Groundwater

The water was vac up & disposed of at ~~the~~ Research oil
Vince will provide verification of water disposal

No Water returned after removal of initial water

They took all soil samples

Thurs 10/24 Cldy 73

Reset train Steam trestle
They poured a new reinforced Conc footer
Reset existing Steam line Posts