



Ohio Department of Commerce

George V. Voinovich, Governor

Division of State Fire Marshal • Bureau of Underground Storage Tank Regulations
9221 Ravenna Road, Suite D7-D8 • Twinsburg, OH 44087 • (216) 425-9848

Nancy S. Chiles, Director

April 9, 1992

Sue McCauslin
Ravenna Arsenal, Inc.
8451 State Route 5
Ravenna, OH 44266-9297

RE: Ravenna Army Ammunition Plant
tank RV11 (15,000 gallon diesel
fuel UST)
Railroad Yard
South Service Road
8451 State Route 5
Ravenna, OH 44266-9297
Portage County
Incident #679298-02

Dear Ms. McCauslin:

The State Fire Marshal, Bureau of Underground Storage Tank Regulations, (SFM, BUSTR) has received all required information regarding corrective actions of an underground storage tank (UST) release at the aforementioned location. Upon review of the analytical results and required reports, at this time BUSTR is not requiring further corrective actions of any contamination resulting from petroleum UST activity at the facility.

Due to information potentially not discovered or revealed, nothing in this letter should be interpreted as a guarantee or warrantee that no problems exist at the aforementioned location. In addition, this letter does not release the responsible party from future responsibility and liability under sections 3737.88 through 3737.89 of the Ohio Revised Code and other state laws and regulations or under the Federal Clean Water Act, Resource Conservation and Recovery Act, or Comprehensive Environmental Response, Compensation, and Liability Act for remedying conditions resulting from any release of contaminants to the environment.


If you have any questions about this determination, you can write to us at 9221 Ravenna Road, Suite D7, Twinsburg, Ohio 44087-2443, or telephone us at (216) 425-9848.

Sincerely,

Michelle Tarka
Site Coordinator

MT/sk

cc: File #679298-02
Virginia Black, Ravenna Health Department





Ohio Department of Commerce

W. W. W. W. W.
Sue M. / Charada
File

<input type="checkbox"/> Information
<input type="checkbox"/> Compliance or applicable
<input type="checkbox"/> Reply N.L.

George V. Voinovich, Governor

Division of State Fire Marshal • Bureau of Underground Storage Tank Regulations
9221 Ravenna Road, Suite D7-D8 • Twinsburg, OH 44087 • (216) 425-9848

Nancy S. Chiles, Director

April 9, 1992

Sue McCauslin
Ravenna Arsenal, Inc.
8451 State Route 5
Ravenna, OH 44266-9297

RE: Ravenna Army Ammunition Plant
tank RV23 (Building 1045)
8451 State Route 5
Ravenna, OH 44266-9297
Portage County
Incident #679298-11

Dear Ms. McCauslin:

The State Fire Marshal, Bureau of Underground Storage Tank Regulations, (SFM, BUSTR) has received all required information regarding corrective actions of an underground storage tank (UST) release at the aforementioned location. Upon review of the analytical results and required reports, at this time BUSTR is not requiring further corrective actions of any contamination resulting from petroleum UST activity at the facility.

Due to information potentially not discovered or revealed, nothing in this letter should be interpreted as a guarantee or warrantee that no problems exist at the aforementioned location. In addition, this letter does not release the responsible party from future responsibility and liability under sections 3737.88 through 3737.89 of the Ohio Revised Code and other state laws and regulations or under the Federal Clean Water Act, Resource Conservation and Recovery Act, or Comprehensive Environmental Response, Compensation, and Liability Act for remedying conditions resulting from any release of contaminants to the environment.

If you have any questions about this determination, you can write to us at 9221 Ravenna Road, Suite D7, Twinsburg, Ohio 44087-2443, or telephone us at (216) 425-9848.


Sincerely,

Michelle Tarka

Michelle Tarka
Site Coordinator

MT/sk

cc: File #679298-11
Virginia Black, Ravenna Health Department





RAVENNA ARSENAL, INC.
8451 STATE ROUTE 5, RAVENNA, OHIO 44266-9297
TELEPHONE: (216) 358-7111 • FAX: (216) 297-3216

February 21, 1992

THRU: Contracting Officer's Representative
Ravenna Army Ammunition Plant
8451 State Route 5
Ravenna, Ohio 44266-9297

TO: Division of State Fire Marshal
Bureau of Underground Storage Tank Regulations
ATTN: Michelle Tarka, Site Coordinator
9221 Ravenna Road, Suite D7-D8
Twinsburg, Ohio 44087

Subject: Incidents 679298-00 (RV-23) and 679298-02 (RV-11)

Dear Ms. Tarka:

As per your request during our telephone conversation on 2/10/92, the following information regarding removal of the above referenced tanks is provided with this letter:

1. Soil disposal receipts for soil removed during excavation
2. Sketch of tank areas showing location of soil samples

Please note that prior to removal of tank RV-23 a soil boring was done to check for possible contamination from a suspected line leak. The boring was located approximately 5 feet south of the tank. This area was subsequently excavated during tank removal.

If you have any questions or need further information regarding this subject, please contact Susan McCauslin at 297-3220. The Government point of contact is Robert J. Kasper, 297-3124.

Sincerely,

RAVENNA ARSENAL, INC.

H.R. Cooper
Plant Engineer

SMC/ade/92006

cc: N. Wulff
W. Carkido
B. Jenkins
T. Chanda
File

cf: AMCCOM
AMSMC-EQM (Cyril Onewokae)
Rock Island, IL w/att

NORTON CONSTRUCTION CO.
6200 ROCKSIDE WOODS BLVD.
INDEPENDENCE, OHIO 44131
447-0070

NORTON CONSTRUCTION CO.
6200 ROCKSIDE WOODS BLVD.
INDEPENDENCE, OHIO 44131
447-0070

Date 3-9-90

Date 3-8-90

TRUCK # 1

TRUCK # 1

NOZZLE NEW
RAVENA ARSENAL
15 CU. YDS. @ \$30.
Load of Rubbish \$ 450.⁰⁰

NOZZLE NEW
RAVENNA ARSENAL
20 CU. YDS. @ \$30.⁰⁰
Load of Rubbish \$ 600.⁰⁰

Signature [Signature]

Signature [Signature]

NORTON CONSTRUCTION CO.
6200 ROCKSIDE WOODS BLVD.
INDEPENDENCE, OHIO 44131

447-0070

Date 3-9-90

TRUCK # 1

NOZZLE NEW
RAVENNA ARSENAL
15 CU. YDS. @ \$30.

Load of Rubbish \$ 450.⁰⁰

Signature [Signature]

RAVENNA ARSENAL, INC.

TELEPHONE CONVERSATION RECORD

November 19, 1990

PERSON CALLING: Michele Tarka - State Fire Marshal's Office
PHONE: 425-9848

PERSON CALLED: Susan McCauslin - RAI Environmental Engineering
PHONE: 297-3220

SUBJECT: Underground Storage Tanks

Following are the file numbers assigned by the Fire Marshal's Office to our removed tanks. Future correspondence should include reference to the appropriate numbers.

<u>Number</u>	<u>Location</u>
679298-00	RV23; Bldg. 1045
679298-01	RV33; Burning Grds
679298-02	RV11; RR Yard
679298-03	RV13, RV14; Bldg. U6
679298-04	RV15, RV16; Bldg. U3
679298-05	RV17, RV18, RV19; Bldg. A-6
679298-06	550 Gal; Bldg. A-6
679298-07	RV37; Bldg. A-1
679298-08	RV10; Post 24
679298-09	RV47; Post 32
679298-10	RV52; Old Atlas


Susan McCauslin

SMC/ade

SNC

IDO
SDB

PURCHASE ORDER CHANGE

RAVENNA ARSENAL, INC.
Ravenna, Ohio 44266
(216) 358-7111
Contract No. DAAA09-88-Z-0001

M.O. # 55-2526

OR036X

R & R INTERNATIONAL, INC.
1234 S. CLEVELAND-MASSILLON RD.
AKRON, OHIO 44321

Date October 19, 1990

P. O. No. 19723 CH-1

ACCT. No. 55-2526

Please amend our Purchase Order No. 19723, Dated 2-2-90, as follows:

CHANGE ITEM 3 TO REFLECT ACTUAL COSTS OF \$5,895.60
(86.7 C.Y. @ \$68.00 PER CUBIC YD.)

ADD ITEM 3A: TRANSPORTATION AND DISPOSAL OF SIX (6) ADDITIONAL
DRUMS OF PETROLEUM PRODUCT (\$370.00 EA.)
EXTENDED COST OF: \$2,220.00

TOTAL REVISED COST: \$41,530.60
CONSIDER ORDER COMPLETE

ENGR/BJJ/co

This order, except as herein amended, shall in all other respects remain as before, unless completely cancelled.


RAVENNA ARSENAL, INC.

By *[Signature]*
Contract/Procurement &
Purchasing

Approved By _____
For Contracting Officer

B. J. JENKINS

APR 18 1990



R&R


INTERNATIONAL, INC.

A TEAM...
Dedicated to serving your needs

**FINAL REPORT FOR THE
REMOVAL OF
FOUR UNDERGROUND STORAGE TANKS**

**PREPARED FOR
RAVENNA ARMY AMMUNITION PLANT
RAVENNA, OHIO**

APRIL, 1990



R&R

INTERNATIONAL, INC.

1234 S. CLEVELAND-MASSILLON ROAD
P.O. BOX 4383
AKRON, OHIO 44321
(216) 666-2200

April 16, 1990

Ravenna Arsenal, Inc.
8451 State Route 5
Ravenna, Ohio 44266-9297

Attention: Mr. Bill Jenkins, Administrator

Reference: Removal of Four (4) UST's
Ravenna Army Ammunition Plant
R & R Project No. 100214

Gentlemen:

Enclosed please find three (3) copies of our Underground Storage Tank Closure Report for the above referenced project. This report has been prepared as part of our services for Contract No. DAAA09-88-Z-0001.

R & R International appreciates the opportunity to have worked with you on this project and we look forward to a long and successful working relationship with Ravenna Arsenal, Inc. If you have any questions or need further assistance, please do not hesitate to contact our office.

Respectfully,

R & R INTERNATIONAL, INC.

Samuel C. Reed
Manager - Remediation Services

G. M. Rana, P.E.
President

SCR/GMR:mm
Enclosures




CERTIFICATION STATEMENT

I CERTIFY THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE "REQUIREMENTS FOR UNDERGROUND STORAGE TANK REMOVAL," AS PREPARED FOR THE RAVENNA ARSENAL, INCORPORATED. ALL REMOVAL, ABATMENT, RESTORATION AND REPORTING ACTIVITIES WERE CONDUCTED IN ACCORDANCE WITH THE "REQUIREMENTS FOR UNDERGROUND STORAGE TANK REMOVAL" AND APPLICABLE PROVISIONS OF 40 CFR PART 280, "EPA TECHNICAL STANDARDS AND CORRECTIVE ACTION REQUIREMENTS FOR OWNERS AND OPERATORS OF UNDERGROUND STORAGE TANKS;" ARTICLES 28, 35 AND 36 OF THE OHIO ADMINISTRATIVE CODE; AND AMERICAN PETROLEUM INSTITUTE (API) BULLETIN NO. 1604, "RECOMMENDED PRACTICE FOR ABANDONMENT OR REMOVAL OF USED UNDERGROUND SERVICE STATION TANKS."

A handwritten signature in black ink, appearing to read "G. M. Rana", is written over a horizontal line.

G. M. Rana, P.E.


16 APRIL 1990
Date





CERTIFICATION STATEMENT

I CERTIFY THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE "REQUIREMENTS FOR UNDERGROUND STORAGE TANK REMOVAL," AS PREPARED FOR THE RAVENNA ARSENAL, INCORPORATED. ALL REMOVAL, ABATMENT, RESTORATION AND REPORTING ACTIVITIES WERE CONDUCTED IN ACCORDANCE WITH THE "REQUIREMENTS FOR UNDERGROUND STORAGE TANK REMOVAL" AND APPLICABLE PROVISIONS OF 40 CFR PART 280, "EPA TECHNICAL STANDARDS AND CORRECTIVE ACTION REQUIREMENTS FOR OWNERS AND OPERATORS OF UNDERGROUND STORAGE TANKS;" ARTICLES 28, 35 AND 36 OF THE OHIO ADMINISTRATIVE CODE; AND AMERICAN PETROLEUM INSTITUTE (API) BULLETIN NO. 1604, "RECOMMENDED PRACTICE FOR ABANDONMENT OR REMOVAL OF USED UNDERGROUND SERVICE STATION TANKS."



G. M. Rand, P.E.

April 16, 1990
Date



CLOSURE ASSESSMENT REPORT

I. OWNER

NAME: Ravenna Army Ammunition Plant

ADDRESS: 8451 State Rt. 5
Ravenna, Ohio 44266-9297

CONTACT: Mr. Wayne Carkido

TELEPHONE: (216) 297-3237

II. DATE(S) of Tank Removal: February 9, 12, and 13, 1990

III. FIRE INSPECTOR

NAME: Mr. Homer Myers

ADDRESS: 3702 State Rt. 183
Rootstown, Ohio 44272

TELEPHONE: (O) 614-864-5510
(R) 216-325-1375

IV. NEUTRAL THIRD PARTY

NAME: Mr. Homer Myers

AFFILIATION: State Fire Marshal's Office

V. SAMPLER(S)

NAME: Mr. Brad Kinzy

AFFILIATION: R & R International, Inc.

CLOSURE ASSESSMENT REPORT (Continued)

VI. VISUAL SITE EVALUATION - Tank #1 RA #33

1. Tank size 2,000 gallon - Diesel Fuel.
2. Tank under grass and soil mound, top one-half exposed.
3. Excavation did not indicate any visual or olfactory signs of contamination.
4. The tank was intact externally; no holes or visual signs of leaks. Contamination not found according to visual and olfactory inspection of tank exterior.
5. Approximately four (4) yards of contaminated soil removed from the fill pipe area.

VII. VISUAL SITE EVALUATION - Tank #2 RA #11

1. Tank size 15,000 gallon - Diesel fuel under a concrete vault.
2. Excavated pit did not indicate any visual or olfactory signs of contamination in any area..
3. The tank was intact externally; no holes or visual signs of leaks. Contamination not found according to visual and olfactory inspection of tank exterior.
4. Approximately 15 - 20 yards of contaminated soil removed from the suction line area near building.

VIII. VISUAL SITE EVALUATION - Tank #3 RA#22

1. Tank size 15,000 gallon - Diesel fuel under a concrete vault and grass.
2. Excavated pit did not indicate any visual or olfactory sign of contamination in any area.
3. The tank was intact externally; no holes or visual signs of leaks. Contamination not found according to visual and olfactory inspection of tank exterior.
4. Approximately 15 - 20 yards of contaminated soil removed from suction line area near building.



INTERNATIONAL, INC.

CLOSURE ASSESSMENT REPORT (Continued)

IX. VISUAL SITE EVALUATION - Tank #4 RA#23

1. Tank size 15,000 gallon - Diesel fuel under grass.
2. Excavated pit did not indicate any visual or olfactory signs of contamination in any area.
3. The tank was intact externally; no holes or visual signs of leaks. Contamination not found according to visual and olfactory inspection of tank exterior.
4. Approximately eight (8) to ten (10) yards of contaminated soil removed from fill pipe area.

X. SAMPLE COLLECTION PROCEDURE

Soil samples were collected in four (4) ounce teflon-lid glass sample jars using a stainless steel spoon. The sample locations are indicated on the attached site sketch. Samples were collected after scraping up to four (4) inches of soil from the surface. The sampling spoon was decontaminated in between each sample collection by a thorough rinsing with distilled water and wiping dry with a clean tissue. The samples obtained were immediately placed in a cooler, containing ice, for preservation. The samples were kept in the cooler until delivery to the laboratory. A Chain-of-Custody for all samples was started, a copy of which is attached to this report.

XI. LABORATORY

NAME: Holk Environmental Services, Inc.

ADDRESS: 7777 Wall Street
Valley View, Ohio 44125

TELEPHONE: (216) 524-0888

XII. LABORATORY RESULTS

A copy of the Analytical Report from the laboratory forms a part of this report.




CLOSURE ASSESSMENT REPORT (Continued)

XIII. SPECIAL COMMENTS


1. The tanks were cleaned on site by R & R International, Inc. personnel. The resultant sludges and rinsates were disposed of by Chemtron Corporation of Avon, Ohio. The waste analysis data forms a part of this report.
2. The 2,000 gallon tank was disposed of at the E. 79th Scrap and Auto Wrecking in Cleveland, Ohio; the three (3) 15,000 gallon tanks were taken to Holub Iron & Steel Co., Inc. in Akron, Ohio for disposal. Documentation of disposal forms a part of this report.
3. Approximately 50 cubic yards of contaminated soil, removed from the excavations, was disposed of at Norton Landfill A.K.A. Royalton Road Sanitary Landfill in Broadview Heights, Ohio.
4. Due to security restrictions, photographs of the tank removal operations were not obtained.
5. All laboratory test results, Chain-of-Custody records, and tank disposal receipts are presented in Appendix A of this report.

BUILDING
S - 340




SOIL SAMPLE LOCATIONS IA → IF

2000 gal. UST
TANK # 1, RA # 33
R. A. I.
RAVENA, OHIO



SOIL SAMPLE LOCATIONS
 2A — 2E, 3A — 3E
 15,000 gal. USTS
 TANK #2 RA # II
 TANK #3 RA # 22
 R.A.I.
 RAVENA, OHIO



PARKING AREA

BUILDING

PUMP HOUSE

A S T

SOIL SAMPLE LOCATIONS
 4A — 4E
 15,000 GAL. UST
 TANK # 4 RA # 23
 R. A. I.
 RAVENA, OHIO

MAN WAY

FILL PIPE

ROADWAY

N

OHIO DEPARTMENT OF COMMERCE
DIVISION OF STATE FIRE MARSHAL

REGULATIONS PERTAINING TO PETROLEUM UNDERGROUND STORAGE TANK
SUSPECTED RELEASE INVESTIGATIONS AND CORRECTIVE ACTIONS

OAC 1301:7-7-28 (A), (E), (I), (J), AND (K)
OAC 1301:7-7-36
Ohio Revised Code 3737.882 and 3737.99(1)

1301:7-7-28. Article 28: FLAMMABLE AND COMBUSTIBLE LIQUIDS

Note: This reproduction of the Ohio Administrative Code does not contain the full text of Article 28 of the Ohio Fire Code, OAC 1301:7-7-28. The text of this printing contains only those paragraphs of Article 28 that pertain directly to petroleum underground storage tank suspected and confirmed releases and the typical tank repair or replacement activities conducted during release investigations and corrective actions. Other sections of the Ohio Fire Code may apply.

(A) Section F-2800.0. General.

- (1) FM-2800.1. Scope: This rule shall apply to the transportation, storage, handling and processing of flammable and combustible liquids and to any underground storage tank system as defined in paragraph (B) of rule 1301:7-7-02 of the Administrative Code (F-201.0). The provisions of NFIPA 30, NFIPA 30A, NFIPA 329, PEI RP 100-87, API 1604, API 1631 and ASTM G57-78 listed in rule 1301:7-7-34 of the Administrative Code shall apply where the provisions of this rule do not specifically cover conditions and operations.
- (2) FM-2800.2. Permit required: A permit shall be obtained from the fire official for each of the following:
 - (a) To install, remove, repair or alter in any way a stationary tank for the storage of flammable or combustible liquids, or to modify or replace any line.
 - (b) To install, repair or alter in any way, an underground storage tank, to modify or replace any piping connected thereto, to take such tank system temporarily or permanently out of service, or to place an out-of-service tank system back into service. When such a permit is not required by the local fire official the permit shall be obtained from the fire marshal.
 - (c) For the storage, handling or use of class I liquids in excess of five gallons in a dwelling or other place of human habitation, or in excess of ten gallons in any other building or other occupancy, or in excess of sixty gallons outside of any building except that no permit shall be required for the following:
 - (i) For the storage or use of flammable liquids in the fuel tank of a motor vehicle, aircraft, motorboat, mobile power plant or mobile heating plant; or
 - (ii) For the storage or use of paints, oils, varnishes or similar mixtures when such liquids are stored for painting or maintenance, or similar purposes upon the premises, and which are not stored for a period exceeding thirty days.
 - (d) Storage, handling or use of class II combustible liquids or class III combustible liquids in excess of twenty-five gallons in a building, or in excess of sixty gallons outside of a building, except for fuel oil used in connection with oil burning equipment in single-family residential buildings.
 - (e) For the manufacture, processing, blending or refining of flammable or combustible liquids.
 - (f) For the storage of flammable or combustible liquids in stationary tanks.
 - (g) For placing any flammable or combustible liquid stationary tank temporarily or permanently out of service and to place said tank back into service (see paragraph (E)-(9) below [FM-2804.9]).
 - (h) Permits shall be obtained from the fire marshal for above-ground flammable and combustible liquid tank installations in bulk plants. This paragraph applies only

where a permit is not obtained from another officer mentioned in section 3737.14 of the Revised Code.

- (3) FM-2800.3. Permit application: The application for a permit shall be submitted in such form as the fire official may prescribe and shall be accompanied by drawings and such additional information as may be required by the fire official. Permit and inspection fees which are required by ordinance shall accompany all applications. When a permit required by paragraph (A)(2)(b) of this rule is obtained from the fire marshal, an inspection fee in the amount of fifty dollars shall be paid to the fire marshal for each underground storage tank permit.
 - (4) F-2800.3.1. Stationary tank information: The application to install, remove, repair or alter any stationary tank for the storage of flammable or combustible liquids shall contain a general description of the proposed work and shall include two copies of a drawing indicating location, use, capacity and piping arrangement of all existing and proposed tanks located, or which are to be located, upon the premises and all adjacent buildings and property lines. Information which confirms that the tank meets the design requirements in paragraph (B)(2) below (F-2801.2) shall be attached to or made a part of the application.
- (E) Section 2804.0. Underground storage tanks.
- (1) FM-2804.1. Underground storage tank program compliance. All underground storage tank systems containing flammable or combustible liquids shall comply with the requirements of rule 1301:7-7-35 of the Administrative Code.
 - (2) FM-2804.2. Location: Underground storage tanks containing flammable or combustible liquids shall be located at least five feet from any wall, foundation or property line. The top of flammable liquid tanks shall be below the lowest floor level of any building within twenty feet of said tanks. Tanks shall not be located in or under any building unless said building and tank installation is constructed in accordance with the building code and NFIPA 30 listed in rule 1301:7-7-34 of the Administrative Code. A distance of at least one foot shall be maintained between underground tanks in multiple tank installations.
 - (3) FM-2804.3. Special conditions: The fire official may require greater separations or he may limit the storage capacity when the installation is subject to a severe exposure hazard or topographical conditions when necessary for the safety of the general public.
 - (4) FM-2804.4. Tank protection installation: Underground storage tanks containing flammable or combustible liquids shall comply with the following installation requirements:
 - (a) Steel tanks. Cathodically protected steel or approved noncorrosive coated steel underground storage tanks shall be set on a firm foundation and surrounded with at least six inches of noncorrosive inert material such as clean sand or gravel well tamped in place. Tanks, and the six inches of protective material, shall be covered with a minimum of two feet of earth or shall be covered with eighteen inches of earth, on top of which shall be placed a slab of reinforced concrete not less than four inches thick. When underground tanks are, or are likely to be, subjected to vehicular traffic, they shall be protected against damage by at least eighteen inches of earth, over the six inches of protective material, plus six inches of reinforced concrete or eight inches of asphaltic concrete. The reinforced concrete or asphaltic concrete protective cover shall extend at least one foot horizontally beyond the outline of the tank. When new tanks are located in an area that may be subjected to flooding or corrosion, applicable precautions shall be used in accordance with NFIPA 30 listed in rule 1301:7-7-34 of the Administrative Code.
 - (b) Fiberglass-reinforced plastic (FRP) tanks shall be installed in accordance with the manufacturer's specifications.
 - (5) FM-2804.5. Tank construction: Underground storage tanks containing flammable or combustible liquids shall meet the following requirements:
 - (a) Tanks shall be designed and built to prevent releases due to corrosion or structural failure for the operational life of the tank, using noncorrosive material or cathodi-

cally protected steel.

- (b) The material used in constructing or lining the tank shall be compatible with the substance to be stored.
 - (c) Steel tank systems shall be cathodically protected by an impressed current cathodic protection system, sacrificial anodes, or some other type of equivalent protection. If a cathodic protection system is used, it shall be maintained in accordance with paragraph (e)(5)(d) below. Selection of the type of protection to be employed shall be based upon the corrosion history of the area and the judgment of a qualified engineer. If a soil test conducted in accordance with ASTM standard G57-78, or another standard approved by the fire marshal, indicates that soil resistivity in an installation location is twelve thousand ohms per centimeter or more (unless a more stringent standard is prescribed by the fire marshal by rule), a storage tank without corrosion protection may be installed in that location during the period until new standards are promulgated by the administrator of the United States environmental protection agency.
 - (d) If a cathodic protection system is installed, an ongoing preventative maintenance program shall be used. Where sacrificial anodes have been installed, their proper operation shall be confirmed by the installer within six to twelve months of installation and one year thereafter. If these tests confirm proper operation, subsequent inspection intervals can be extended to five years. However, if underground work is performed at a protected site, cathodic protection should be remonitored six to twelve weeks after work is completed and one year thereafter before again extending the inspection interval. If an impressed current cathodic protection system is installed, the operator shall verify, at least once a month, that it is operating, and a qualified person shall conduct an on-site test and inspection, at least once a year, to measure the structure to soil and structure-to-structure potentials and the rectifier voltage and current output.
- (6) F-2804.6. Vent piping: Vent pipes from underground tanks containing flammable liquids shall be so located that the discharge point is outside of buildings, higher than the fill pipe opening and not less than twelve feet above the adjacent ground level. Vent pipes shall discharge only upward in order to disperse vapors. Each tank shall be vented through piping adequate in size as specified in the standards listed in rule 1301:7-7-34 of the Administrative Code, to prevent flow-back of vapor or liquid at the fill opening while the tank is being filled. Threaded joints and connections shall be liquid-tight with a suitable lubricant or piping compound.
- (7) F-2804.7. Fill piping: Fill piping passing through concrete shall be located in sleeves, mastic or the equivalent to protect against settlement, frost action and vibration. Welded or screwed joints or approved connectors shall be used. Threaded joints and connections shall be made liquid-tight and shall be made tight with a suitable lubricant or piping compound. Fill pipes shall terminate within six inches of the bottom of the tank.
- (8) FM-2804.8. Testing: All underground storage tanks containing flammable or combustible liquids shall be subjected to the following tests.
- (a) All tanks shall be strength tested before they are placed in service in accordance with the applicable provisions of the code or standard under which they were built. The "American Society of Mechanical Engineers" (ASME) code stamp, "American Petroleum Institute" (API) monogram, the label of the "Under writer's Laboratories, Inc." (UL), or the "Underwriter's Laboratories of Canada" (ULC) or an approved equivalent identification label on a tank shall be evidence of compliance with the strength test.
 - (b) Before tanks are placed into the hole they shall be tested with not less than three psi or more than five psi air pressure. All leaks or deformations shall be corrected in a manner approved by the fire official before the tanks are placed into the hole. Mechanical caulking is not permitted for correcting leaks in welded tanks.
 - (c) After the tank is set in the excavation and all lines are connected another air test

- shall be conducted. This test must be conducted before the lines and the tank are covered over and before the tank is filled with product.
- (d) When the vertical length of the fill and vent pipes is such that when filled with liquid the static head imposed upon the bottom of the tank exceeds ten psig, the tank and related piping shall be tested hydrostatically to a pressure equal to the static head thus imposed. In special cases where the height of the vent above the top of the tank is excessive, the hydrostatic test pressure shall be specified by the fire official.
 - (e) Periodic tests of underground tank storage systems may be required by the fire official to determine that leakage has not occurred. Testing shall be done in accordance with NFIPA 329 listed in rule 1301:7-7-34 of the Administrative Code.
- (9) FM-2804.9. Abandonment of tanks: A permit shall be obtained from the fire official to remove, abandon, place temporarily out of service or otherwise dispose of any underground storage tank containing flammable or combustible liquids. When such a permit is not required from the local fire official the permit shall be obtained from the fire marshal.
- (a) Tanks "temporarily out of service" shall have the fill line, gauge opening and pump connection secured against tampering. Vent lines shall remain open and be maintained in accordance with the requirements of this rule for vent lines.
 - (b) Any tank not used for a period of ninety days shall be properly safeguarded or removed in a manner approved by the fire official.
 - (c) Any tank which has been abandoned for a period of one year shall be removed from the property in a manner approved by the fire official and the site restored in an approved manner. When the fire official determines that the removal of the tank is not necessary, he may permit the tank to be abandoned in place in accordance with API 1604 listed in rule 1301:7-7-34 of the Administrative Code, and including the following methods:
 - (i) Remove all flammable or combustible liquid from the tank and all connecting lines.
 - (ii) Disconnect the suction, inlet, gauge, and vent lines.
 - (iii) Fill the tank completely with an inert solid material. Cap remaining underground piping.
 - (iv) Keep a record of tank size, location, date of abandonment, and method used for placing the abandoned tank in a safe condition.
 - (d) Tanks which are to be reinstalled for flammable or combustible liquid service shall comply with all the provisions of this rule.
 - (e) Tanks which are to be returned to service shall be tested in accordance with NFIPA 329 listed in rule 1301:7-7-34 of the Administrative Code.
- (1) Section FM-2808.0. Tank lining. Procedure for the interior coating and repair of leaking and/or deteriorated underground storage tanks containing flammable or combustible liquids (both steel and nonmetallic).
- (1) FM-2808.1. The local fire official shall determine whether or not the repair of leaking and/or deteriorating underground storage tanks containing flammable or combustible liquids shall be permitted within its jurisdiction. If such repair is permitted by the local fire official, it shall be accomplished in the manner prescribed in paragraphs (1)(2) and (1)(5) below.
 - (2) FM-2808.2. Manufacturers desiring to have their product used in Ohio shall register the specifications for the internal coating system for the repair of underground storage tanks containing flammable or combustible liquids with the fire marshal. The specifications shall

clearly describe the composition of the product, strength, limitations on use, preparation procedures, application procedures, quality control techniques, curing times and temperatures, field thickness testing procedures, field hardness testing procedures, and a method for determining whether an existing tank is repairable. This information, along with the results of the standards tests, shall be signed and sealed by a registered professional engineer.

- (3) FM-2808.3. Each manufacturer who has registered an internal coating system must submit to the fire marshal a list of qualified applicators. It is the responsibility of the manufacturer to keep this list current. The list shall indicate that the applicator is qualified to seal metal tanks, nonmetallic tanks or both. The internal coating procedure shall be in accordance with API 1631 listed in rule 1301:7-7-34 of the Administrative Code.
- (4) FM-2808.4. The applicator shall inform the following officials of the location of each project in the following manner:
 - (a) The local fire authority shall have in its possession a written notice stating the location of the project and the applicator's anticipated timetable for each stage of the project, prior to the commencement of the project. A copy of such written notice shall be mailed to the fire marshal simultaneously with its delivery to the local fire authority.
 - (b) Any applicator failing to make proper notification of the project location will be removed, for a period of six months, from the qualified applicator list on file with the fire marshal. Reinstatement can be accomplished only by the manufacturer resubmitting the applicator's name after the six-month period has elapsed.
 - (c) A current "Certificate of Insurance" covering the liability of the applicator shall be filed with the fire marshal.
 - (d) A sample of the "Application for Tank Repairs" may be obtained from the fire marshal.
- (5) FM-2808.5. A "Certificate of Performance" shall be utilized as follows:
 - (a) A "Certificate of Performance" on each field application shall be submitted to the local fire authority. The certificate (to be designed by the fire marshal and printed and supplied by the contractor) shall be signed by the qualified applicator and will confirm that the tank preparation and product application complies with the sealant manufacturer's specifications which are registered with the fire marshal.
 - (b) A sample of the "Certificate of Performance" may be obtained from the fire marshal.
- (J) Section FM-2809.0. Leak detection. Inventory records for underground storage tanks containing flammable and combustible liquids shall be maintained by the owner or operator of such tank. The procedures for inventory control are as follows:
 - (1) FM-2809.1. Daily inventory records shall be kept for each tank at each location by the operator. Such records shall be available at the location for inspection at any time by a proper authority and shall cover at least ninety days prior to the date of inspection.
 - (2) FM-2809.2. The inventory referred to in paragraph (J)(1) above shall be based on the actual measurement of tank liquid levels daily. The written record of such testing shall include a computation of daily gain or loss. The operator of the location shall be responsible for taking action to correct any abnormal loss or gain not explainable by temperature variations or other causes. Such abnormal loss or gain shall be reported promptly by the operator to the local fire official and fire marshal pursuant to paragraph (K) of this rule (FM-2810.0).
 - (3) FM-2809.3. The mere recording of pump meter readings combined with shipment records shall not constitute adequate inventory records for the purpose of this rule.
 - (4) FM-2809.4. Exemptions. The requirements for daily inventory records shall not apply in the following situations:

- (a) Daily inventories are not required to be maintained when an installation is not in operation, except that during such an operation when an inventory must be taken at least once every seven days.
 - (b) Daily inventories need not be maintained for storage tanks connected to oil burning equipment.
 - (c) Daily inventories need not be maintained for storage tanks connected to manufacturing equipment.
- (5) FM-2809.5. The following actions shall be taken by the operator daily:
- (a) The operator shall record all meter totalizer readings, immediately gauge and record all tank measurements and balance inventory and product transferred.
 - (b) The operator shall record and make adjustments for all transfers of product occurring during gauging period.
 - (c) The operator shall retain all of the aforementioned records.
 - (d) The operator shall check all tanks for water. Experience will indicate whether daily checks are required or if they can be made less frequently. In any circumstances, the check must be made once a week. Tanks should be checked for water after a thaw and after a delivery.
- (K) Section FM-2810.0. Underground storage tank release reporting and confirmation.
- (1) FM-2810.1. Suspected releases requiring reporting. All owners and operators of underground storage tank containing flammable or combustible liquids shall report within twenty-four hours to the fire official and the fire marshal any of the following conditions:
- (a) Test, sampling, or monitoring results from a release detection method specified under paragraph (J) of this rule (FM-2809.0), Or any other release detection method used, that indicates a release may have occurred;
 - (b) Unusual operating conditions such as erratic behavior of product dispensing equipment, the sudden loss of product from a tank system, an unexplained presence of water in the tank or the physical presence of water in the tank, or the physical presence of the regulated substance or an unusual level of vapors on the site that are of an unknown origin;
 - (c) Impacts in the surrounding area, such as evidence of regulated substances or resulting vapors in soils, basements, sewer and utility lines, and nearby surface water;
 - (d) An indication from a gas chromatography or equivalent method that there is a concentration of at least one hundred parts per million of total hydrocarbons in a soil sample; and
 - (e) Any spill or overflow of petroleum that exceeds twenty-five gallons or causes a sheen on any surface water. Any spill or overflow of petroleum of twenty-five gallons or less must be contained and cleaned up immediately, and if such cleanup cannot be accomplished within twenty-four hours, the fire official and the fire marshal shall be notified within twenty-four hours of the spill or overflow.
- (2) FM-2810.2. Release investigation and confirmation. Unless corrective action is initiated by the owner or operator under rule 1301:7-7-36 of the Administrative Code for releases of petroleum, or as otherwise directed by the fire marshal, all suspected releases requiring reporting under this paragraph must be immediately investigated by the owner or operator using one of the following applicable procedures of this paragraph. Confirmation of a petroleum release by one of these methods will require the owner and operator to comply with the requirements for corrective action under rule 1301:7-7-36 of the Administrative Code.

- (a) In the case of an underground storage system having secondary containment, an investigation of a possible release into the interstitial area between the underground storage tank and the secondary barrier using procedures that will determine if the interstitial monitoring is working properly;
- (b) In the case of a failed tank or piping tightness test, an investigation in the following manner:
 - (i) A check of inventory records to detect a discrepancy that indicates a release may have occurred in accordance with the requirements of paragraph (J) of this rule.
 - (ii) Isolation from the tank and retesting of the piping within seven days of the initial reporting to the fire marshal to determine if a release may have occurred in accordance with the requirements in paragraph (J) of this rule;
 - (iii) Isolation from the piping and retesting of the tank within seven days of the initial reporting to the implementing agency to determine if a release may have occurred in accordance with the requirements in paragraph (J) of this rule (after the top of the tank has been excavated and all loose fitting vent pipes or other equipment has been checked, replaced or tightened); and
 - (iv) Analysis of soil core samples for hydrocarbon and/or chemical contamination in the unsaturated zone under the underground storage tank system, or, when the ground water is no more than twenty feet from the ground surface, analysis of ground-water samples for hydrocarbon and/or chemical contamination.
- (c) In the case of a discrepancy during inventory reconciliation in accordance with paragraph (J) of this rule, or any other suspected release, an investigation conducted in the following manner:
 - (i) A tightness test of the tanks and piping that is conducted within seven days of the initial reporting to the fire marshal to determine if a release may have occurred; and
 - (ii) Analysis of soil core samples for hydrocarbon and/or chemical contamination in the unsaturated zone under the underground storage tank system, or, when the ground water is no more than twenty feet from the ground surface, analysis of ground-water samples for hydrocarbon and/or chemical contamination.
- (d) A site-specific investigation, under the direction of the fire marshal, of the suspected release incident to determine if a release has occurred and reached soils outside of the excavation zone or ground water;
- (e) Any other investigation procedure that is no less stringent than any of the procedures in paragraphs (a) to (c) of this rule and is approved for that underground storage tank system by the fire marshal.

Effective: 5/9/88

Original Signed
Certification

April 29, 1988
Date

Promulgated Under: 119.03 + 3737.86
Authorized By: 3737.02 + 3737.82
Amplifies: 3737.82
Prior Effective Date: 7/1/79
6/1/85.

1301:7-7-36. CORRECTIVE ACTIONS AND COST RECOVERY STANDARDS FOR PETROLEUM UNDERGROUND STORAGE TANK RELEASES.

(A) General

- (1) Purpose. For the purpose of prescribing rules pursuant to section 3737.88 of the Revised Code, the fire marshal hereby adopts this rule to establish standards for corrective actions for releases of petroleum from underground storage tanks and standards for the recovery of costs for undertaking corrective or enforcement actions with respect to such releases. This rule is adopted by the fire marshal in accordance with Chapter 119. of the Revised Code and shall not be considered a part of the "Ohio Fire Code."
 - (2) Scope. This rule shall apply to any suspected or confirmed release of petroleum from an underground storage tank as defined in paragraph (B) of rule 1301:7-7-35 of the Administrative Code.
 - (3) Requirement. All owners and operators of UST systems, in response to a suspected or confirmed release of petroleum from a UST system, shall comply with the requirements of this rule. These provisions apply to all UST systems containing petroleum as defined in paragraph (B) of rule 1301:7-7-35 of the Administrative Code.
 - (4) Fire marshal corrective actions. All corrective actions undertaken by the fire marshal or assistant fire marshal pursuant to division (A)(3) of section 3737.88 of the Revised Code shall be consistent with the requirements of this rule.
- (B) Definitions. When used in this rule, the terms shall have the same meaning as those defined in paragraph (B) of rule 1301:7-7-35 of the Administrative Code.
- (C) Initial abatement requirements, procedures, and evaluation.
- (1) Suspected release confirmation. All suspected releases requiring reporting under paragraph (K) of rule 1301:7-7-28 of the Administrative Code shall be investigated and confirmed or disproved by the owner or operator in a manner consistent with paragraph (K) of rule 1301:7-7-28 of the Administrative Code to establish whether the corrective action requirements of this rule shall be followed.
 - (2) Upon confirmation of an actual release in accordance with paragraph (K) of rule 1301:7-7-28 of the Administrative Code, or discovery of a release in any other manner, the owners and operators shall:
 - (a) Report the release to the fire official and fire marshal within twenty-four hours pursuant to paragraph (K) of rule 1301:7-7-28 of the Administrative Code;
 - (b) Stop any further release from the UST system;
 - (c) Mitigate all fire, explosion, and safety hazards;
 - (d) Remove and properly dispose of all visibly contaminated soil and any associated groundwater from the excavation zone;
 - (e) Conduct an investigation to determine the possible presence of free product and initiate removal of any free product found as soon as practicable;
 - (f) Report all initial corrective action taken pursuant to this paragraph, including a verification of tank repair or closure if appropriate, to the fire official and the fire marshal within twenty days of the confirmation or discovery of the release.
 - (3) Site investigation. The owner and operator shall perform a site investigation for contaminated soil, groundwater, or free product and shall assemble from such an investigation, or from other sources (e.g., USGS maps, SCS soil maps, ODNR, OEPA, and other agencies), any information deemed necessary by the fire marshal. The site investigation and information shall include, but is not limited to, the following:

- (a) Data on the nature and estimated quantity of the released substance;
 - (b) Data from surface and subsurface soil sampling and analyses;
 - (c) Data from groundwater and/or surface-water sampling and analyses; and
 - (d) Data from available sources and/or site investigations concerning background levels prior to the release, water quality and use, well locations, subsurface soil conditions, climatological conditions, land use, and surrounding populations.
- (4) Reporting. The results of this site investigation and all required information shall be reported to the fire marshal within twenty days of the confirmation or discovery of the release unless otherwise directed by the fire marshal. The fire marshal may request the collection and submission of additional information and/or a corrective action plan for additional soil, surface-water, and groundwater cleanup.
- (D) Free product removal. At sites where an owner or operator's investigations under paragraph (C)(2) of this rule indicate the presence of a free product, the owner or operator shall remove free-floating product to the maximum extent practicable while continuing, as necessary, any action initiated under paragraph (C) of this rule, and while preparing for subsequent actions required under paragraph (E) or (F) of this rule. In meeting the requirements of this paragraph, the owner or operator shall:
- (1) Conduct free product recovery in such a manner that such actions do not spread contamination into previously uncontaminated areas through untreated discharge or improper disposal techniques.
 - (2) Conduct free product recovery in such a manner that such actions do not produce vapors in the atmosphere at levels such that they pose a health and safety threat to previously uncontaminated areas.
 - (3) Handle any flammable products in a safe and competent manner to prevent fires or explosions.
 - (4) Unless directed to do otherwise by the fire marshal, prepare and submit, within thirty days of the confirmation or discovery of the release, a free product removal report to the fire marshal. The report shall provide, but is not limited to, the following information:
 - (a) The name of the person(s) responsible for implementing the plan;
 - (b) The estimated quantity and type of product on site and the product thickness in wells, boreholes, and excavations;
 - (c) Details of the product recovery system;
 - (d) Whether any discharge will take place on or off site during the recovery operation;
 - (e) The type of treatment and expected effluent quality from any discharge; and
 - (f) The disposition of the recovered product.
- (E) Site assessment. Whenever an investigation under paragraph (C)(3) of this rule indicates that there may be remnant soil contamination from the release, or that the released product or product from contaminated soil may have reached groundwater, or as otherwise directed by the fire marshal, the owners and operators shall:
- (1) Conduct additional investigations of the release, the release site, and the surrounding area possibly affected by the release, to determine the full extent and location of the soils contaminated by the release.
 - (2) Conduct additional investigations of the release, the release site, and the surrounding area possibly affected by the release to determine the presence of dissolved contamination due to the release in the ground water.

- (3) When directed by the fire marshal, conduct an exposure assessment to determine the extent of exposure of, or potential for exposure of, individuals to petroleum from the release. Such assessment shall be based on such factors as the nature and extent of contamination and the existence of or potential for pathways of human exposure, the size of the community within the likely pathways of exposure, and the comparison of expected human exposure levels to the short-term and long-term health effects associated with identified contaminants and any available recommended exposure or tolerance limits for such contaminants.
 - (4) The information collected by the owners and operators during the course of the investigations under this paragraph shall be submitted in accordance with a schedule established by the fire marshal.
 - (5) The fire marshal may request the submission of a corrective action plan for additional soil and/or ground-water cleanup.
- (F) Soil and ground-water cleanup.
- (1) Owners and operators required by the fire marshal under this rule to develop and submit a corrective action plan for responding to any contaminated soils, surface waters, or ground waters shall submit such a plan according to a schedule established by the fire marshal.
 - (2) The fire marshal shall approve the corrective action plan only if it assures that implementation of the plan will provide adequate protection of human health, safety, and the environment. In making this determination, the fire marshal shall consider:
 - (a) The physical and chemical characteristics of the petroleum substance, including its toxicity, persistence, and potential for migration;
 - (b) The hydrogeologic characteristics of the facility and the surrounding land;
 - (c) The proximity, quality, and current and future uses of ground water and surface waters; and
 - (d) The results of an exposure assessment when such an assessment is required.
 - (3) Upon approval of the corrective action plan, the owners and operators shall implement the plan and monitor, evaluate, and report the results of implementation, as required by the fire marshal.
- (G) Public participation.
- (1) Corrective action plans. For each corrective action plan submitted to the fire marshal under paragraph (F) of this rule, and prior to the approval of such plan, the fire marshal shall provide an opportunity for public review and comment on the plan. The fire marshal shall provide notice to the public by means designed to reach those members of the public most directly affected by the release and the planned corrective action. Public notice shall provide adequate time for the review of the submitted plan by the affected public. Such notice may include, but is not limited to, public notice in local newspapers, including block advertisements, public service announcements, or letters to individual households.
 - (2) If there is sufficient public interest, or for any other reason, the fire marshal may hold a public meeting to consider comments on the corrective action plan. The fire marshal shall hold a public meeting in any case where implementation of an approved corrective action plan does not achieve the established cleanup levels and termination of that plan is under consideration by the fire marshal.
 - (3) In deciding whether to approve or modify the corrective action plan, the fire marshal shall consider and respond to the comments from the public.
- (H) Owner or operator liable for costs. The owner or operator of an underground storage tank from which a release of petroleum has occurred is liable to the state for any costs incurred for any corrective or enforcement action undertaken by the fire marshal, assistant fire marshal, or attorney general, that

is conducted pursuant to section 3737.88 of the Revised Code. The liability under this paragraph shall be construed to be the standard of liability which obtains under section 311 of the Federal Clean Water Pollution Act.

- (1) Cost recovery. In determining the equities for seeking the recovery of costs under this rule, the fire marshal may consider the amount of financial responsibility required to be maintained under subsections (C) and (D)(5) of section 9003 of the Resource Conservation and Recovery Act, as amended, and the factors considered in establishing such amount under subsection (D)(5) of such act.
- (2) Effect on liability.
 - (a) No transfer of liability. No indemnification, hold harmless, or similar agreement or conveyance shall be effective to transfer from the owner or operator of any underground storage tank or from any person who may be liable for a release or threat of release under this paragraph, to any other person the liability imposed under this paragraph.
 - (b) No bar to cause of action. Nothing in this paragraph, including the provisions of paragraph (H)(2)(a) of this rule, shall bar a cause of action that an owner or operator or any person subject to liability under this rule, or a guarantor, has or would have, by reason of subrogation or otherwise against any person.

Effective: 5/9/88

ORIGINAL SIGNED
certification

APRIL 29, 1988
date

promulgated under: 119.03 + 3737.86
Authorized by: 3737.88
Amplifies: 3737.88
Prior effective date: none.

Sec. 3737.882. (A) If, after an examination or inspection, the fire marshal or an assistant fire marshal finds that a release of petroleum is suspected, he shall take such action as he considers necessary to ensure that a suspected release is confirmed or disproved and, if the occurrence of a release is confirmed, to correct the release. These actions may include one or more of the following:

(1) Issuance of a citation and order requiring the responsible person to undertake, in a manner consistent with the requirements of section 9003 of the "Resource Conservation and Recovery Act of 1976," 98 Stat. 3279, 42 U.S.C.A. 6991b, as amended, applicable regulations adopted thereunder, and rules adopted under division (B) of this section, such actions as are necessary to protect human health and the environment, including, without limitation, the investigation of a suspected release.

(2) Requesting the attorney general to bring a civil action for appropriate relief, including a temporary restraining order or preliminary or permanent injunction, in the court of common pleas of the county in which a suspected release is located or in which the release occurred, to obtain the corrective action necessary to protect human health and the environment. In granting any such relief, the court shall ensure that the terms of the temporary restraining order or injunction are sufficient to provide comprehensive corrective action to protect human health and the environment.

(3) Entry onto premises and undertaking corrective action with respect to a release of petroleum if, in his judgment, such action is necessary to protect human health and the environment. Any corrective action undertaken by the fire marshal or assistant fire marshal under division (A)(3) of this section shall be consistent with the requirements of sections 9003 and 9005 of the "Resource Conservation and Recovery Act of 1976," 98 Stat. 3279, 42 U.S.C.A. 6991b, and 98 Stat. 3284, 42 U.S.C.A. 6991e, respectively, as amended, applicable regulations adopted thereunder, and rules adopted under division (B) of this section.

(B) The fire marshal shall adopt, and may amend and rescind, such rules as he considers necessary to establish standards for corrective actions for suspected and confirmed releases of petroleum and standards for the recovery of costs incurred for undertaking corrective or enforcement actions with respect to such releases. The rules also shall include requirements for financial responsibility for the cost of corrective actions for and compensation of bodily injury and property damage incurred by third parties that are caused by releases of petroleum. Rules regarding financial responsibility shall, without limitation, require responsible persons to provide evidence that the parties guaranteeing payment of the deductible amount established under division (E) or (F) of section 3737.91 of the Revised Code are, at a minimum, secondarily liable for all corrective action and third-party liability costs incurred within the scope of the deductible amount. The rules shall be consistent with sections 9003 and 9005 of the "Resource Conservation and Recovery Act of 1976," 98 Stat. 3279, 42 U.S.C.A. 6991b, and 98 Stat. 3284, 42 U.S.C.A. 6991e, respectively, as amended, and applicable regulations adopted thereunder.

(C)(1) No person shall violate or fail to comply with a rule adopted under division (A) of section 3737.88 of the Revised Code or division (B) of this section, and no person shall violate or fail to comply with the terms of any order issued under division (A) of section 3737.88 of the Revised Code or division (A)(1) of this section.

(2) Whoever violates division (C)(1) of this section or division (F) of section 3737.881 of the Revised Code shall pay a civil penalty of not more than ten thousand dollars for each day that the violation continues. The fire marshal may, by order, assess a civil penalty under this division, or he may request the attorney general to bring a civil action for imposition of the civil penalty in the court of common pleas of the county in which the violation occurred. If the fire marshal determines that a responsible person is in violation of division (C)(1) of this section or division (F) of section 3737.881 of the Revised Code, the fire marshal may request the attorney general to bring a civil action for appropriate relief, including a temporary restraining order or preliminary or permanent injunction, in the court of common pleas of the county in which the underground storage tank or, in the case of a violation of division (F)(3) of section 3737.881 of the Revised Code, the training program that is the subject of the violation is located. The court shall issue a temporary restraining order or an injunction upon a demonstration that a violation of division (C)(1) of this section or division (F) of section 3737.881 of the Revised Code has occurred or is occurring.

Any action brought by the attorney general under this division is a civil action, governed by the rules of civil procedure and other rules of practice and procedure applicable to civil actions.

(D) Orders issued under division (A) of section 3737.88 of the Revised Code and divisions (A)(1) and (C) of this section, and appeals thereof, are subject to and governed by Chapter 3745. of the Revised Code. Such orders shall be issued without the necessity for issuance of a proposed action under that chapter. For purpose of appeals of any such orders, the term "director" as used in Chapter 3745. of the Revised Code includes the fire marshal and an assistant fire marshal.

Sec. 3737.99

(I) Whoever knowingly violates division (C) of section 3737.882 of the Revised Code is guilty of an unclassified felony and shall be fined not more than twenty-five thousand dollars or imprisoned for not more than fourteen months, or both. Whoever recklessly violates division (C) of section 3737.882 of the Revised Code is guilty of a misdemeanor of the first degree.

OHIO DEPARTMENT OF COMMERCE
DIVISION OF STATE FIRE MARSHAL
BUREAU OF UNDERGROUND STORAGE TANK REGULATIONS

CORRECTIVE ACTION GUIDANCE
FOR PETROLEUM RELEASES

January 15, 1988

Section 3737.88 of the Ohio Revised Code requires that when the State Fire Marshal finds that a release of petroleum from an underground storage tank has occurred, he shall take actions necessary to protect human health and the environment.

This list of corrective action steps for petroleum releases from UST systems have been prepared to assist UST owners and operators in conducting the corrective action activities required by the State Fire Marshal when a release is discovered. Nothing in this guidance is intended to supercede any action taken by the Fire Marshal or any other local, state, or federal agency or regulation, nor does this list relieve the UST system owner or operator from compliance with any applicable local, state or federal regulations.

General Requirements

These requirements apply to any suspected or confirmed release of petroleum from an underground storage tank. All owners and operators of UST systems, in response to a suspected or confirmed release of petroleum from an UST system, shall comply with these requirements.

Unless otherwise indicated, all reports required by the State Fire Marshal must be submitted in writing to:

Ohio Division of State Fire Marshal
Bureau of Underground Storage Tank Regulation
7510 East Main Street
P.O. Box 525
Reynoldsburg, Ohio 43068-3395

Suspected Release Confirmation

- (A) All suspected releases of petroleum from UST systems must be reported to the local fire department and the State Fire Marshal within 24 hours of their discovery. The report to the State Fire Marshal may be made by calling 614-752-7938 or 1-800-686-2878.

Any suspected release that affects surface or drinking water supplies must be reported to the Ohio Environmental Protection Agency at 1-800-282-9378.

Any suspected release that threaten's Ohio's wildlife must be reported to the Ohio Department of Natural Resources at 614-265-4300.



- (B) Suspected releases must be immediately investigated and either confirmed or disproved by a method acceptable to the local fire department and the State Fire Marshal.
- (C) If a suspected release is confirmed, the owners and operators of the UST system must undertake all required corrective actions.

Initial Corrective Actions

The following steps must be taken at all confirmed petroleum releases sites:

- (A) Upon confirmation of an actual release, or discovery of a release in any other manner, the owners and operators of the UST system must:
 - (1) Report the confirmed releases to the local fire department and the State Fire Marshal within twenty-four hours.
 - (2) Stop any further release from the UST system;
 - (3) Mitigate all fire, explosion, and safety hazards;
 - (4) Remove and properly dispose of all visibly contaminated soil and any associated groundwater from the excavation zone. The disposal of contaminated soil or water must comply with all applicable local, state and federal regulations;
 - (5) Conduct an investigation to determine the possible presence of free product and initiate removal of any free product found as soon as practicable;
 - (6) Report all initial corrective action taken, including a verification of tank repair or closure if appropriate, to the local fire department and the State Fire Marshal within twenty days of the confirmation or discovery of the release.
 - (7) All UST system repairs, removals, abandonment, installation, and replacement must comply with the requirements of the Ohio Fire Code and all other local and state regulations. The Ohio Fire Code requires a permit from the fire official for all such actions.
- (B) Site investigation. The owner and operator must perform a site investigation for contaminated soil, groundwater, or free product and assemble from the investigation, or from other sources (e.g., USGS maps, SCS soil maps, Ohio Department of Natural Resources Division of Water, Ohio Environmental Protection Agency, and other agencies), any information deemed necessary by the State Fire Marshal. The site investigation and information must include, but is not limited to, the following:
 - (1) Data on the nature and estimated quantity of the released substance;
 - (2) Data from surface and subsurface soil sampling and analyses;

- (3) Data from groundwater and/or surface water sampling and analyses; and
 - (4) Data from available sources and/or site investigations concerning background levels prior to the release, water quality and use, well locations, subsurface soil conditions, climatological conditions, land use, and surrounding populations.
- (C) Reporting. The results of this site investigation and all required information must be reported to the State Fire Marshal within twenty days of the confirmation or discovery of the release unless otherwise directed by the Fire marshal. The State Fire Marshal may request the collection and submission of additional information and/or a corrective action plan for additional soil, surface water, and groundwater cleanup.

Free Product Removal

The following steps must be taken at **all release sites where free product has been found**:

- (A) At sites where an owner or operator's investigations indicate the presence of a free product, the owner or operator must remove free floating product to the maximum extent practicable while continuing, as necessary, all other corrective action steps initiated, and while preparing for subsequent long term corrective actions. In meeting this requirement, the owner or operator shall:
 - (1) Conduct free product recovery in such a manner that such actions do not:
 - (a) spread contamination into previously uncontaminated areas through untreated discharge or improper disposal techniques, or
 - (b) produce vapors in the atmosphere at levels such that they pose a health and safety threat to previously uncontaminated areas.
 - (2) Handle any flammable products in a safe and competent manner to prevent fires or explosions.
- (B) Unless directed to do otherwise by the State Fire Marshal, prepare and submit, within thirty days of the confirmation or discovery of the release, a free product removal report to the State Fire Marshal. The report shall provide, but is not limited to, the following information:
 - (1) The name of the person(s) responsible for implementing the plan;
 - (2) The estimated quantity and type of product on site and the product thickness in wells, boreholes, and excavations;
 - (3) Details of the product recovery system;

- (4) Whether any discharge will take place on or off site during the recovery operation;
- (5) The type of treatment and expected effluent quality from any discharge; and
- (6) The disposition of the recovered product.

Site Assessment

The following steps must be taken at all **release sites where remaining soil or groundwater contamination has been found**:

- (A) Whenever an investigation indicates that there may be remaining soil contamination from the release, or that the released product or product from contaminated soil may have reached groundwater, or as otherwise directed by the State Fire Marshal, the owners and operators must:
 - (1) Conduct additional investigations of the release, the release site, and the surrounding area possibly affected by the release, to determine the full extent and location of the soils contaminated by the release; and
 - (2) Conduct additional investigations of the release, the release site, and the surrounding area possibly affected by the release to determine the presence of dissolved contamination due to the release in the groundwater.
- (B) When directed by the State Fire Marshal, conduct an exposure assessment to determine the extent of exposure of, or potential exposure for exposure of, individuals to petroleum from the release. Such assessment shall be based on such factors as the nature and extent of contamination and the existence of or potential for pathways of human exposure, the size of the community within the likely pathways of exposure, and the comparison of expected human exposure levels to the short-term and long-term health effects associated with identified contaminants and any available recommended exposure or tolerance limits for such contaminants.
- (C) The information collected by the owners and operators during the course of this site assessment shall be submitted in accordance with a schedule established by the State Fire Marshal.
- (D) The State Fire Marshal may request the submission of a corrective action plan for additional soil and/or groundwater cleanup.

Long Term Corrective Action

The following steps must be taken when **long term soil and/or groundwater cleanup** is required by the State Fire Marshal:

- (A) Owners and operators must develop and submit a corrective action plan for responding to any contaminated soils, surface waters, or groundwaters shall submit such a plan according to a schedule established by the State Fire Marshal.
- (B) The State Fire Marshal shall approve the corrective action plan only if it assures that implementation of the plan will provide adequate protection of human health, safety, and the environment. In making this determination, the State Fire Marshal shall consider:
 - (1) The physical and chemical characteristics of the petroleum substance, including its toxicity, persistence, and potential for migration;
 - (2) The hydrogeologic characteristics of the facility and the surrounding land;
 - (3) The proximity, quality, and current and future uses of groundwater and surface waters; and
 - (4) The results of an exposure assessment when such an assessment is required.
- (C) Upon approval of the corrective action plan, the owners and operators shall implement the plan and monitor, evaluate, and report the results of implementation, as required by the State Fire Marshal.
- (D) Public participation.
 - (1) Prior to the approval of each long term corrective action plan submitted, the State Fire Marshal will provide an opportunity for public review and comment on the plan.
 - (2) If there is sufficient public interest, or for any other reason, the State Fire Marshal may hold a public meeting to consider comments on the corrective action plan. A public meeting will be conducted in any case where implementation of an approved corrective action plan does not achieve the established cleanup levels and termination of that plan is under consideration.
 - (3) In deciding whether to approve or modify the corrective action plan, the fire marshal will consider and respond to the comments from the public.

Cost Recovery

The owner or operator of an underground storage tank from which a release of petroleum has occurred is liable to the state for any costs incurred for any corrective or enforcement action undertaken by the State that is conducted pursuant to section 3737.88 of the Ohio Revised Code.

cc: N. Wulff
W. Carkido
T. Chanda
File



RAVENNA ARSENAL INC.

8451 STATE ROUTE 5
RAVENNA, OHIO 44266-9297

Telephone (216) 358-7111

Autovon 346-3210

February 8, 1990

THRU: Contracting Officer's Representative
Ravenna Army Ammunition Plant
8451 State Route 5
Ravenna, Ohio 44266-9297

TO: Commander
U. S. Army Armament, Munitions and Chemical Command
ATTN: AMSMC-PCG-B (Shirlene Wise)
Rock Island, IL 61299-6000

Subject: Specification For Removal of Four (4) Ea. Underground
Storage Tanks (USTs)
(Ref. Phone Conversation on 1 Feb. 1990 @ 1400 Hrs. SAB)

Dear Sir:

Attached are the specifications for removal of the four (4) USTs which failed their required tank tightness tests. The four tanks are as follows:

1. Tank 33 DEAC
2. Tank 23 Bldg. 1045
3. Tank 22 Rail Yard
4. Tank 11 Rail Yard

The specifications were written by a consulting engineering firm registered in the State of Ohio. The specifications were originally drawn up for the removal of 12 registered USTs declared abandoned at the Ravenna Army Ammunition Plant, but may be used for the removal of any UST at the RVAAP.

Sincerely,

RAVENNA ARSENAL, INC.

H. R. Cooper
Plant Engineer

HRC/WAC/wt/wc90002

Attachment

2/8/90 @ 17:15 hrs.

Sue,

I spoke to a Sam Reed Fm/ R & R last night. ChemTron their sludge disposer, requires a sludge characteristic profile be performed; which includes PCB analysis. He said we could sign a waiver to dispense Fm/ PCB Analysis if we would provide statement that there wasn't any PCBs in the sludge. I said No, we would not sign such a waiver being that we really don't know what's been dumped into those tanks other than fuel oil. The problem is that neither of us know if the tank removal specs. (he's got a copy) specifically call for PCB analyses or if the specs. state the responsibility of the contractor to perform all required analyses upon the sludge to assure proper disposal. In any case, if the specs. in some manner don't put the responsibility of costs upon the contractor to test for PCBs then this will be interpreted as an additional cost. If it's determined to be an additional cost, he's been advised to contact Jenkins before PCB analysis is performed. I think!!! There is a general statement to the effect that the contractor is responsible for all required analyses upon the sludge. I've put the tank removal plan on your desk. Let Jenkins & Wayne ^{know} of this discussion in case Reed feels this is an additional cost.


Also, Reed said, since ChemTron wants to perform an analytical profile on the sludge, the 5 drums can't be taken off site for disposal. Reed assured me the drums were weather & spill protected — You or Wayne might want to check this out.

Have a Nice Day

Chenda Fm/ RABEWA



Message 11



Date: FRI, 02 FEB 90 09:18:41 CST
From: Robert J. Kasper <ORVAAP@RIA-EMH1.ARMY.MIL>
To: op01@ria-emh1.army.mil, oppxpg@ria-emh1.army.mil, oincdr@ria-emh1.army.mil

SMCRV-CR (200)

2 February 1990

MEMORANDUM FOR Commander, U.S. Army Armament, Munitions and Chemical Command,
ATTN: AMSMC-PL/Mr. Woodhouse, Rock Island, IL 61299-6000

SUBJECT: Update on Underground Storage Tanks Testing/Removal, RVAAP

1. Status of original project for removal of 12 abandoned USTs.
 - a. Ground cover removed and all tanks exposed.
 - b. Hazardous hauler to drain and remove any remaining material, 2 Feb 90.
 - c. State Fire Marshal to inspect 5 Feb 90.
 - d. If State Fire Marshal approves, cleaning of the tanks to begin.
 - e. State Fire Marshal to inspect after cleaning. Upon Fire Marshal's approval, removal will begin with a projected completion date of 30 Mar 90 for all tanks.
2. An additional 8 tanks that were in service were tested. 3 tanks were found to be leaking and were drained and required removal. A 4th tank requires removal with the 3 leaking tanks because it is adjacent to one of the leaking tanks and will have to be removed with the leaking tank. The 4th tank was considered in the cost estimate for removal. It was also drained. Status of removal of the 4 tanks is as follows.
 - a. \$94,000 has been funded for removal of 4 tanks.
 - b. Subcontract to be let 2 Feb 90.
 - c. Same procedures with State Fire Marshal inspection/approval apply as for 12 tanks in paragraph 1 above.
 - d. Estimated completion for removal of additional 4 tanks is also 30 Mar 90.
3. Request for 20 day leniency extension from the Division of State Fire Marshal, Ohio Department of Commerce to complete removal was verbally approved 1 Feb 90.
4. POC is Mr. John Cicero, AUTOVON 346-3127.

FOR THE COMMANDER:

ROBERT J. KASPER
Commander's Representative

CF:
Cdr, INAAP

TELEPHONE CONVERSATION RECORD

DATE: February 1, 1990

PERSON CALLING: Michelle Tarka
Site Coordinator
Div. State Fire Marshal


PHONE:

PERSON CALLED: H. R. Cooper
Plant Engineer

PHONE: 297-3240

SUBJECT: Request For Extension of Time to Complete
Investigation of Leaking UST
Ref. Ltr. Dated 30 Jan. 1990

Ms. Tarka called to say that there are no problems with our request for a 20 day extension.


H. R. Cooper

cc: COR RVAAP Office
N. Wulff
T. Chanda
W. Carkido
File

hcust.pr

UNCLAS

01 01 011520Z FEB 90 RR UUUU 0311400

CDR AMCCOM ROCK ISL IL//AMSMC-PCG-B (R)//
CDR RVAAP RAVENNA OH//SMCRV-CA//

FEB 01 1990
N. WULFF

UNCLAS (715K)

SGD EMIL E. MASLANKA, CONTRACTING OFFICER
SUBJ UNILATERAL OBLIGATION OF FUNDS

1. THE FOL IS UNIL OBLIG FOR PERFORMANCE UNDER CONTRACT DAAA09-
88-Z-0001:

CLIN: 0046AE PRON: M1OPFB28M1G2/01
ACRN: UNK AMS-CD: 4211052910**4210052910
ACCTG CLASS: 21-02034-0658251P4210-2572-S11173
AMT OBLIG: \$94,000.00 CUM CLIN AMT: \$94,000.00
DESC: FY 90 ENVIRONMENTAL RESTORATION PROJECT 5902910-04,

UNDERGROUND STORAGE TANK REMOVAL IAW RAI LETTERS OF 16, 19, AND
26 JAN 90.

2. THIS ACTION WILL BE FORMALIZED ON P00092.

3. REQUEST CONTRACTOR'S ACK OF RECEIPT OF THIS MSG.


4. POC IS SHIRLENE WISE, AMSMC-PCG-B (R), AUTOVON 793-3359.

2-1-90

AMSMC-PCG (R)
AMSMC-PCG-B (R)
AMSMC-PDP-B (R)

AMSMC-CPF-LG (R)
AMSMC-BPA-P (R)

MS. WISE/CONTR SPEC/
AMSMC-PCG-B (R)/23359



TO	OFFICE	ACTION
<i>C</i>	<i>C</i>	
<i>C</i>	<i>C</i>	
	SAF	
	SPM	
	RETURN	

EMIL E. MASLANKA, CONTR OFF, AMSMC-PCG-B (R), 26628

~~Handwritten signature~~

UNCLAS

cc: N. Wulff
T. Chanda
W. Carkido
File



RAVENNA ARSENAL INC.

8451 STATE ROUTE 5
RAVENNA, OHIO 44266-9297

Telephone (216) 388-7111

Autovon 346-3210

January 30, 1990

THRU: Contracting Officer's Representative
Ravenna Army Ammunition Plant
8451 State Route 5
Ravenna, Ohio 44266-9297

TO: Ohio Department of Commerce
Division of State Fire Marshal
Bureau of Underground Storage Tank Regulations
ATTN: Michelle Tarka, Site Coordinator
7510 East Main Street
P.O. Box 525
Reynoldsburg, Ohio 43068-3395

Subject: Request For Extension Of Time To Complete Investigation
Of Leaking UST

Dear Ms. Tarka:

Your office has been notified about three tanks which failed their tank tightness tests.

The tanks were drained as soon as the test results were known. The earth surrounding the tanks are generally low permeability clay.

These tanks were included in a project to test eight tanks at the Ravenna Army Ammunition Plant. After each of the first tanks failed, the plant requested funding from the Army Command Headquarters to remove the tanks to comply with the requirements of OAC Rule 1301:7-7-36.

The command waited for the results of the last leak test so that it could be included in the same project if it failed. It failed its test on January 26, 1990.

We hereby request a 20 day extension to the allowed time of 20 days to remove a tank. The extension is requested for each tank. This will allow for the time delay in funding the removal of the first tanks while waiting on the results of the third test. It will also allow for approximately one week to process a contract modification and for the fact that the contractor has three tanks to remove almost simultaneously. We expect to have the tanks removed and the required samples taken by the requested extended deadlines.

Extension of Time for UST

-2-

A summary of the proposed dates are as follows:

	<u>Date Reported</u>	<u>20 Days</u>	<u>20 Day Extension</u>
Tank No. 33	January 15	Feb. 4	February 24
Tank No. 23	January 19	Feb. 8	February 28
Tank No. 11	January 26	Feb. 15	March 7

Sincerely,

RAVENNA ARSENAL, INC.



H. R. Cooper
Plant Engineer

HRC/wt/hc90008

cf: AMCCOM
AMSMC-PCG-B (Shirlene Wise)

AMCCOM
AMSMC-ISE-M (Ms. Ronnie DePorter)

cc: N. Wulff
R. Holford
J. Melnik
T. Chanda
File



RAVENNA ARSENAL INC.

8451 STATE ROUTE 5
RAVENNA, OHIO 44266-9297

Telephone (216) 358-7111

Autovon 346-3210

January 29, 1990

THRU Contracting Officer's Representative
Ravenna Army Ammunition Plant
8451 State Route 5
Ravenna, OH 44266-9297

TO Commander
U.S. Army Armament, Munitions and Chemical Command
Attn: AMSMC-ISE-M (Mr. Dennis Versluys)
Rock Island, IL 61299-6000

Subject: Reporting of a #2 Fuel Oil Leak from RVAAP's Underground Storage Tank
(UST), #RV22-Rail Yard Building 47-40; Following 26 January 1990
Failure to Pass State Required Tank Tightness Test

Dear Sir:

Attached is completed DARCOM Form 2647-R in response to subject leak incident.

This installation's point of contact will be Thomas M. Chanda, Environmental
Engineer, Autovon 346-3221.

Sincerely,

RAVENNA ARSENAL, INC.

H. R. Cooper
Plant Engineer

HRC:TMC:ade:TMC90002
Attachment

cf: INAAP
Attn: Col. Miller

1 February 1983

DARCOM Suppl 1 to AR 200-1

TELEPHONIC NOTIFICATION OF POLLUTION INCIDENT (ALL TIMES ARE LOCAL TIMES)		DATE/TIME REPORT RECEIVED
1. INSTALLATION Ravenna Army Ammunition Plant		26 January 1990
2. INSTALLATION COMMANDER Mr. Robert J. Kasper, Commander's Rep.		
3. PERSON REPORTING INCIDENT (Include Phone No. and Ext) T.M. Chanda AV 346-3221	4. PERSON RECEIVING REPORT (Include Office and Ext) Mr. Dennis Versluys AMSMC-ISE-M AV743-1870	5. INCIDENT DISCOVERY DATE AND TIME 26 January 1990 At 1430 Hrs.
NATURE OF INCIDENT		
6. TYPE AND AMOUNT OF MAT AND SOURCE No. 2 Fuel Oil at 0.353 Gals./Hr (0.05 gals/Hr max allowable)	7. SEVERITY <input type="checkbox"/> MINOR <input type="checkbox"/> REPORTABLE <input type="checkbox"/> MEDIUM <input type="checkbox"/> MAJOR <input checked="" type="checkbox"/> NON REPORT- ABLE	8. PERSONNEL INJURIES/PROPERTY LOSS None
9. CAUSE Tank tightness test failure Administered under regulatory standards	10. EQUIP/FAC INVOLVED (Location and Specific area) Railroad yard at Bldg. 47-40 - 15000 gal underground storage tank RV #22 - R.R. locomotive fueling station.	
11. DURATION/MAGNITUDE OF POLLUTION PRODUCED/RELEASED		
a. SOURCE OF RELEASE BEEN STOPPED. <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		
b. RELEASED MATERIAL BEEN RETAINED. <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		
c. REACH INTO NAVIGABLE WATERS. <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		
d. NAME OF RECEIVING STREAM OR WATERS. N/A		
e. PASS THE INSTALLATION BOUNDARY. <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		
f. NPDES PERMIT POINTS INVOLVED. <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO SPECIFY.		
g. SAMPLE BEING TAKEN FOR LEGAL RECORD. <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		
12. DAMAGE/IMPACT ON SURROUNDINGS (Ground water, wildlife, etc.) Contamination of subsurface soils within immediate area of Underground Storage Tank; vertical & horizontal migrational path unknown till remedial action undertaken.		
13. REMEDIAL ACTION TAKEN Product removed from tank immediately following tank tightness test failure; submitted funding request to AMCCOM PCO to implement remedial action.		
14. REMEDIAL ACTION PLANNED Tank & contaminated soil removal; soil sampling & analysis to determine extent of migrational path with subsequent abatement response.		15. DATE OF REMEDIAL ACTION COMPLETION (est or actual) By State 16 FEB 1990 STDS.
16. NOTIFICATIONS		
a. REGIONAL EPA. <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO WHEN?		
b. STATE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> WHEN? 26 January 1990		
c. COAST GUARD OR NATIONAL RESPONSE CENTER (800-424-8802) <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO WHEN?		
d. NEXT HIGHER HQ <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> YES <input type="checkbox"/> NO WHEN?		
17. REACTION BY NEWS MEDIA/PUBLIC None		
18. DOLLAR VALUE OF MATERIAL SPILLED Unknown due to discovery of leak only after administering leak.		19. TOTAL COST CLEANUP ACTIVITIES (Est or Actual) \$59,000. (est.)
DISTRIBUTION <input checked="" type="checkbox"/> AMCCOM, AMSMC-ISE <input checked="" type="checkbox"/> RVAAP CO. <input checked="" type="checkbox"/> RVAAP COR <input checked="" type="checkbox"/> RAI		

TELEPHONE CONVERSATION RECORD

DATE: January 26, 1990

FROM: SUSAN MCCAUSLIN, ENVIRONMENTAL SPECIALIST PHONE 216-297-3220

TO: TODD PARFITT, STATE FIRE MARSHALL'S OFFICE PHONE 1-800-686-2878

SUBJECT: TANK TEST FAILURE, TANK #22 RAIL YARD

I called B.U.S.T. and spoke with Todd parfitt to report the tank leak test failure of Tank #22. Todd recorded all needed information and requested we mail him a map of the facility indicating the location of the leaking tanks.



Susan McCauslin

SM:ade:012690.PR

cc: N. Wulff
B. Jenkins
D. Kanavy
T. Chanda
W. Carkido
File



RAVENNA ARSENAL INC.

8451 STATE ROUTE 5
RAVENNA, OHIO 44266-9297

Telephone (216) 358-7111

Autovon 346-3210

January 26, 1990

THRU: Contracting Officer's Representative
Ravenna Army Ammunition Plant
8451 State Route 5
Ravenna, Ohio 44266-9297

TO: Commander
U. S. Army Armament, Munitions and Chemical Command
ATTN: AMSMC-PCG-B (Shirlene Wise)
Rock Island, IL 61299-6000

Subject: Corrective Action - Leaking Underground Storage Tank
Ref. RAI Letter January 16, 1990, Same Subject
RAI Letter January 19, 1990, Same Subject

Dear Sir:

The referenced letter advised you of the failure of a tank tightness test on two tanks during the testing of eight underground Storage Tanks at Ravenna AAP.

On the afternoon of January 26, 1990 a third tank (the Railroad Yard #2 Fuel Oil Dispensing Station), failed the tightness test. The leakage rate was approximately 0.30 gallons per hour vs. criteria of 0.05 gallons per hour. Per Ohio guidelines for tanks failing a tightness test the #2 Fuel Oil contents in the tank was removed to another tank thus eliminating the possibility of further loss.

As with prior two tanks discussed in the reference letter, we recommend removal of the tank rather than attempting to repair. This tank is steel construction and 49 years old. If the tank is rusted extensively, as we assume it is due to its age, it would not be able to be repaired. The removal of the 15,000 gallon tank in accordance with Ohio EPA requirements is estimated to cost \$59,000 depending upon the extent of ground contamination and assuming no ground water contamination. We believe these are reasonable assumptions because the sub surface soil is mostly clay. The reason for the higher cost is that a second tank of the same age is in the same excavation. Any attempt to remove the failed tank will affect the structural integrity of the other tank. In addition, these tanks have concrete vaults over part of them which will increase the subcontractors work. The work must be subcontracted because RAI is not certified by the State for tank removal.

Request that additional funds in the amount of \$59,000 be provided in the same way as the \$35,000 requested in the referenced letters for the Deactivation Furnace and Building 1045 Tanks. The total requirement is now \$94,000.

As explained in the referenced letter, the tank must be removed within 20 days from January 26, 1990 or by February 15, 1990. We will request an extension of 20 days (the maximum allowed) to March 7, 1990. To complete the physical work prior to March 7, 1990, we must be authorized to proceed by February 13, 1990. Failure to complete the removal of this tank by March 7, 1990 will result in the plant being in non-compliance with Ohio regulations.

As a reminder, the funding requested in the prior letters must be received by February 8, 1990 to avoid a non-compliance violation for those tanks.

Of the original eight tanks all have now been tested.

A 1383 Exhibit-1 and a DD Form 319-R are attached for the project. Also a DD Form 319-R for the first two tanks is attached.

Sincerely,

RAVENNA ARSENAL, INC.



H. R. Cooper
Plant Engineer

HRC/wt/hc90003

cf: AMCCOM
AMSMC-ISE (Ms. Ronnie DePorter)

AMCCOM
AMSMC-BPA-P

Attachment

Exhibit 1
1383 REPORT EXHIBIT 1
AMCCOM SUPPLEMENTAL INFORMATION SHEET

Installation Name: Ravenna Army Ammunition plant
Project Name: Underground Storage Tank Removal - 2 Leaking Tanks (Second group)

1. FUNDED: NO
2. PRON:
3. AMS CODE/PROGRAM ELEMENT (PE):
4. EXECUTING AGENCY: RVAAP OPERATING CONTRACTING
5. PRIORITY: HIGH
6. 319R #:
7. HAZMIN: YES
8. SOURCE STATUS: ACTIVE
9. TECH/ADMIN APPROVAL: YES
10. PERCENT CMPL: -0-
11. a. SUPPORTS PRODUCTION: NO
b. IF YES, SPECIFY:
12. TYPE EFFORT: CLOSURE
13. CORRECT NOV: NO
14. ON COMPLIANCE SCHEDULE/AGREEMENT: YES
15. NEPA DOCUMENTATION:
 - A. Prepared; Record of Environmental Consideration
 - B. Approved: YES, Installation Level Only
16. IMPACT IF NOT FUNDED: Ravenna Army ammunition Plant will not be in compliance with Ohio Administration Code Rule 1301-7-7-36(C)(2) which applies to UST's which fail a tightness test.

1383 REPORT EXHIBIT 1

SUPPLEMENTAL INFORMATION SHEET

DATE PREPARED: 1/25/90

GSA INVENTORY CONTROL NO: 20736

1. PROJECT NARRATIVE DESCRIPTION:

This project is to remove two leaking underground storage tanks (15,000 gallon capacities). The project includes abandonment of the tanks by removal according to an approved closure plan, removal and disposal of all visibly contaminated soils, testing of remaining soil, and completion of a closure report.

FUNDING TYPE: PAA INSTALLATION STATUS: Inactive
REQUIRED FOR MOBILIZATION: No; however, the removal of these tanks must be fully coordinated with revisions to the mobilization plan.

2. SPECIFIC TYPE OF POLLUTION/CONTAMINATION:

The tanks failed routine tank tightness tests on January 26, 1990. The subject tanks contained No. 2 fuel oils.

3. AMOUNT OF POLLUTION/CONTAMINATION:

The two (2) tanks to be removed have a combined capacity of 30,000 gals. Inventory checks have not indicated extensive product loss. Extent of contamination will be assessed during removal process.

4. POLLUTION SOURCE AND DISCHARGE, EMISSION OR DEPOSIT POINT:

Discharge is to the soil around the tanks.

5. EXISTING TREATMENT & OTHER CONTROL MEASURES: None

6. EFFECTIVENESS OF EXISTING TREATMENT CONTROL: Not applicable

7. REMEDIAL MEASURES PROPOSED & ESTIMATED EFFECT IN CORRECTING PROBLEMS: None

Tanks have been emptied of most fluid. The tanks remain in violation until removed or repaired and contamination is cleaned up.

8. APPLICABLE STANDARD: OAC 1301:7-7-36 (C)(2)

*9. OTHER RELEVANT INFORMATION:

The tanks must be removed within 40 days of discovery and contamination of the leak. (20 days per regulation plus the maximum extension allowed of 20 days). One tank was determined leaking January 26, 1990. Time to complete removal of both tanks is two weeks. Both tanks must be removed since they are in the same excavation and are 49 years old. One can't be removed without disturbing the other. Funding is needed by February 10, 1990.



Federal Agency Pollution Abatement Plan — Project Report

I. Facility Information

1. State Abbr.	2. Agency/Bureau	3. GSA Installation	4. EPA Region	5. Country	6. New Installation
O H	2-1-3-8	2-0-7-3-6	0-5	U S A	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
7. Name of the Installation RAVENNA ARMY AMMUNITION PLANT					
8. Street Address 8451 STATE ROUTE 5					
9. City Name RAVENNA OHIO				10. ZIP Code, if known 44266	11. Ownership Type C

II. Basic Project Information

1. Agency Project Number	2. Various Locations <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	3. Media S W	4. Pollutant Category L U S T	5. Funding Account 0 4	6. Year Funding Required 9 0
7. Project Name (Brief description) UNDEIRGROUND STORAGE TANK REMOVAL (2 TANKS) 2ND					
8. Project Contact Name TOM CHANDA			9. Contact Telephone 216-287-3221	10. Total Cost Estimate (in \$1,000)	

11. Project Assessment		12. Compliance Status	
<input checked="" type="checkbox"/> High (H) Project critical to Agency program and/or cleanup of local environment	<input checked="" type="checkbox"/> ESOP Does not meet established standard and compliance deadline has passed	<input type="checkbox"/> ESRO Meets established standard but need placement due to obsolescence	
<input type="checkbox"/> Med (M) Project important to Agency program and/or cleanup of local environment	<input type="checkbox"/> ESOP Does not meet established standard and compliance deadline is in the future	<input type="checkbox"/> ESRE Meets established standard but need placement due to need for expansion	
<input type="checkbox"/> Low (L) Project desirable to Agency program and/or cleanup of local environment	<input type="checkbox"/> PSOP Does not meet pending standard and compliance deadline is in the future	<input type="checkbox"/> ESOL Meets established standards but has demonstrate leadership	
		<input type="checkbox"/> OTHR Other	

13. Project Cost			14. Project Milestones/Progress (All dates are monthly)		
Fiscal Year	Budgeted (\$1,000)	Funded (\$1,000)	Design/Plan Completion	Construction/Work	
				Start	Complete
90	59.0		0-1-90	0-1-90	0-2-90
			Final Compliance Required	Progress Code	Fiscal Year Complete
			0-2-90		
			For OGE User Only		
			Program ID	Field Office	

Project Narrative (including description of legal requirements and pollutants to be controlled)

SEE ATTACHED 1383 EXHIBIT

RAVENNA ARMY AMMUNITION PLANT

RECORD OF ENVIRONMENTAL CONSIDERATION (REC)

Ravenna Arsenal, Inc.

January 26, 1990

I. PROJECT TITLE/PROPOSED PROJECT

Underground Storage Tank Removal - 2 Leaking Tanks (Second Group)

II. PROJECT DESCRIPTION

RVAAP has 2 USTs which have failed tank tightness tests. In compliance with State and Federal EPA regulations said USTs and their appurtenances must be removed or repaired immediately. Due to the age of the tanks this project proposes removal.

III. ANTICIPATED DATE AND/OR DURATION OF PROPOSED ACTION

Expected to be performed in February 1990.


IV. REASON FOR USING RECORD OF ENVIRONMENTAL CONSIDERATION

The proposed action is categorically excluded under the provisions of Categorical Exclusion A-7, AR200-2, Appendix A (and no extraordinary circumstances exist as defined in paragraph 4-3) because subject action is in compliance with State and Federal EPA regulations pertaining to the removal of leaking USTs.




T. M. CHANDA
Environmental Engineer/Proponent

1-26-90
DATE


H. R. COOPER
Plant Engineer

1-26-90
DATE


ROBERT J. KASPER -
Commander's Representative Installation
Environmental Engineer

26 Jan 90
DATE

CURRENT OR BACKLOG OF DEFICIENCY IDENTIFICATION AND INDUSTRIAL PREPAREDNESS MEASURE (IPM)
(AMCCOM Suppl 1 to AR 700-90)

1. INSTALLATION NAME/PIN
Ravenna Army Ammunition Plant / PIN 995282

2. DATE OF SUBMISSION
ORIGINAL
Jan. 26, 1990

REQUIREMENT CONTROL SYMBOL
FEEDER FOR RCS CSCAB-205
3. ACTION OFFICE

4. LINE/AREA General	5. LINE/AREA STATUS CODE A	6. IPM NUMBER	7. REASON CODE C1
	9. IMPACT CODE E	10. IMPLEMENTATION CODE G	11. TIME IPM REQ AFTER M:DAY
8. PROG FUNDING CODE PAA (ENVIR)		12. TIME TO COMP DESIGN 0	13. TIME TO COMP PHY WORK 2 WKS
14. STATE OF READ		WITHOUT IPM	WITH IPM

15. ITEM/COMPONENT MANUFACTURED N/A	16. ISN	17. PROD CAP (MAX)		18. PROD LEVEL OFF TIME		19. RELATED IPMS
		WITHOUT IPM	WITH IPM	WITHOUT IPM	WITH IPM	
20. OPERATIONAL IMPACT						
<input checked="" type="checkbox"/> MISSION SUPPORT			<input type="checkbox"/> GENERAL SUPPORT			
<input type="checkbox"/> PROD SUPPORT			<input type="checkbox"/> ADMIN SUPPORT			
21. LOCAL CONTROL NUMBER						
22. PROGRAM CONTROL NUMBER						
25. COST DATA (\$000)						
a. REAL PROPERTY	(1) LABOR COST		(2) MATERIAL COST		(3) SUBCONTRACT	
(1) LABOR COST	(1) LABOR COST		(2) MATERIAL COST		(3) SUBCONTRACT	
(2) MATERIAL COST	(2) MATERIAL COST		(4) G&A COST		(5) FEE	
(3) SUBCONTRACT	(3) SUBCONTRACT		(4) G&A COST		(5) FEE	
(4) G&A COST	(4) G&A COST		(5) FEE		(6) TOTAL EST COST	
(5) FEE	(5) FEE		(6) TOTAL EST COST		(6) TOTAL EST COST	
(6) TOTAL EST COST	(6) TOTAL EST COST		(6) TOTAL EST COST		(6) TOTAL EST COST	

23. DEFICIENCY PROJECT TITLE
P.O.C. R.J. Kasper COR AV 346-3124
W.A. Garkido AV346-3237

DESCRIPTION: (Bldg no, equipment, sq ft, length, quantity, etc.)
12450

a. REAL PROPERTY FAC CAT CODE NUMBER
 b. EQUIPMENT

Remove two (2) underground storage tanks which failed their required tank tightness tests.

- Tank #33 DEAC Furnance - 2000 Gal. # 2 Fuel Oil
- Tank #23 Bldg. 1045 - 15000 Gal. #2 Fuel Oil

The tanks must be removed within 40 days of discovery of leak(20 days/regulations plus 20 days maximum extension granted). The tanks were determined leaking on 1/15/90 and 1/18/90. Time to complete removal of both tanks is 2 weeks. Funding is needed by February 8, 1990.

26. DD FORM 1391 PROCESSOR NUMBER

27. AMCCOM PROJECT IDENTIFICATION NUMBER

28. VERIFIED
OFFICE _____ DATE _____
 YES NO CODE _____

29. VAUDATED
OFFICE _____ DATE _____
 YES NO CODE _____

SIGNATURE _____

24. JUSTIFICATION (includes impact on mobilization planning, effort, economics, etc.)
Ravenna Army Ammunition Plant will not be in compliance with Ohio Administration Code Rule 1301:7-7-36(c)(2) which applies to USTs which fail a tightness test.

CURRENT OR BACKLOG OF DEFICIENCY IDENTIFICATION AND INDUSTRIAL PREPAREDNESS MEASURE (IPM)
(AMCCOM Suppl 1 to AR 700-90)

1. **INSTALLATION NAME/PIN**
Ravenna Army Ammunition Plant /Pin 995282

2. **DATE OF SUBMISSION**
ORIGINAL
Jan. 26, 1990

REQUIREMENT CONTROL SYMBOL
FEEDER FOR RCS CSCAB-205
3. **ACTION OFFICE**

4. LINE/AREA General	5. LINE/AREA STATUS CODE A	6. IPM NUMBER	7. REASON CODE C1	8. PROG FUNDING CODE ICOMP DESIGN	9. TIME TO 13. TIME TO 14. STATE OF READ WITHOUT IPM WITH IPM
9. IMPACT CODE E	10. IMPLEMENTATION CODE G	11. TIME IPM REQ AFTER M-DAY	12. TIME TO 13. TIME TO 14. STATE OF READ WITHOUT IPM WITH IPM	15. IPM NUMBER	16. STATE OF READ WITHOUT IPM WITH IPM

15. ITEM/COMPONENT MANUFACTURED	16. ISN	17. PROD CAP (MAX) WITHOUT IPM WITH IPM	18. PROD LEVEL OFF TIME WITHOUT IPM WITH IPM	19. RELATED IPMS
---------------------------------	---------	---	--	------------------

a. N/A	N/A	N/A	N/A	N/A	N/A
b. N/A	N/A	N/A	N/A	N/A	N/A
c. N/A	N/A	N/A	N/A	N/A	N/A
d. N/A	N/A	N/A	N/A	N/A	N/A
e. N/A	N/A	N/A	N/A	N/A	N/A
f. N/A	N/A	N/A	N/A	N/A	N/A
g. N/A	N/A	N/A	N/A	N/A	N/A
h. N/A	N/A	N/A	N/A	N/A	N/A
i. N/A	N/A	N/A	N/A	N/A	N/A
j. N/A	N/A	N/A	N/A	N/A	N/A
k. N/A	N/A	N/A	N/A	N/A	N/A
l. N/A	N/A	N/A	N/A	N/A	N/A
m. N/A	N/A	N/A	N/A	N/A	N/A
n. N/A	N/A	N/A	N/A	N/A	N/A
o. N/A	N/A	N/A	N/A	N/A	N/A
p. N/A	N/A	N/A	N/A	N/A	N/A

23. **DEFICIENCY PROJECT TITLE** P.O.C. R.J. KASPER
AV346-3124

DESCRIPTION: (Bldg no, equipment, sq ft, length, quantity, etc.)
W.A. Garkido
AV346-3237

a. REAL PROPERTY FAC CAT CODE NUMBER 12450
 b. EQUIPMENT

To remove one (1) underground storage tank (UST) which failed it required tightness test and one (1) UST adjacent to said UST (within 3 ft.) of the same size, age, and construction.
1. Tank #22 Rail YD - 15000 Gal. - #2 Fuel Oil
2. Tank #11 Rail YD - 15000 Gal. - #2 Fuel Oil
The tanks must be removed within 40 days of discovery of leak(20 days/regulations, plus 20 days maximum extension granted) The tank was determined leaking on January 26, 1990. Time to complete removal of both tanks is 2 weeks. Funding is needed by February 10, 1990.

24. **JUSTIFICATION** (includes impact on mobilization planning, effort, economics, etc.)
Ravenna Army Ammunition Plant will not be in compliance with Ohio Administration Code 1301:7-7-36

(C) (2) which applies to USTs which fail a tightness test.

20. OPERATIONAL IMPACT	<input checked="" type="checkbox"/> MISSION SUPPORT	<input type="checkbox"/> GENERAL SUPPORT
	<input type="checkbox"/> PROD SUPPORT	<input type="checkbox"/> ADMIN SUPPORT
21. LOCAL CONTROL NUMBER		
22. PROGRAM CONTROL NUMBER		
25. COST DATA (\$000)		
a. REAL PROPERTY	b. EQUIPMENT	
(1) LABOR COST	(1) LABOR COST	
(2) MATERIAL COST	(2) MATERIAL COST	
(3) SUBCONTRACT	(3) SUBCONTRACT	
(4) G&A COST	(4) G&A COST	
(5) FEE	(5) FEE	
(6) TOTAL EST COST	(6) TOTAL EST COST	
26. DD FORM 1391 PROCESSOR NUMBER		
27. AMCCOM PROJECT IDENTIFICATION NUMBER		

28. **VERIFIED** YES NO **CODE** _____
OFFICE _____ **DATE** _____

SIGNATURE _____
29. **VALIDATED** YES NO **CODE** _____
OFFICE _____ **DATE** _____

SIGNATURE _____

cc: N. Wulff
T. Chanda
W. Carkido
File



RAVENNA ARSENAL INC.

8451 STATE ROUTE 5
RAVENNA, OHIO 44266-9297

Telephone (216) 358-7111

Autovon 346-3210

January 26, 1990

THRU: Contracting Officer's Representative
Ravenna Army Ammunition Plant
8451 State Route 5
Ravenna, Ohio 44266-9297

[Handwritten signature]
26 Jan 90

TO: Commander
U. S. Army Armament, Munitions and Chemical Command
ATTN: AMSMC-ISE-M (Ms. Ronnie DePorter)
Rock Island, IL 61299-6000

Subject: Corrective Action - Leaking Underground Storage Tank
Ref. RAI Letter January 16, 1990 - Same Subject
RAI Letter January 19, 1990 - Same Subject

Dear Sir:

Per your request, a 1383 Exhibit 1 and supporting documentation have been prepared for the removal of the two leaking tanks discussed in the referenced letters.

It is attached for further action.

Sincerely,

RAVENNA ARSENAL, INC.

H.R. Cooper

H. R. Cooper
Plant Engineer

HRC/wt/hc90005

Attachment

cf: AMCCOM
AMSMC-PCG-B



Federal Agency Pollution Abatement Plan — Project Report

I. Facility Information

1 State Alpha O H	2 Agency/Bureau 2 1 3 8	3 GSA Installation 2 0 7 3 6	4 EPA Region 0 5	5 Country U S A	6 New Installation <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
7 Name of the Installation R A V E N N A A R M Y A M M U N I T I O N P L A N T					
8 Street Address 8 4 5 1 S T A T E R O U T E 5					
9 City Name R A V E N N A O H I O			10 ZIP Code, if known 4 4 2 6 6 - 9 2 9 7		11 Ownership Type C

II. Basic Project Information

1 Agency Project Number	2. Various Locations <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	3. Media S W	4 Pollutant Category L U S T	5. Funding Account 0 4	6 Year Funding Required 9 0
7 Project Name (Brief description) U N D E R G R O U N D S T O R A G E T A N K R E M O V A L (2 T A N K S)					
8 Project Contact Name T O M C H A N D A		9 Contact Telephone 2 1 6 - 2 9 7 1 - 3 1 2 1 1		10. Total Cost Estimate (in \$1,000's)	

11 Project Assessment		12 Compliance Status	
<input checked="" type="checkbox"/> High (H) Project critical to Agency program and/or cleanup of local environment	<input type="checkbox"/> Med (M) Project important to Agency program and/or cleanup of local environment	<input checked="" type="checkbox"/> ESDP Does not meet established standard and compliance deadline has passed	<input type="checkbox"/> ESDP Does not meet established standard and compliance deadline is in the future
<input type="checkbox"/> Low (L) Project desirable to Agency program and/or cleanup of local environment		<input type="checkbox"/> PSDP Does not meet pending standard and compliance deadline is in the future	<input type="checkbox"/> ESRO Meets established standard but needs re-placement due to obsolescence
			<input type="checkbox"/> ESRE Meets established standard but needs re-placement due to need for expansion
			<input type="checkbox"/> ESDL Meets established standards but needs to demonstrate leadership
			<input type="checkbox"/> OTHER Other

13 Project Cost			14 Project Milestones/Progress (All dates are month/year)		
Fiscal Year	Budgeted (\$1,000)	Funded (\$1,000)	Design/Plan Completion	Construction/Work	
				Start	Completion
9 0	3 5 0		0 1 1 9 0	0 1 1 9 0	0 2 1 9 0
			Final Compliance Required	Progress Code	Fiscal Year Completed
			0 2 1 9 0		
			For DOE Use Only		
			Program ID	Field Office	

Project Narrative (including description of legal requirement and pollutants to be controlled)

SEE ATTACHED 1383 EXHIBIT 1

SUPPLEMENTAL INFORMATION SHEET

DATE PREPARED: 1/25/90

GSA INVENTORY CONTROL NO: 20736

1. PROJECT NARRATIVE DESCRIPTION:

This project is to remove two leaking underground storage tanks (2,000 and 15,000 gallon capacities). The project includes abandonment of the tanks by removal according to an approved closure plan, removal and disposal of all visibly contaminated soils, testing of remaining soil, and completion of a closure report.

FUNDING TYPE: PAA INSTALLATION STATUS: Inactive
REQUIRED FOR MOBILIZATION: No; however, the removal of these tanks must be fully coordinated with revisions to the mobilization plan.

2. SPECIFIC TYPE OF POLLUTION/CONTAMINATION:

The tanks failed routine tank tightness tests on January 15 and 18, 1990. The subject tanks contained No. 2 fuel oils.

3. AMOUNT OF POLLUTION/CONTAMINATION:

The two (2) tanks to be removed have a combined capacity of 17,000 gals. Inventory checks have not indicated extensive product loss. Extent of contamination will be assessed during removal process.

4. POLLUTION SOURCE AND DISCHARGE, EMISSION OR DEPOSIT POINT:

Discharge is to the soil around the tanks.

5. EXISTING TREATMENT & OTHER CONTROL MEASURES: None6. EFFECTIVENESS OF EXISTING TREATMENT CONTROL: Not applicable7. REMEDIAL MEASURES PROPOSED & ESTIMATED EFFECT IN CORRECTING PROBLEMS: None

Tanks have been emptied of most fluid. The tanks remain in violation until removed or repaired and contamination is cleaned up.

8. APPLICABLE STANDARD: OAC 1301:7-7-36 (C)(2)*9. OTHER RELEVANT INFORMATION:

The tanks must be removed within 40 days of discovery and contamination of the leak. (20 days per regulation plus the maximum extension allowed of 20 days). The tanks were determined leaking January 15 and 18, 1990. Time to complete removal of both tanks is two weeks. Funding is needed by February 8, 1990.

Exhibit 1
1383 REPORT EXHIBIT 1
AMCCOM SUPPLEMENTAL INFORMATION SHEET

Installation Name: Ravenna Army Ammunition plant
Project Name: Underground Storage Tank Removal - 2 Leaking Tanks

1. FUNDED: NO
2. PRON:
3. AMS CODE/PROGRAM ELEMENT (PE):
4. EXECUTING AGENCY: RVAAP OPERATING CONTRACTING
5. PRIORITY: HIGH
6. 319R #:
7. HAZMIN: YES
8. SOURCE STATUS: ACTIVE
9. TECH/ADMIN APPROVAL: YES
10. PERCENT CMPL: -0-
11. a. SUPPORTS PRODUCTION: NO
b. IF YES, SPECIFY:
12. TYPE EFFORT: CLOSURE
13. CORRECT NOV: NO
14. ON COMPLIANCE SCHEDULE/AGREEMENT: YES
15. NEPA DOCUMENTATION:
 - A. Prepared; Record of Environmental Consideration
 - B. Approved: YES, Installation Level Only
16. IMPACT IF NOT FUNDED: Ravenna Army ammunition Plant will not be in compliance with Ohio Administration Code Rule 1301-7-7-36(C)(2) which applies to UST's which fail a tightness test.

RECORD OF ENVIRONMENTAL CONSIDERATION (REC)

Ravenna Arsenal, Inc.

January 25, 1990

I. PROJECT TITLE/PROPOSED PROJECT

Underground Storage Tank Removal - 2 Leaking Tanks

II. PROJECT DESCRIPTION


RVAAP has 2 USTs which have failed tank tightness tests. In compliance with State and Federal EPA regulations said USTs and their appurtenances must be removed or repaired immediately. Due to the age of the tanks this project proposes removal.

III. ANTICIPATED DATE AND/OR DURATION OF PROPOSED ACTION

Expected to be performed in February 1990.

IV. REASON FOR USING RECORD OF ENVIRONMENTAL CONSIDERATION

The proposed action is categorically excluded under the provisions of Categorical Exclusion (CX) A-5 and A-12, AR200-2, Appendix A (and no extraordinary circumstances exist as defined in paragraph 4-3) because subject action is in compliance with State and Federal EPA regulations pertaining to the removal of leaking USTs.




T. M. CHANDA
Environmental Engineer

1-26-90
DATE



H. R. COOPER

1-26-90
DATE



ROBERT J. KASPER
Commander's Representative Installation
Environmental Engineer

26 Jan 90
DATE

TELEPHONE OR VERBAL CONVERSATION RECORD

For use of this form, see AR 340-15; the proponent agency is The Adjutant General's Office.

DATE

1-25-90

SUBJECT OF CONVERSATION

Need 1383's on failed underground STG. TANKS

INCOMING CALL


PERSON CALLING	ADDRESS	PHONE NUMBER AND EXTENSION
S. Wise	AMSMC-PCG-B	793-3359
PERSON CALLED	OFFICE	PHONE NUMBER AND EXTENSION
J. CICERO	SMCRU-CA	346-3127

OUTGOING CALL

PERSON CALLING	OFFICE	PHONE NUMBER AND EXTENSION
PERSON CALLED	ADDRESS	PHONE NUMBER AND EXTENSION

SUMMARY OF CONVERSATION

Need RAI To submit 1383's on failed
 Underground STG. TANK - DATA FAX To RONNIE
 DePorter + Shirlene WISE!



cc: RVAAP (CR (zero))
 Wolff
 Cooper
 file

TELEPHONE OR VERBAL CONVERSATION RECORD		DATE
For use of this form, see AR 340-15; the proponent agency is The Adjutant General's Office.		1/23/90
SUBJECT OF CONVERSATION <i>Extension Request For UST Remedial Action Following UST Tightness Failure</i>		
INCOMING CALL		
PERSON CALLING	ADDRESS	PHONE NUMBER AND EXTENSION
PERSON CALLED	OFFICE	PHONE NUMBER AND EXTENSION
OUTGOING CALL		
PERSON CALLING	OFFICE	PHONE NUMBER AND EXTENSION
<i>T.M. Chanda</i>	<i>RAI Environmental Engineering</i>	<i>816-297-3221</i>
PERSON CALLED	ADDRESS	PHONE NUMBER AND EXTENSION
<i>Richard Sissler</i>	<i>State Fire Marshal's Office Site Coordinator Columbus, GA</i>	<i>1-800-686-2878</i>
SUMMARY OF CONVERSATION		
<p><i>Mr. Sissler was posed with subject request in view of RVAAP's remedial action efforts being coordinated into one funded project. RVAAP still has one more UST to test; previously RVAAP had 2 (ea) UST fail tightness testing which requires a Feb. 5th & Feb 9th 1990 (respectively). Final corrective action. RVAAP would require an extension to finish UST testing, make funding requests, remove failed USTs, remove contaminated soil and/or product removal, and soil analysis.</i></p> <p><i>Sissler said that the State cannot formally grant extensions; but can demonstrate a 20 day leniency period following regulated deadlines. After which enforcement action takes over to any irresponsiveness.</i></p> <p><i>Sissler suggested RVAAP write an explanatory letter indicating inability to meet the initial 20 da. deadline; he cannot see any objection in allowing an additional 20 days to accomplish remediation under a One Project Scenario.</i></p>		

DA FORM 751
 APR 66

REPLACES EDITION OF 1 FEB 58 WHICH WILL BE USED.

T.M. Chanda
 * GPO: 1965 O - 543-775, 54

IMPORTANT FAX INFORMATION



1234 S. Cleveland-Massillon Rd.
Akron, Ohio 44321
(216) 666-2200
FAX: (216) 666-7874

Please deliver immediately to: Mr. Bill Jenkins

Company: Ravenna Arsenal, Incorporated

Fax #: (216) 297-3216

Reference: _____

Response Requested:	Y <input type="checkbox"/>	N <input type="checkbox"/>
Hardcopy to follow by mail:	Y <input type="checkbox"/>	N <input type="checkbox"/>

No. of pages (including cover sheet): 3 Date: 1-23-90

Please contact Mary if all pages not received.


Comments: _____

B. J. JENKINS

JAN 23 1990


C. H. [Signature]

For Internal Use Only: _____



Signed By: _____

[Signature]



R&R

INTERNATIONAL, INC.

1234 S. CLEVELAND-MASSILLON ROAD
P.O. BOX 4383
AKRON, OHIO 44321
(216) 666-2200

January 23, 1990

B. J. JENKINS
JAN 23 1990

Mr. Bill Jenkins
Ravenna Arsenal, Incorporated
8451 State Route 5
Ravenna, Ohio 44266-9297

Reference: Removal of Two (2) 15,000 Gallon Tanks and Concrete Vault

Dear Mr. Jenkins:

Enclosed please find the following:

1. Cost Basis
2. Cost of Services

We are looking forward to working with you on this project. Please call us when we can be of assistance.

Respectfully,

R & R INTERNATIONAL, INC.

G. M. Rand, P.E.
President

GMR:mfp
Enclosure

B. J. JENKINS

JAN 23 1990

COST BASIS

Number of tanks to be removed:	2
Size	15,000 gallons

NOTE:

1. Ravenna Arsenal will pump out the water in the concrete vault and all contents (Number 2 fuel oil) from the tanks.
2. "Complete Removal of Tanks" - means excavation, transportation, disposal of the tanks and associated piping.
3. Included in the prices are cost of backfilling the hole with on-site soil, cost of analytical testing and closure report.

COST OF SERVICES

Two (2) tanks, 15,000 gallons, complete removal	\$ 18,400.00
Concrete Vault removed	1,400.00
Contaminated soil removal	68.00 per yard

Saw Reed R&R

Pds up front of landfill

Copy of soil analyses

- 7 PIT
- PCB
- BET X
- Final Pt.
- EP Tox.

Before material on-site
I.D. of job on the day

TELEPHONE CONVERSATION RECORD


DATE: JANUARY 19, 1990, 8:15 A.M.

FROM: SUSAN MCCAUSLIN, ENVIRONMENTAL SPECIALIST PHONE 216-297-3220

TO: TODD PARFITT, STATE FIRE MARSHALL'S OFFICE PHONE 1-800-686-2878

SUBJECT: TANK TEST FAILURE, TANK #23 BUILDING 1045

I called B.U.S.T. and spoke to Todd Parfitt to report the tank leak test failure of Tank #23. Todd took down all required information and informed me that the Fire Marshall's Office would be sending us a letter outlining our requirements with regard to corrective action.



Susan McCauslin

SM:ade



RAVENNA ARSENAL INC.

8451 STATE ROUTE 5
RAVENNA, OHIO 44266-9297

Telephone (216) 358-7111

cc: N. Wulff
B. Jenkins
D. Kanavy
T. Chanda
W. Carkido
File

Autovon 346-3210

January 19, 1990

THRU: Contracting Officer's Representative
Ravenna Army Ammunition Plant
8451 State Route 5
Ravenna, Ohio 44266-9297

TO: Commander
U. S. Army Armament, Munitions and Chemical Command
ATTN: AMSMC-PCG-B (Shirlene Wise)
Rock Island, IL 61299-6000

Subject: Corrective Action - Leaking Underground Storage Tank
Ref. RAI Letter January 16, 1990, Same Subject

Dear Sir:

The referenced letter advised you of the failure of a tank tightness test on Tank No. 33 during the testing of eight underground Storage Tanks at Ravenna AAP.

On the evening of January 18, 1990 a second tank at the #2 Fuel Oil Dispensing Station, Building 1045, failed the tightness test. The leakage rate was approximately 0.27 gallons per hour vs. criteria of 0.05 gallons per hour. Per Ohio guidelines for tanks failing a tightness test the 15,000 gallons of #2 Fuel Oil in the tank was removed to another tank thus eliminating the possibility of further loss.

As with the Deactivation Furnace tank discussed in the reference letter, we recommend removal of the tank rather than attempting to repair. This tank is steel construction and approximately 35 to 40 years old. The removal of the 15,000 gallon tank in accordance with Ohio EPA requirements is estimated to cost \$25,000 depending upon the extent of ground contamination and assuming no ground water contamination. We believe these are reasonable assumptions because the sub surface soil is mostly clay.

Request that additional funds in the amount of \$25,000 be provided in the same way as the \$10,000 requested in the referenced letter for the Deactivation Furnace Tank.

As explained in the referenced letter, the tank must be removed within 20 days from January 18, 1990 or by February 7, 1990. To complete the physical work prior to February 7, 1990, we must be authorized to proceed by January 29, 1990. Failure to complete the removal of this tank by February 7, 1990 will result in the plant being in non-compliance with Ohio regulations.

As a reminder, the funding requested in the referenced letter must be received by January 26, 1990 to avoid a non-compliance violation for that tank.

Of the original eight tanks to be tested only one remains to be tested next week.

Sincerely,

RAVENNA ARSENAL, INC.



H. R. Cooper
Plant Engineer

HRC/wt/hc90003

cf: AMCCOM
AMSMC-ISE (Ms. Ronnie DePorter)

OHIO DEPARTMENT OF COMMERCE
DIVISION OF STATE FIRE MARSHAL
BUREAU OF UNDERGROUND STORAGE TANK REGULATIONS

CORRECTIVE ACTION GUIDANCE
FOR PETROLEUM RELEASES

January 15, 1988

Section 3737.88 of the Ohio Revised Code requires that when the State Fire Marshal finds that a release of petroleum from an underground storage tank has occurred, he shall take actions necessary to protect human health and the environment.

This list of corrective action steps for petroleum releases from UST systems have been prepared to assist UST owners and operators in conducting the corrective action activities required by the State Fire Marshal when a release is discovered. Nothing in this guidance is intended to supercede any action taken by the Fire Marshal or any other local, state, or federal agency or regulation, nor does this list relieve the UST system owner or operator from compliance with any applicable local, state or federal regulations

General Requirements

These requirements apply to any suspected or confirmed release of petroleum from an underground storage tank. All owners and operators of UST systems, in response to a suspected or confirmed release of petroleum from an UST system, shall comply with these requirements.

Unless otherwise indicated, all reports required by the State Fire Marshal must be submitted in writing to:

Ohio Division of State Fire Marshal
Bureau of Underground Storage Tank Regulation
7510 East Main Street
P. O. Box 525
Reynoldsburg, OH 43068-3395

Suspected Release Confirmation

- (A) All suspected releases of petroleum from UST systems must be reported to the local fire department and the State Fire Marshal within 24 hours of their discovery. The report to the State Fire Marshal may be made by calling 614-752-8200 or 1-800-282-1927.

Any suspected release that effects surface or drinking water supplies

must be reported to the Ohio Environmental Protection Agency at 1-800-282-9378.

Any suspected release that threatens Ohio's wildlife must be reported to the Ohio Department of Natural Resources 614-265-4300.

- (B) Suspected releases must be immediately investigated and either confirmed or disproved by a method acceptable to the local fire department and the State Fire Marshal.
- (C) If a suspected release is confirmed, the owners and operators of the UST system must undertake all required corrective actions.

Initial Corrective Actions

The following steps must be taken at **all confirmed petroleum releases sites**:

- (A) Upon confirmation of an actual release, or discovery of a release in any other manner, the owners and operators of the UST system must:
 - (1) Report the confirmed releases to the local fire department and the State Fire Marshal within twenty-four hours.
 - (2) Stop any further release from the UST system;
 - (3) Mitigate all fire, explosion, and safety hazards;
 - (4) Remove and properly dispose of all visibly contaminated soil and any associated groundwater from the excavation zone. The disposal of contaminated soil or water must comply with all applicable local, state and federal regulations;
 - (5) Conduct an investigation to determine the possible presence of free product and initiate removal of any free product found as soon as practicable;
 - (6) Report all initial corrective action taken, including a verification of tank repair or closure if appropriate, to the local fire department and the State Fire Marshal within twenty days of the confirmation or discovery of the release.
 - (7) All UST system repairs, removals, abandonment, installation, and replacement must comply with the requirements of the Ohio Fire Code and all other local and state regulations. The Ohio Fire Code requires a permit from the fire official for all such actions.
- (B) Site investigation. The owner and operator must perform a site investigation for contaminated soil, groundwater, or free product and assemble from the investigation, or from other sources (e.g., USGS maps, SCS soil maps, Ohio Department of Natural Resources Division of Water, Ohio Environmental Protection Agency, and other agencies), any information

deemed necessary by the State Fire Marshal. The site investigation and information must include, but is not limited to, the following:

- (1) Data on the nature and estimated quantity of the released substance;
 - (2) Data from surface and subsurface soil sampling and analyses;
 - (3) Data from groundwater and/or surface water sampling and analyses;
and
 - (4) Data from available sources and/or site investigations concerning background levels prior to the release, water quality and use, well locations, subsurface soil conditions, climatological conditions, land use, and surrounding populations.
- (C) Reporting. The results of this site investigation and all required information must be reported to the State Fire Marshal within twenty days of the confirmation or discovery of the release unless otherwise directed by the fire marshal. The State Fire Marshal may request the collection and submission of additional information and/or a corrective action plan for additional soil, surface water, and groundwater cleanup.

Free Product Removal

The following steps must be taken at **all release sites where free product has been found**:

- (A) At sites where an owner or operator's investigations indicate the presence of a free product, the owner or operator must remove free floating product to the maximum extent practicable while continuing, as necessary, all other corrective action steps initiated, and while preparing for subsequent long term corrective actions. In meeting this requirement, the owner or operator shall:
 - (1) Conduct free product recovery in such a manner that such actions do not:
 - (a) spread contamination into previously uncontaminated areas through untreated discharge or improper disposal techniques, or
 - (b) produce vapors in the atmosphere at levels such that they pose a health and safety threat to previously uncontaminated areas.
 - (2) Handle any flammable products in a safe and competent manner to prevent fires or explosions.
- (B) Unless directed to do otherwise by the State Fire Marshal, prepare and submit, within thirty days of the confirmation or discovery of the release, a free product removal report to the State Fire Marshal. The report shall provide, but is not limited to, the following information:

- (1) The name of the person(s) responsible for implementing the plan;
- (2) The estimated quantity and type of product on site and the product thickness in wells, boreholes, and excavations;
- (3) Details of the product recovery system;
- (4) Whether any discharge will take place on or off site during the recovery operation;
- (5) The type of treatment and expected effluent quality from any discharge; and
- (6) The disposition of the recovered product.

Site Assessment

The following steps must be taken at all **release sites where remaining soil or ground water contamination has been found**:

- (A) Whenever an investigation indicates that there may be remaining soil contamination from the release, or that the released product or product from contaminated soil may have reached groundwater, or as otherwise directed by the State Fire Marshal, the owners and operators must:
 - (1) Conduct additional investigations of the release, the release site, and the surrounding area possibly affected by the release, to determine the full extent and location of the soils contaminated by the release; and
 - (2) Conduct additional investigations of the release, the release site, and the surrounding area possibly affected by the release to determine the presence of dissolved contamination due to the release in the ground water.
- (B) When directed by the State Fire Marshal, conduct an exposure assessment to determine the extent of exposure of, or potential exposure for exposure of, individuals to petroleum from the release. Such assessment shall be based on such factors as the nature and extent of contamination and the existence of or potential for pathways of human exposure, the size of the community within the likely pathways of exposure, and the comparison of expected human exposure levels to the short-term and long-term health effects associated with identified contaminants and any available recommended exposure or tolerance limits for such contaminants.
- (C) The information collected by the owners and operators during the course of this site assessment shall be submitted in accordance with a schedule established by the State Fire Marshal.
- (D) The State Fire Marshal may request the submission of a corrective action plan for additional soil and/or ground water cleanup.

Long Term Corrective Action

The following steps must be taken when **long term soil and/or ground water cleanup** is required by the State Fire Marshal:

- (A) Owners and operators must develop and submit a corrective action plan for responding to any contaminated soils, surface waters, or ground waters shall submit such a plan according to a schedule established by the State Fire Marshal.
- (B) The State Fire Marshal shall approve the corrective action plan only if it assures that implementation of the plan will provide adequate protection of human health, safety, and the environment. In making this determination, the State Fire Marshal shall consider:
 - (1) The physical and chemical characteristics of the petroleum substance, including its toxicity, persistence, and potential for migration;
 - (2) The hydrogeologic characteristics of the facility and the surrounding land;
 - (3) The proximity, quality, and current and future uses of ground water and surface waters; and
 - (4) The results of an exposure assessment when such an assessment is required.
- (C) Upon approval of the corrective action plan, the owners and operators shall implement the plan and monitor, evaluate, and report the results of implementation, as required by the State Fire Marshal.
- (D) Public participation.
 - (1) Prior to the approval of each long term corrective action plan submitted, the State Fire Marshal will provide an opportunity for public review and comment on the plan.
 - (2) If there is sufficient public interest, or for any other reason, the State Fire Marshal may hold a public meeting to consider comments on the corrective action plan. A public meeting will be conducted in any case where implementation of an approved corrective action plan does not achieve the established cleanup levels and termination of that plan is under consideration.
 - (3) In deciding whether to approve or modify the corrective action plan, the fire marshal will consider and respond to the comments from the public.

Cost Recovery

The owner or operator of an underground storage tank from which a release of petroleum has occurred is liable to the state for any costs incurred for any corrective or enforcement action undertaken by the State that is conducted pursuant to section 3737.88 Of the Ohio Revised Code.

Data Chart for Tank System Tightness Test

PLEASE PRINT

1. OWNER Property <input checked="" type="checkbox"/> Tank(s) <input checked="" type="checkbox"/>	REVENNA ARSENAL					
	Name	Address	Representative	Telephone		
2. OPERATOR	SAME					
	Name	Address	Representative	Telephone		
3. REASON FOR TEST (Explain Fully)	NEW LAWS					
4. WHO REQUESTED TEST AND WHEN	WAYNE CARLIDO					
	Name	Title	Company or Affiliation	Date		
5. TANK INVOLVED Use additional lines for manifolded tanks	Identify by Direction	Capacity	Brand/Supplier	Grade	Approx. Age	Steel/Fiberglass
	#11 R/R YARD	15,000		#2 Fuel Oil	49 YRS	STEEL
6. INSTALLATION DATA	Location	Cover	Fills	Vents	Siphones	Pumps
	North inside driveway, Rear of station, etc.	EARTH	2" + 3"	2"	N/A	suction
7. UNDERGROUND WATER	Depth to the Water table <u>725</u>					
	Is the water over the tank? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
8. FILL-UP ARRANGEMENTS	Tanks to be filled _____ hr. _____ Date Arranged by _____ Name _____ Telephone _____					
	Extra product to "top off" and run tank tester. How and who to provide? Consider NO Lead.					
9. CONTRACTOR, MECHANICS, any other contractor involved	Terminal or other contact for notice or inquiry _____ Company _____ Name _____ Telephone _____					
	Additional information on any items above. Officials or others to be advised when testing is in progress or completed. Visitors or observers present during test, etc.					
10. OTHER INFORMATION OR REMARKS	Tests were made on the above tank systems in accordance with test procedures prescribed for as detailed on attached test charts with results as follows:					
	Tank Identification	Tight	Leakage Indicated	Date Tested		
#11 R/R YARD	NO	- .353 G.P.H.	1-26-90			
12. SENSOR CERTIFICATION 3-89 Date 2408 Serial No. of Thermal Sensor						
13. This is to certify that these tank systems were tested on the date(s) shown. Those indicated as "Tight" meet the criteria established by the National Fire Protection Association Pamphlet 329.						
Technicians						
1. A.L. BEARS			ALL OHIO PETRO TEST INC.			
Certification # 12210645			Testing Contractor or Company. By: Signature			
2. _____			2507 4th ST. N.W. CANTON, OHIO 44708			
Certification # _____			Address			

1300	4	11.5	12	1.225	1.205	-0.020	2.53	+1	4.023	1.043	-2.15
1305	7	11.5	12	.985	.965	-0.020	2.53	+0	4.000	-0.020	-1.235
1310	8	11.4	12	.965	.940	-0.025	2.53	+0	4.000	-0.025	-1.260
1315	9	11.4	12	.940	.915	-0.025	2.54	+1	4.023	-0.048	-1.308
1320	10	11.4	12	.915	.890	-0.025	2.54	+0	4.000	-0.025	-1.333
1325	11	11.4	12	.890	.865	-0.025	2.55	+1	4.023	-0.048	-1.381
1330	12	11.4	12	.865	.840	-0.025	2.54	-1	4.023	-0.002	-1.383
1335	13	11.4	12	.840	.815	-0.025	2.55	+1	4.023	-0.048	-1.431
1340	14	11.4	12	.815	.790	-0.025	2.55	+0	4.000	-0.025	-1.456
1345	15	11.4	12	.790	.765	-0.025	2.56	+1	4.023	1.048	-1.504
1350	16	11.4	12	.765	.740	-0.025	2.56	+0	4.000	-0.025	-1.529
1355	17	11.4	12	.740	.715	-0.025	2.56	+0	4.000	-0.025	-1.554
1400	18	11.4	12	.715	.690	-0.025	2.55	-1	4.023	1.002	-1.556
1405	19	11.4	12	.690	.665	-0.025	2.55	+0	4.000	-0.025	-1.581
1410	20	11.4	12	.665	.640	-0.025	2.56	+1	4.023	-0.048	-1.629
1415	21	11.4	12	.640	.615	-0.025	2.56	+0	4.000	-0.025	-1.645
1420	22	11.4	12	.615	.590	-0.025	2.56	+0	4.000	-0.025	-1.679
1425	23	11.4	12	.590	.565	-0.025	2.56	+0	4.000	-0.025	-1.704
1430	24	11.4	12	.565	.540	-0.025	2.55	-1	4.023	-0.002	-1.706
		End Test								-1.353	GRN.

P-T Tank Test Data Chart
Additional Info

1. Net Volume Change at Conclusion of Precision Test -1.353 gph
 Signature of Tester: AL Sears
 Date: 1-26-90

2. Statement:
 Tank and product handling system has been tested tight according to the Precision Test Criteria as established by N.F.P.A. publication 329. This is not intended to indicate permission of a leak.
 OR
 Tank and product handling system has failed the tank tightness test according to the Precision Test Criteria as established by N.F.P.A. publication 329.

It is the responsibility of the owner and/or operator of this system to immediately advise state and local authorities of any implied hazard and the possibility of any reportable pollution to the environment as a result of the indicated failure of this system. Health Consultants Incorporated does not assume any responsibility or liability for any loss of product to the environment.

Tank Owner/Operator _____

Date _____

27.	28.	29.	30.	31.	32.	33.	34.	35.	36.	37.	38.	39.
	DATE 1-26-88 (24 hr.)	Reading No.	HYDROSTATIC PRESSURE CONTROL	VOLUME MEASUREMENTS (V) RECORD TO 1001 GAL.	Product in Graduate	Product Replaced (-)	TEMPERATURE COMPENSATION USE FACTOR (a)	Thermal Sensor Reading	Change Higher + Lower (c)	Computation (c) x (a) = Expansion + Contraction -	TEMPERATURE CHANGING EACH READING	ACCUMULATED CHANGE
	Record details of setting up and running test. (Use full length of line if needed.)	Standpipe Level in inches	Level to which Restored	Before Reading	After Reading	Product Recovered (+)					Temperature Adjustment	At Low Level compute Change per Hour (MPa criteria)
12731	ARRIVE TEST LOCATION											
12730	MAKE MODIFICATION TO TANK TOP FOREGGIN.											
1245	CHECK FIVE GRADEWATER TABLE											
1244	SET UP SCAFFOLDING											
1243	SET UP EQUIP											
1242	FIL LEGUIP AND BLEED AIR FROM SYSTEM											
1241	START CIRCULATION											
1240	DRAW SAMPLES											
1239	START HIGH LEVEL TEST	1	12		800	800		222				
1238		2	12	800	570	-230		222	+1	4.023	-253	
1237		3	12	570	270	-300		223	+1	4.023	-323	
1236		4	12	1000	700	-300		226	+3	4.067	-369	
1235	Bleed Air From System	5	12	700	355	-345		228	+2	4.046	-391	
1234		6	12	355	070	-285		228	+0	4.000	-285	
1233		7	12	1000	755	-245		229	+1	4.023	-268	
1232		8	12	755	520	-235		232	+3	4.069	-294	
1231		9	12	520	285	-235		234	+2	4.046	-281	
1230		10	12	1000	800	-200		237	+3	4.067	-269	
1229		11	12	800	600	-200		239	+2	4.046	-246	
1228		12	12	1600	400	-200		241	+2	4.046	-246	
1227	PROPAGATE LOW LEVEL TEST											
1226	PRELIM READING	13	12					245				
1225	" "	14	12					248				
1224	START LOW LEVEL TEST	1	12	305	300	-005		249	+1	4.023	-028	
1223		2	12	300	285	-015		251	+2	4.046	-061	
1222		3	12	285	265	-020		251	+0	4.000	-020	
1221		4	12	265	245	-020		252	+1	4.023	-043	
1220		5	12	245	225	-020		252	+0	4.000	-020	

14. RUSSIA ARSENAL SK 5 Ky, Ky 40119 DD12 1-20-10
 Name of Supplier, Owner or Dealer Address No and Street(s) City State Date of Test

15. TANK TO TEST
 #11 R/E yard
 #2 fuel oil
 Identify by position Brand and Grade

15a. BRIEF DIAGRAM OF TANK FIELD

16. CAPACITY
 Nominal Capacity 15,000 Gallons
 By most accurate capacity chart available 15,540 Gallons

From Station Chart Tank Manufacturer's Chart Company Engineering Data Charts supplied with Other

Total Gallons as Reading 15,540

17. FILL-UP FOR TEST

Sick Water Bottom before fill-up 0 in. 0 Gallons
 Tank Diameter 124 in. Inventory 70 Poff

15,540
20
TOTAL
 Transfer total to line 25a 15,560

18. SPECIAL CONDITIONS AND PROCEDURES TO TEST THIS TANK Water in tank Line(s) being tested with LVLLT
 High water table in tank excavation

See manual sections applicable. Check below and record procedure in log (27).
 Use maximum allowable test pressure for all tests. Four pound rule does not apply to doublewalled tanks.
 Complete section below.

19. TANK MEASUREMENTS FOR TST ASSEMBLY

Bottom of tank to grade 247 in. Add 30" for "T" probe assy. 30 in. Total tubing to assemble - approximate 277 in.

20. EXTENSION HOSE SETTING

Tank top to grade 121 in. Extend hose on suction tube 6" or more below tank top 0 in.

If fill pipe extends above grade, use top of fill.

21. VAPOR RECOVERY SYSTEM Stage I Stage II

24b. COEFFICIENT OF EXPANSION RECIPROCAL METHOD

Type of Product #2 fuel oil
 Hydrometer Employed 4 H
 Temperature in Tank After Circulation 46.4 °F
 Temperature of Sample 41.0 °F
 Difference (T-T') -5 °F
 Observed A.P.L. Gravity 34.9

22. Thermal Sensor reading after circulation 3221 digits
4647 digits
342 °F


23. Digits per °F in range of expected change 342 digits

COEFFICIENT OF EXPANSION (Complete after circulation)

24a. Corrected A.P.L. Gravity 38
 Observed A.P.L. Gravity 38

24c. FOR TESTING WITH WATER see Table C & D

Water Temperature after Circulation 15.566 °F
 Table C Reciprocal 2159
 Total quantity in full tank (16 or 17) 15,566
 Volume change in this tank per °F 2,209,819.3
 Volume change per digit in this tank per °F 2,209,819.3
 Transfer to Line 25a.



The above calculations are to be used for dry soil conditions to establish a positive pressure advantage, or when using the four pound rule to compensate for the presence of subsurface water in the tank area.

Refer to N.F.P.A. 30. Sections 2-3.2.4 and 2-7.2 and the tank manufacturer regarding allowable system test pressures.

25. (a) 15,560 Total quantity in full tank (16 or 17) x (b) 312 Coefficient of expansion for involved product = 4,839.2 Volume change per °F in test Range (23)

26. (a) 7,209,819.3 Volume change per °F (25 or 24b) x (b) 312 Coefficient of expansion for involved product = 2,235,108.3 Volume change per digit Complete to 4 decimal places. This is test factor (a)

Data Chart for Tank System Tightness Test

PLEASE PRINT

1. OWNER Property <input checked="" type="checkbox"/> Tank(s) <input checked="" type="checkbox"/>	REJUNKA ARSENAL Name Address Representative Telephone Name Address Representative Telephone																					
2. OPERATOR	SAME Name Address Telephone																					
3. REASON FOR TEST (Explain Fully)	NEW LAWS																					
4. WHO REQUESTED TEST AND WHEN	WAYNE CARLIDO ENG. Name Title Company or Affiliation Date Address Telephone																					
5. TANK INVOLVED Use additional lines for manifolded tanks	Identify by Direction #23 B. 1045	Capacity 15,000	Brand/Supplier	Grade #2 FUEL OIL	Approx. Age 41 YRS	Steel/Fiberglass STEEL																
6. INSTALLATION DATA	Location Southeast corner of Building 1045 North inside driveway, Rear of station, etc.	Cover EARTH Concrete, Black Top, Earth, etc.	Fills 4"	Vents 2"	Siphons N/A	Pumps Suction Suction, Remote. Make if known																
7. UNDERGROUND WATER	Depth to the Water table 34 is the water over the tank? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No																					
8. FILL-UP ARRANGEMENTS	Tanks to be filled _____ hr. _____ Date Arranged by _____ Name Telephone Extra product to "top off" and run tank tester. How and who to provide? Consider NO LEAD. Terminal or other contact for notice or inquiry _____ Company Name Telephone																					
9. CONTRACTOR, MECHANICS, any other contractor involved	_____ _____ _____																					
10. OTHER INFORMATION OR REMARKS	Suction Line disconnected for test with STATE FIRE MARSHALL Additional information on any items above. Officials or others to be advised when testing is in progress or completed. Visitors or observers present during test, etc.																					
11. TEST RESULTS	Tests were made on the above tank systems in accordance with test procedures prescribed for as detailed on attached test charts with results as follows: <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 30%;">Tank Identification</th> <th style="width: 10%;">Tight</th> <th style="width: 30%;">Leakage Indicated</th> <th style="width: 30%;">Date Tested</th> </tr> </thead> <tbody> <tr> <td>#23 B. 1045</td> <td>NO</td> <td>- .3005 G.P.H.</td> <td>1-18-90</td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>						Tank Identification	Tight	Leakage Indicated	Date Tested	#23 B. 1045	NO	- .3005 G.P.H.	1-18-90								
Tank Identification	Tight	Leakage Indicated	Date Tested																			
#23 B. 1045	NO	- .3005 G.P.H.	1-18-90																			
12. SENSOR CERTIFICATION 3-89 Date 2408 Serial No. of Thermal Sensor	13. This is to certify that these tank systems were tested on the date(s) shown. Those indicated as "Tight" meet the criteria established by the National Fire Protection Association Pamphlet 329. Technicians 1. AL SEARS ALL OHIO PETERS TEST INC. Certification # 122110645 Testing Contractor or Company. By: Signature 2507 4th ST. N.W. CANTON, OHIO 44708 Address Certification # _____																					

1730		6	13.0	12	270	305	4,035	477	-1	7,022	4,057	
1735	START LOW LEVEL TEST	1		12				476				
1740		2	11.9	12	315	310	7,005	476	70	4,000	7,005	
1745		3	11.7	12	310	300	7,010	477	71	4,022	7,032	7,037
1750		4	11.7	12	300	290	7,010	477	70	4,000	7,010	7,047
1755		5	11.5	12	290	270	7,020	478	71	4,022	7,042	7,059
1800		6	11.5	12	270	250	7,020	478	70	4,000	7,020	7,109
1805		7	11.5	12	270	270	7,020	478	70	4,000	7,020	7,129
1810		8	11.5	12	270	250	7,020	479	71	4,022	7,042	7,171
1815		9	11.5	12	250	230	7,020	480	71	4,022	7,042	7,213
1820		10	11.5	12	230	210	7,020	480	70	4,000	7,020	7,233
1825		11	11.5	12	210	190	7,020	480	70	4,000	7,020	7,253
1830		12	11.5	12	190	170	7,022	480	70	4,000	7,020	7,273
1835		13	11.5	12	170	150	7,020	481	71	4,022	7,042	7,315
1840		14	11.5	12	150	130	7,020	482	71	4,022	7,042	7,357
1845		15	11.5	12	130	110	7,020	482	70	4,000	7,020	7,377
1850		16	11.5	12	110	90	7,020	482	70	4,000	7,020	7,397
1855		17	11.5	12	90	70	7,020	481	-1	7,022	4,002	7,395
1900		18	11.5	12	70	50	7,020	481	70	4,000	7,020	7,415
1905		19	11.5	12	50	30	7,020	482	71	4,022	7,042	7,457
1910		20	11.5	12	30	10	7,020	483	71	4,022	7,042	7,499
1915		21	11.5	12	10	0	7,020	483	70	4,000	7,020	7,519
1920		22	11.5	12	0	0	7,020	484	71	4,022	7,042	7,561
1925		23	11.5	12	0	0	7,020	484	70	4,000	7,020	7,581
1930		24	11.5	12	0	0	7,020	484	70	4,000	7,020	7,601

P-T Tank Test Data Chart

Additional Info

1. Net Volume Change at Conclusion of Precision Test 3005 gph

Signature of Tester: H. L. Spawo

Date: 1-18-90

2. Statement:
 Tank and product handling system has been tested tight according to the Precision Test Criteria as established by N.F.P.A. publication 329. This is not intended to indicate permission of a leak.

Tank and product handling system has failed the tank tightness test according to the Precision Test Criteria as established by N.F.P.A. publication 329.

OR

It is the responsibility of the owner and/or operator of this system to immediately advise state and local authorities of any implied hazard and the possibility of any reportable pollution to the environment as a result of the indicated failure of this system. Health Consultants Incorporated does not assume any responsibility or liability for any loss of product to the environment.

Tank Owner/Operator _____

Date _____

14. REUSWAH ARSUAL SR. 5 REUSWAH DND 1-18-70
 Name of Supplier, Owner or Dealer Address No and Street(s) City State Date of Test

15. TANK TO TEST #23 B, 1045
 Identify by position
#2 FUEL OIL
 Brand and Grade

15a. BRIEF DIAGRAM OF TANK FIELD

16. CAPACITY
 Nominal Capacity 15000 Gallons
 By most accurate capacity chart available 15,546 Gallons

From Station Chart
 Tank Manufacturer's Chart
 Company Engineering Data
 Charts supplied with
 Other

17. FILL-UP FOR TEST

Slick Water Bottom before Fill-up 241 in. 62 Gallons
 Tank Diameter 126 in. Inventory 15,546 Gallons

Total Gallons as Reading 15,546

18. SPECIAL CONDITIONS AND PROCEDURES TO TEST THIS TANK
 High water table in tank excavation
 Water in tank (EO line(s) being tested with LWLT

See manual sections applicable. Check below and record procedure in log (27).
 Use maximum allowable test pressure for all tests.
 Four pound rule does not apply to doublewalled tanks.
 Complete section below:

1. Is four pound rule required? Yes No

2. Height to 12" mark from bottom of tank 2707 in.

3. Pressure at bottom of tank 4,609 P.S.I.


4. Pressure at top of tank 4,483 P.S.I.

20. EXTENSION HOSE SETTING
 Tank top to grade 326 in.
 Extend hose on suction tube 6" or more below tank top 10 in.

19. TANK MEASUREMENTS FOR TSTT ASSEMBLY
 Bottom of tank to grade 186 in.
 Add 30" for "T" probe assembly 30 in.
 Total tubing to assemble - approximate 186 in.

21. VAPOR RECOVERY SYSTEM Stage I Stage II

24b. COEFFICIENT OF EXPANSION RECIPROCAL METHOD
 Type of Product #2 FUEL OIL
 Hydrometer Employed 4 H
 Temperature in Tank After Circulation 44.0 °F
 Temperature of Sample 43 °F
 Difference (t-t') -1 °F
 Observed A.P.I. Gravity 34.0
 Reciprocal 2179 Page # 38
 Total quantity in full tank (16 or 17) 15,504 Reciprocal 2179
 Volume change in this tank per °F 71151904
 Transfer to Line 26a.



The above calculations are to be used for dry soil conditions to establish a positive pressure advantage, or when using the four pound rule to compensate for the presence of subsurface water in the tank area.

Refer to N.F.P.A. 30, Sections 2-3.2.4 and 2-7.2 and the tank manufacturer regarding allowable system test pressures.

25. (a) 71151904 x (b) 320 = (c) 2222349 gallons
 Total quantity in full tank (16 or 17) Coefficient of expansion for involved product
 Digit per °F in test Range (23) Volume change per °F (25 or 24b) This is test factor (a)

26. Volume change per °F (25 or 24b) Digit per °F in test Range (23)

24c. FOR TESTING WITH WATER see Table C & D
 Water Temperature after Circulation Table C
 Coefficient of Water Table D
 Added Surfactant? Yes No Transfer COE to Line 25b.

27. Sensor Calibration 16730 16732

LOG OF TEST PROCEDURES

28. DATE TIME (24 hr.)	Record details of setting up and running test (use full length of line if needed)	29. Reading No.	30. HYDROSTATIC PRESSURE CONTROL		31. VOLUME MEASUREMENTS (V) RECORD TO 0.01 GAL.		34. TEMPERATURE COMPENSATION USE FACTOR (a)			38. NET VOLUME CHANGING EACH READING	39. ACCUMULATED CHANGE
			Stagnant level in inches	Level to which restored	Product in Graduate Before Reading	Product in Graduate After Reading	Product Replaced (-)	Product Recovered (+)	Thermal Sensor Reading		

1-18-90	ARRIVE TEST LOCATION STICK WAIT FOR TANK TO BE TOPPED OFF												
	SETUP SCARFOLDING												
	SETUP 2 SETS OF GAUGES												
	FILE GAUGE AND BLEED AIR FROM SYSTEM												
1130	START CIRCULATION												
1229	TAKE SAMPLE												
1230	START HIGH LEVEL TEST	1	4/2		1,720	1,720				7450			
1245		2	39.2	4/2	1,720	1,620	-100			4150	+0	1,000	-100
1300		3	37.9	4/2	1,620	1,470	-150			4151	+1	1,022	-172
1315	Bleed AIR FROM SYSTEM	4	37.5	4/2	1,470	1,290	-180			4151	+0	1,000	-180
1330		5	37.3	4/2	1,000	1,820	-180			4151	+0	1,000	-180
1345		6	37.7	4/2	1,820	1,660	-160			4152	+1	1,022	-182
1400		7	37.7	4/2	1,660	1,500	-160			4153	+1	1,022	-182
1415		8	38.0	4/2	1,500	1,350	-150			4155	+2	1,044	-194
1430		9	38.0	4/2	1,350	1,200	-150			4158	+3	1,067	-217
1445		10	38.0	4/2	1,200	1,050	-150			4160	+2	1,044	-194
5003		11	38.0	4/2	1,050	1,610	-150			4163	+3	1,067	-217
1515		12	38.0	4/2	1,610	1,310	-150			4164	+1	1,022	-172
1517	Drop To low level TEST												
	Rebled MANWAY												
1600	RETURN HOUR HIGH LEVEL												
1615		1		4/2		1,725				7470			
1630		2	38.3	4/2	1,725	1,590	-135			4172	+2	1,044	-179
1645		3	38.3	4/2	1,590	1,455	-135			4176	+4	1,089	-224
1700		4	38.3	4/2	1,455	1,320	-135			4178	+2	1,044	-179
1702	Drop To low level TEST												
1715		5	15.2	1/2	1,600	1,760	4160			4178	+0	1,000	4160

Data Chart for Tank System Tightness Test

PLEASE PRINT

<p>1. OWNER Property <input checked="" type="checkbox"/></p> <p> Tank(s) <input checked="" type="checkbox"/></p>	<p><i>REUNNA ARSENA</i></p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 33%;">Name</td> <td style="width: 33%;">Address</td> <td style="width: 15%;">Representative</td> <td style="width: 19%;">Telephone</td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td>Name</td> <td>Address</td> <td>Representative</td> <td>Telephone</td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </table>						Name	Address	Representative	Telephone					Name	Address	Representative	Telephone								
Name	Address	Representative	Telephone																							
Name	Address	Representative	Telephone																							
<p>2. OPERATOR</p>	<p><i>Same</i></p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 33%;">Name</td> <td style="width: 33%;">Address</td> <td style="width: 15%;">Representative</td> <td style="width: 19%;">Telephone</td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </table>						Name	Address	Representative	Telephone																
Name	Address	Representative	Telephone																							
<p>3. REASON FOR TEST (Explain Fully)</p>	<p><i>LEAKS</i></p>																									
<p>4. WHO REQUESTED TEST AND WHEN</p>	<p><i>WELLS CONTRACTORS INC.</i> <i>ENG.</i></p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 33%;">Name</td> <td style="width: 33%;">Title</td> <td style="width: 15%;">Company or Affiliation</td> <td style="width: 19%;">Date</td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td colspan="3">Address</td> <td>Telephone</td> </tr> <tr> <td colspan="3"> </td> <td> </td> </tr> </table>						Name	Title	Company or Affiliation	Date					Address			Telephone								
Name	Title	Company or Affiliation	Date																							
Address			Telephone																							
<p>5. TANK INVOLVED</p> <p>Use additional lines for manifolded tanks</p>	Identify by Direction	Capacity	Brand/Supplier	Grade	Approx. Age	Steel/Fiberglass																				
	<i>#33 DEAC FURNACE</i>	<i>2000</i>		<i>#2 FUEL OIL</i>		<i>STEEL</i>																				
<p>6. INSTALLATION DATA</p>	Location	Cover	Fills	Vents	Siphones	Pumps																				
	<i>EAST SIDE OF BURN JAIL</i>	<i>EARTH</i>	<i>3"</i>	<i>2"</i>	<i>N/A</i>	<i>Suction</i>																				
	North inside driveway, Rear of station, etc.	Concrete, Black Top, Earth, etc.	Size, Titfill make, Drop tubes, Remote Fills	Size, Manifolded	Which tanks?	Suction, Remote, Make if known																				
<p>7. UNDERGROUND WATER</p>	<p>Depth to the Water table <i>69</i></p> <p style="text-align: right;">Is the water over the tank? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p>																									
<p>8. FILL-UP ARRANGEMENTS</p>	<p>Tanks to be filled _____ hr. _____ Date Arranged by _____ Name Telephone _____</p> <p>Extra product to "top off" and run tank tester. How and who to provide? Consider NO Lead.</p> <hr/> <p>Terminal or other contact for notice or inquiry _____ Company Name Telephone _____</p>																									
<p>9. CONTRACTOR, MECHANICS, any other contractor involved</p>	<p> </p> <p> </p> <p> </p>																									
<p>10. OTHER INFORMATION OR REMARKS</p>	<p> </p> <p> </p> <p> </p> <p>Additional information on any items above. Officials or others to be advised when testing is in progress or completed. Visitors or observers present during test, etc.</p>																									
<p>11. TEST RESULTS</p>	<p>Tests were made on the above tank systems in accordance with test procedures prescribed for as detailed on attached test charts with results as follows:</p> <table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 33%;">Tank Identification</th> <th style="width: 16.6%;">Tight</th> <th style="width: 33%;">Leakage Indicated</th> <th style="width: 16.6%;">Date Tested</th> </tr> </thead> <tbody> <tr> <td><i>#33 DEAC FURNACE</i></td> <td><i>NO</i></td> <td><i>7.0825 G.P.H.</i></td> <td><i>1-15-90</i></td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>						Tank Identification	Tight	Leakage Indicated	Date Tested	<i>#33 DEAC FURNACE</i>	<i>NO</i>	<i>7.0825 G.P.H.</i>	<i>1-15-90</i>												
Tank Identification	Tight	Leakage Indicated	Date Tested																							
<i>#33 DEAC FURNACE</i>	<i>NO</i>	<i>7.0825 G.P.H.</i>	<i>1-15-90</i>																							
<p>12. SENSOR CERTIFICATION</p> <p><i>3-89</i></p> <p>Date</p> <p><i>2458</i></p> <p>Serial No. of Thermal Sensor</p>	<p>13. This is to certify that these tank systems were tested on the date(s) shown. Those indicated as "Tight" meet the criteria established by the National Fire Protection Association Pamphlet 329.</p> <p style="text-align: center;">Technicians</p> <p>1. <i>A.L. SEARS</i></p> <p>Certification # <i>122110645</i></p> <p>2. _____</p> <p>Certification # _____</p> <p style="text-align: right;"><i>ALL OHIO PETRO TEST INC.</i></p> <p style="text-align: right;">Testing Contractor or Company. By: Signature</p> <p style="text-align: right;"><i>2507 4TH ST NW CANTON, OHIO</i></p> <p style="text-align: right;">Address <i>44708</i></p>																									

1415	12	12.5	12	1265	1285	7.020	686	77	7.022	-1.002	7.061
1450	13	12.5	12	1245	1305	7.020	696	710	7.032	-1.012	7.073
1455	14	12.5	12	1305	1325	7.020	704	78	7.026	-1.006	7.079
1500	15	12.5	12	1325	1345	7.020	711	77	7.022	-1.002	7.081
1505	16	12.5	12	1345	1365	7.020	721	710	7.032	-1.012	7.093
1510	17	12.5	12	1365	1385	7.020	731	710	7.032	-1.012	7.105
1515	18	12.5	12	1385	1405	7.020	739	78	7.026	-1.006	7.111
1520	19	12.5	12	1405	1425	7.020	749	710	7.032	-1.012	7.123
1525	20	12.5	12	1425	1445	7.020	757	78	7.026	-1.006	7.129
1530	21	12.5	12	1445	1465	7.020	765	78	7.026	-1.006	7.135
1535	22	12.5	12	1465	1485	7.020	774	79	7.029	-1.009	7.144
1540	23	12.5	12	1485	1505	7.020	783	79	7.029	-1.009	7.153
1545	24	12.5	12	1505	1525	7.020	793	710	7.032	-1.012	7.165
DROP PRODUCT DISCONNECT COPPER PRODUCT LINE AND RE TEST TANK ONLY											

P-T Tank Test Data Chart

Additional Info

1. Net Volume Change at Conclusion of Precision Test 10825 gph
 Signature of Tester: AL Seano
 Date: 1-15-90

2. Statement:
 Tank and product handling system has been tested tight according to the Precision Test Criteria as established by N.F.P.A. publication 329. This is not intended to indicate permission of a leak.

OR

Tank and product handling system has failed the tank tightness test according to the Precision Test Criteria as established by N.F.P.A. publication 329.

It is the responsibility of the owner and/or operator of this system to immediately advise state and local authorities of any implied hazard and the possibility of any reportable pollution to the environment as a result of the indicated failure of this system. Health Consultants Incorporated does not assume any responsibility or liability for any loss of product to the environment.

Tank Owner/Operator _____

Date _____

14. REUNION APPROPRIAL SPS KEONURY DD10 1-12-80
 Name of Supplier, Owner or Dealer Address No and Street(s) City State Date of Test

15. TANK TO TEST
 # 33 DINAC FURNACE
 Identify by position
 # 2 FUEL OIL
 Brand and Grade

15a. BRIEF DIAGRAM OF TANK FIELD

16. CAPACITY
 Nominal Capacity 2000 Gallons
 By most accurate capacity chart available 2005 Gallons

From
 Station Chart
 Tank Manufacturer's Chart
 Company Engineering Data
 Charts supplied with Petro-Tite Equip
 Other SLIDESHARE

17. FILL-UP FOR TEST
 Slick Water Bottom 1/8 in. 1 Gallons
 before fill-up to 1/4 in. Tank Diameter 64 in. Inventory 64 in.

Total Gallons as Reading
64 in. 2005
2005
7 5
1
2009

18. SPECIAL CONDITIONS AND PROCEDURES TO TEST THIS TANK
 See manual sections applicable. Check below and record procedure in log (27).
 Use maximum allowable test pressure for all tests. Four pound rule does not apply to doublewalled tanks.
 Complete section below:
 1. Is four pound rule required? Yes No
 2. Height to 12" mark from bottom of tank 100 in.
 3. Pressure at bottom of tank 3,100 P.S.I.
 4. Pressure at top of tank 1,116 P.S.I.


21. VAPOR RECOVERY SYSTEM Stage II
 24b. COEFFICIENT OF EXPANSION RECIPROCAL METHOD
 Type of Product #2 Fuel Oil
 Hydrometer Employed 4 H
 Temperature in Tank 34.2 °F
 After Circulation 37 °F
 Temperature of Sample 43 °F
 Difference (+/-) 34.4
 Observed A.P.I. Gravity 21.78 Page # 38
 Reciprocal 2178 Reciprocal 2178
 Total quantity in full tank (16 or 17) 2009 Volume change in this tank per °F Transfer to Line 25a.

19. TANK MEASUREMENTS FOR TSTT ASSEMBLY
 Bottom of tank to grade 69 in. 30 in.
 Add 30" for "T" probe assy. 99 in.
 Total tubing to assemble - approximate 99 in.

20. EXTENSION HOSE SETTING
 Tank top to grade 6 in.
 Extend hose on suction tube 6" or more below tank top 20 in.

22. Thermal Sensor reading after circulation 49.72
 23. Digits per °F in range of expected change 34/35 digits
 24a. COEFFICIENT OF EXPANSION (Complete after circulation)
 Corrected A.P.I. Gravity 28.4
 Observed A.P.I. Gravity 28.4
 Hydrometer employed 28.4 H
 Observed Sample Temperature 28.4 °F
 Corrected A.P.I. Gravity 28.4
 @ 60°F. From Table A 28.4
 Coefficient of Expansion for Involved Product
 From Table B 28.4
 Transfer COE to Line 25b.

24c. FOR TESTING WITH WATER see Table C & D
 Water Temperature after Circulation
 Table C 28.4 °F
 Coefficient of Water
 Table D 28.4
 Added Surfactant? Yes No Transfer COE to Line 25b.



NOTES:
 The above calculations are to be used for dry soil conditions to establish a positive pressure advantage, or when using the four pound rule to compensate for the presence of subsurface water in the tank area.
 Refer to N.F.P.A. 30, Sections 2-3.2.4 and 2-7.2 and the tank manufacturer regarding allowable system test pressures.

25. (a) Total quantity in full tank (16 or 17) 7224058
 (b) Coefficient of expansion for involved product 28.4
 Volume change per °F (25 or 24b) 28.4
 Digits per °F in test Range (23)

(c) Volume change in this tank per °F 2032.027
 Volume change per digit 1.0032
 Compute to 4 decimal places. This is test factor (a)

27. Sensor Calibration 16230, 16232 LOG OF TEST PROCEDURES		30. HYDROSTATIC PRESSURE CONTROL		31. VOLUME MEASUREMENTS (V) RECORD TO .001 GAL.		34. TEMPERATURE COMPENSATION USE FACTOR (a)		38. NET VOLUME CHANGING EACH READING		39. ACCUMULATED CHANGE
28. DATE 1-15-70 (24 hr.)	Record details of setting up and running test (Use full length of line if needed.)	29. Reading No.	32. Product in Graduate		33. Product Replaced (-) Product Recovered (+)	35. Thermal Sensor Reading	36. Change Higher - Lower (C)	37. Compensation (C) x (a) = Expansion + Contraction -	Temperature Adjustment Volume Minus Expansion (+) or Contraction (-) (23(V) - 427(I))	At Low level compute Change per Hour (NFA criteria)
			Beginning of Reading	Level to which Restored						
1/30	ARRIVE TEST SITE WAIT FOR PERSON TO UNLOCK AREA TO TRUCK TO DETESTED							1.0032		
1/30	START High Level Test	1				141R				
1/30	START High Level Test	2	13.1	42	245	295	1.050	1.083	-.033	
1/30	START High Level Test	3	13.1	42	295	340	1.045	1.083	-.038	
1/30	START High Level Test	4	13.1	42	340	390	1.050	1.083	-.033	
1/30	START High Level Test	5	13.1	42	350	440	1.050	1.083	-.033	
1/30	START High Level Test	6	12.9	42	440	475	1.035	1.084	-.051	
1/30	START High Level Test	7	13.7	42	475	540	1.065	1.077	-.01R	
1/30	START High Level Test	8	13.2	42	540	580	1.040	1.074	-.034	
1/30	START High Level Test	1	12.5	42	580	600	1.020	1.022	-.002	
1/30	START High Level Test	2	12.5	42	600	620	1.020	1.022	-.002	
1/30	START High Level Test	3	12.5	42	620	640	1.013	1.029	-.013	
1/30	START High Level Test	4	12.5	42	640	660	1.020	1.022	-.002	
1/30	START High Level Test	5	12.5	42	620	640	1.028	1.024	-.004	
1/30	START High Level Test	6	12.5	42	640	660	1.037	1.029	-.009	
1/30	START High Level Test	7	12.5	42	660	680	1.047	1.032	-.012	
1/30	START High Level Test	8	12.5	42	680	700	1.056	1.029	-.009	
1/30	START High Level Test	9	12.5	42	700	720	1.063	1.022	-.002	
1/30	START High Level Test	10	12.5	42	720	745	1.072	1.029	-.009	
1/30	START High Level Test	11	12.5	42	745	765	1.079	1.022	-.002	

Data Chart for Tank System Tightness Test

PLEASE PRINT

<p>1. OWNER <input checked="" type="checkbox"/> Property <input checked="" type="checkbox"/> Tank(s)</p>	<p><u>REXINA ARSENAL</u></p> <p>Name _____ Address _____ Representative _____ Telephone _____</p> <p>Name _____ Address _____ Representative _____ Telephone _____</p>																					
<p>2. OPERATOR</p>	<p><u>SAME</u></p> <p>Name _____ Address _____ Telephone _____</p>																					
<p>3. REASON FOR TEST (Explain Fully)</p>	<p><u>RETEST AFTER DISCONNECTING COOPER LINE</u></p>																					
<p>4. WHO REQUESTED TEST AND WHEN</p>	<p><u>WAYNE CARLSON</u> <u>ENG.</u></p> <p>Name _____ Title _____</p>		<p><u>SAME</u></p> <p>Company or Affiliation _____</p>		<p><u>1-15-90</u></p> <p>Date _____</p>																	
<p>5. TANK INVOLVED</p> <p>Use additional lines for manifolded tanks</p>	<p>Identify by Direction <u>#33 DEAC.</u> <u>FURNACE</u></p>	<p>Capacity <u>2000</u></p>	<p>Brand/Supplier</p>	<p>Grade <u>#2 FUEL OIL</u></p>	<p>Approx. Age</p>	<p>Steel/Fiberglass <u>STEEL</u></p>																
<p>6. INSTALLATION DATA</p>	<p>Location <u>EAST SIDE OF BURN UNIT</u></p> <p>North inside driveway, Rear of station, etc.</p>	<p>Cover <u>EARTH</u></p> <p>Concrete, Black Top, Earth, etc.</p>	<p>Fills <u>8"</u></p> <p>Size, Titefill make, Drop tubes, Remote Fills</p>	<p>Vents <u>2"</u></p> <p>Size, Manifolded</p>	<p>Siphones <u>N/A</u></p> <p>Which tanks?</p>	<p>Pumps <u>DISCONNECTE</u></p> <p>Suction, Remote, Make if known</p>																
<p>7. UNDERGROUND WATER</p>	<p>Depth to the Water table <u>69</u></p> <p>is the water over the tank? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p>																					
<p>8. FILL-UP ARRANGEMENTS</p>	<p>Tanks to be filled _____ hr. _____ Date _____ Arranged by _____ Name _____ Telephone _____</p> <p>Extra product to "top off" and run tank tester. How and who to provide? Consider NO Lead.</p> <p>Terminal or other contact for notice or inquiry _____ Company _____ Name _____ Telephone _____</p>																					
<p>9. CONTRACTOR, MECHANICS, any other contractor involved</p>	<p>_____</p> <p>_____</p> <p>_____</p>																					
<p>10. OTHER INFORMATION OR REMARKS</p>	<p><u>DISCONNECTED PRODUCT LINE TEST TANK ONLY</u></p> <p>Additional information on any items above. Officials or others to be advised when testing is in progress or completed. Visitors or observers present during test, etc.</p>																					
<p>11. TEST RESULTS</p>	<p>Tests were made on the above tank systems in accordance with test procedures prescribed for as detailed on attached test charts with results as follows:</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Tank Identification</th> <th>Tight</th> <th>Leakage Indicated</th> <th>Date Tested</th> </tr> </thead> <tbody> <tr> <td><u>#33 DEAC</u> <u>FURNACE</u></td> <td><u>NO</u></td> <td><u>-0.065 G.P.H.</u></td> <td><u>1-15-90</u></td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>						Tank Identification	Tight	Leakage Indicated	Date Tested	<u>#33 DEAC</u> <u>FURNACE</u>	<u>NO</u>	<u>-0.065 G.P.H.</u>	<u>1-15-90</u>								
Tank Identification	Tight	Leakage Indicated	Date Tested																			
<u>#33 DEAC</u> <u>FURNACE</u>	<u>NO</u>	<u>-0.065 G.P.H.</u>	<u>1-15-90</u>																			
<p>12. SENSOR CERTIFICATION</p> <p><u>3-89</u> Date <u>2428</u> Serial No. of Thermal Sensor</p>	<p>13. This is to certify that these tank systems were tested on the date(s) shown. Those indicated as "Tight" meet the criteria established by the National Fire Protection Association Pamphlet 328.</p> <p>Technicians</p> <p>1. <u>AL. SCARS</u></p> <p>2. _____</p> <p>Certification # <u>122110645</u></p> <p>Certification # _____</p> <p><u>ALL OHIO PETRO TEST INC.</u> Testing Contractor or Company. By: Signature <u>2507 4TH ST. N.W. CANTON, OHIO 44708</u> Address</p>																					

14. RESURVA APRESSUAL SRS RESURVA OHIO 410-70
 Name of Supplier, Owner or Dealer Address No. and Street(s) City State Date of Test

15. TANK TO TEST
 #33 Day FURNACE
 Identity by position
 #R EUSK DIL
 Brand and Grade

15a. BRIEF DIAGRAM OF TANK FIELD

16. CAPACITY
 Nominal Capacity 2000 Gallons
 By most accurate capacity chart available 2005 Gallons

From Station Chart Tank Manufacturer's Chart
 Company Engineering Data
 Charts supplied with REPORTERSHIP
 Other SLIDE CHART

17. FILL-UP FOR TEST
 Slick Water Bottom before fill-up 18' in 1 Gallons
 Tank Diameter 64 in. Inventory 64 Gallons
 Total Gallons as Filled 2005

18. SPECIAL CONDITIONS AND PROCEDURES TO TEST THIS TANK
 Water in tank WD (wells) being tested with LVLT
 High water table in tank excavation

19. TANK MEASUREMENTS FOR TSTT ASSEMBLY
 Bottom of tank to grade 69 in. 30 in.
 Add 30" for "T" probe assy. 99 in.
 Total tubing to assemble - approximate 99 in.

20. EXTENSION HOSE SETTING
 Tank top to grade 4 in.
 Extend hose on suction tube 6" or more below tank top 20 in.

21. VAPOR RECOVERY SYSTEM Stage II
 Reciprocal 2176 Page 38

24b. COEFFICIENT OF EXPANSION RECIPROCAL METHOD
 Type of Product #25 SLOIC
 Hydrometer Employed 2
 Temperature in Tank After Circulation 354 °F
 Temperature of Sample 39 °F
 Difference (t-t') +3 °F
 Observed A.P.I. Gravity 34.5
 Reciprocal 2176 Page 38


24c. FOR TESTING WITH WATER see Table C & D
 Water Temperature after Circulation _____ °F
 Table C _____ °F
 Coefficient of Water _____
 Table D _____
 Added Surfactant? Yes No Transfer COE to Line 25b.

22. Thermal Sensor reading after circulation 48.31
 Observed A.P.I. Gravity 35.36 °F
 Hydrometer employed _____ °F
 Observed Sample Temperature _____ °F

23. (Digits per °F in range of expected change) 292 digits
 COEFFICIENT OF EXPANSION (Complete after circulation)

24a. Corrected A.P.I. Gravity
 Observed A.P.I. Gravity _____
 Corrected A.P.I. Gravity _____
 @ 60°F From Table A _____

25. (a) 9223345 x (b) 292 = (c) 26831586 gallons
 Total quantity in full tank (16 or 17) 9223345
 Coefficient of expansion for Involved Product 292
 Volume change per °F (25 or 24b) 26831586
 Digits per °F in test Range (23)



NOTES:
 Depth of burial 4 in.
 Tank dia. 64 in.
 Water table 0 in.

The above calculations are to be used for dry soil conditions to establish a positive pressure advantage, or when using the four pound rule to compensate for the presence of subsurface water in the tank area.
 Refer to N.F.P.A. 30, Sections 2-3.2.4 and 2-7.2 and the tank manufacturer regarding allowable system test pressures.

28. DATE (24 hr)	Record details of setting up and running test. (Use full length of line if needed.)	29. Reading No.	30. Standpipe Level in Inches	31. Product in Graduate	32. Product in Graduate	33. Product Replaced (-) / Product Recovered (+)	34. Thermal Sensor Reading	35. Change Higher (+) / Lower (-) (C)	36. Computation (C) * (a) = Expansion (+) / Contraction (-)	37. Temperature Adjustment	38. NET VOLUME CHANGING EACH READING	39. ACCUMULATED CHANGE
	Disconnect Copper product line Plug off to Retest Tank only											
	Fill Legrip Bleedair from System								.0032			
1630	RESTART Circulation	1	4/2		540		4831					
1645	START High Level Test	2	4/2.7	4/2	510	4.030	857	+26	4.083	-.048		
1700		3	4/2.6	4/2	570	4.025	868	+11	4.035	-.010		
1715		4	4/2.6	4/2	595	4.025	884	+16	4.051	-.026		
1730	CHANGE SET Tube Direction	5	4/2.4	4/2	620	4.020	902	+18	4.058	-.038		
1745		6	4/2.4	4/2	640	4.020	917	+15	4.048	-.028		
1800		7										
1802	DRY To Low Level Test	8	13.6	12	660	4.070	929	+12	4.038	4.032		
1815		9	13.0	12	695	4.090	942	+13	4.042	-.002		
1830		10	12.3	12	735	4.015	948	+6	4.019	-.004		
1835	START Low Level Test	11	12.2	12	750	4.010	951	+3	4.010	4.000		-.004
1840		12	12.2	12	750	4.010	955	+4	4.013	-.003		-.007
1845		13	12.2	12	760	4.010	960	+5	4.016	-.006		-.013
1850		14	12.2	12	770	4.010	965	+5	4.016	-.006		-.019
1855		15	12.2	12	780	4.010	970	+5	4.016	-.006		-.025
1900		16	12.2	12	790	4.010	974	+4	4.013	-.003		-.028
1905		17	12.2	12	800	4.010	979	+7	4.022	-.012		-.040
1910		18	12.2	12	810	4.020	981	+5	4.016	-.006		-.046
1915		19	12.2	12	820	4.010	986	+3	4.010	4.000		-.046
1920		20	12.2	12	830	4.010	989	+4	4.013	-.003		-.049
1925		21	12.2	12	840	4.010	993	+5	4.016	-.006		-.055
1930		22	12.2	12	850	4.010	998	+5	4.016	-.006		-.061
1935		23	12.2	12	860	4.010	1003	+5	4.016	-.006		-.061

HOLK ENVIRONMENTAL SERVICES, INC.
 7777 WALL STREET
 VALLEY VIEW, OHIO 44125
 (216) 524-0888

CHAIN OF CUSTODY RECORD

GENERATOR/CUSTOMER <i>R-R INT'L</i>	CONTACT <i>Vince Marek - Nozzle New</i>
ADDRESS <i>1234 S. Cleve-Massillon Rd.</i>	PHONE NUMBER <i>248-5552</i>
CITY, STATE, ZIP <i>Akron Ohio 44321</i>	TITLE <i>OWNER</i>
SAMPLE I.D. <i>UOT Soil Samples</i>	SAMPLED BY <i>BRAD KINSEY</i>
SAMPLING LOCATION <i>RAVENNA ARSENAL</i>	DATE AND TIME <i>2-13-90 11:00 AM TANK#1 SMPS.</i>
SAMPLE DESCRIPTION <i>BROWN SOIL SAMPLES</i>	OF SAMPLING <i>2-14-90 2:00 PM TANK#2-4 smpls</i>
TYPE OF SAMPLE	
<input checked="" type="checkbox"/> COMPOSITE <input checked="" type="checkbox"/> GRAB <input type="checkbox"/> AIR <input type="checkbox"/> OTHER	NUMBER OF CONTAINERS <i>THIRTEEN (13)</i>
<i>1 OF 13 12 OF 13</i>	

SALES CUSTODY

SIGNATURE	SIGNATURE	DATE	TIME
RELINQUISHED BY <i>Brad Kinsey</i>	RECEIVED BY <i>Vince Marek</i>	<i>2/14</i>	<i>4 PM</i>
RELINQUISHED BY <i>Vince Marek</i>	RECEIVED BY <i>Joe O'D</i>	<i>2-15-90</i>	<i>11:30A</i>
RELINQUISHED BY <i>Joe O'D</i>	RECEIVED BY TECH SERVICE	DATE	TIME
RELINQUISHED BY TECH SERVICE	RECEIVED BY <i>J. D. Lynn</i>	<i>2-15-90</i>	<i>12 PM</i>

LABORATORY CUSTODY

RECEIVED FROM SAMPLE ROOM			RETURNED TO SAMPLE ROOM		
ANALYST	DATE	TIME	SUPERVISOR	DATE	TIME
ANALYST	DATE	TIME	SUPERVISOR	DATE	TIME
ANALYST	DATE	TIME	SUPERVISOR	DATE	TIME
ANALYST	DATE	TIME	SUPERVISOR	DATE	TIME
ANALYST	DATE	TIME	SUPERVISOR	DATE	TIME
ANALYST	DATE	TIME	SUPERVISOR	DATE	TIME

ANALYTICAL WORK REQUIRED

Holk I.D. # 39015-1 thru 13
39015-1 COMPOSITE OF TANKS #1-#4
 " -2,3,4 TANK #2: EAST, CENTER, WEST
 " -5,6,7 TANK #3: NORTH, " , SOUTH
 " -8,9,10 TANK #1: N , C , SOUTH
 " -11,12,13 TANK #4: N , C , SOUTH



SAMPLE IDENTIFICATION CORRELATION

<u>LAB SAMPLE I.D.</u>	<u>ACTUAL SAMPLE I.D.</u>
#1	
North	1E
Center	1B
South	1D
#2	
East	2D
Center	2B
West	2F
#3	
North	3A
Center	3B
South	3C
#4	
North	4A
Center	4B
South	4C

HOLK ENVIRONMENTAL SERVICES, INC.

7777 Wall Street
Valley View, Ohio 44125
(216) 524-0888
FAX (216) 524-2090

Date Received: 2-15-90Customer I.D.: Ravenna Arsenal

Nozzle New, Inc.
34412 Pettibone Road
Solon, Ohio 44139
Attn: Mr. Vince Marek

P.O.#: vb. VM/JODate Reported: 2-20-90HOLK-Lab #: B9015-8-13Description: soil samples

<u>Customer I.D.</u>	<u>HOLK-Lab #</u>	<u>TPH</u>
Tank #1 (North)	B9015-8	149 ppm
Tank #1 (Center)	B9015-9	305 ppm
Tank #1 (South)	B9015-10	158 ppm
Tank #4 (North)	B9015-11	37 ppm
Tank #4 (Center)	B9015-12	67 ppm
Tank #4 (South)	B9015-13	394 ppm



Thomas H. Richert
Director of Analytical Services

THR/tlg

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be disposed of after 30 days.

HOLK ENVIRONMENTAL SERVICES, INC.


7777 Wall Street
Valley View, Ohio 44125
(216) 524-0888
FAX (216) 524-2090

Date Received: 2-15-90Customer I.D.: Ravenna Arsenal

Nozzle New, Inc.
34412 Pettibone Road
Solon, Ohio 44139
Attn: Mr. Vince Marek

P.O.#: vb. VM/JODate Reported: 2-20-90HOLK-Lab #: B9015-2-7Description: soil samples

<u>Customer I.D.</u>	<u>HOLK-Lab #</u>	<u>TRH</u>
Tank #2 (East)	B9015-2	22 ppm
Tank #2 (Center)	B9015-3	18 ppm
Tank #2 (West)	B9015-4	17 ppm
Tank #3 (North)	B9015-5	23 ppm
Tank #3 (Center)	B9015-6	18 ppm
Tank #3 (South)	B9015-7	44 ppm



Thomas H. Richert
Director of Analytical Services

THR/tlg

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be disposed of after 30 days.

HOLK ENVIRONMENTAL SERVICES, INC.

7777 Wall Street
Valley View, Ohio 44125
(216) 524-0888
FAX (216) 524-2090

Date Received: 2-15-90

Customer I.D.: Ravenna Arsenal

Nozzle New, Inc.
34412 Pettibone Road
Solon, Ohio 44139
Attn: Mr. Vince Marek

P.O.#: vb. VH/JO

Date Reported: 2-20-90

HOLK-Lab #: B9015-8-13

Description: soil samples

<u>Customer I.D.</u>	<u>HOLK-Lab #</u>	<u>BTEX*</u>
Tank #1 (North)	B9015-8	<2 ppb
Tank #1 (Center)	B9015-9	<2 ppb
Tank #1 (South)	B9015-10	<2 ppb
Tank #4 (North)	B9015-11	<2 ppb
Tank #4 (Center)	B9015-12	<2 ppb
Tank #4 (South)	B9015-13	<2 ppb

* Benzene, Toluene, Ethylbenzene, Xylene.


Thomas H. Richert
Director of Analytical Services

THR/tlg

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be disposed of after 30 days.

HOLK ENVIRONMENTAL SERVICES, INC.

7777 Wall Street
 Valley View, Ohio 44125
 (216) 524-0888
 FAX (216) 524-2090


Date Received: 2-15-90Customer I.D.: Ravenna Arsenal

Nozzle New, Inc.
 34412 Pettibone Road
 Solon, Ohio 44139
 Attn: Mr. Vince Marek

P.O.#: vb. VM/JODate Reported: 2-20-90HOLK-Lab #: B9015-2-7Description: soil samples

<u>Customer I.D.</u>	<u>HOLK-Lab #</u>	<u>BTEX*</u>
Tank #2 (East)	B9015-2	<2 ppb
Tank #2 (Center)	B9015-3	<2 ppb
Tank #2 (West)	B9015-4	<2 ppb
Tank #3 (North)	B9015-5	<2 ppb
Tank #3 (Center)	B9015-6	<2 ppb
Tank #3 (South)	B9015-7	<2 ppb

* Benzene, Toluene, Ethylbenzene, Xylene.


 Thomas H. Richert
 Director of Analytical Services

THR/tlg

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be disposed of after 30 days.

HOLK ENVIRONMENTAL SERVICES, INC.

7777 Wall Street
Valley View, Ohio 44125
(216) 524-0888
FAX (216) 524-2090

Date Received: 2-15-90Customer I.D.: Ravenna Arsenal

Nozzle New, Inc.
34412 Pettibone Road
Solon, Ohio 44139
Attn: Mr. Vince Marek

P.O.#: vb. VM/JODate Reported: 2-20-90HOLK-Lab #: B9015-1Description: Composite ofTanks #1 - #4

Flash Point (FMCC)
Paint Filter Test
TPH


>140 F

No Free Liquid Present

71 ppm

EP TOXIC EXTRACTION PROCEDURE (SW-846; Method 1310)

	Results (mg/l)	EP Tox Standard (mg/l)
Arsenic	<0.01	5.0
Barium	0.09	100.0
Cadmium	<0.01	1.0
Chromium	<0.01	5.0
Lead	<0.01	5.0
Mercury	<0.01	0.2
Selenium	<0.01	1.0
Silver	<0.01	5.0



Thomas H. Richert
Director of Analytical Services

THR/tlg

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be disposed of after 30 days.

HOLK ENVIRONMENTAL SERVICES, INC.


7777 Wall Street
Valley View, Ohio 44125
(216) 524-0888
FAX (216) 524-2090

Date Received: 2-15-90Customer I.D.: Ravenna Arsenal

Nozzle New, Inc.
34412 Pettibone Road
Solon, Ohio 44139
Attn: Mr. Vince Marek

P.O.#: vb, VM/JODate Reported: 2-20-90HOLK-Lab #: B9015-1Description: Composite ofTanks #1 - #4

Benzene	<2 ppb
Toluene	<2 ppb
Ethylbenzene	<2 ppb
Xylene	<2 ppb



Thomas H. Richert
Director of Analytical Services

THR/tlg

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be disposed of after 30 days.



CHAIN OF CUSTODY RECORD

FEB 21 1990

PROJECT NO.: 100214	SITE NAME: RAVENNA ARSENAL		STATION LOCATION	NO. OF CON-TAINERS	FLASHPOINT	E.P. TOXICITY	REMARKS
	STATION NO.	GRAB					
SAMPLERS (SIGNATURE): BRAD KALZY	DATE	TIME	COMP.	GRAB			
	2/7	12:40			X	X	
	2/7			1	X	X	TANK #1 (2000 gal)
	2/7			1	X	X	" #2 (15,000 gal)
	2/7			1	X	X	" #3 "
	2/7			1	X	X	" #4 "
RELINQUISHED BY (SIGNATURE): <i>Kevin Kalk</i>	DATE / TIME	RECEIVED BY (SIGNATURE): <i>Thomas J. Deane</i>	DATE / TIME	RELINQUISHED BY (SIGNATURE): <i>L. M. Williams</i>	DATE / TIME	RECEIVED BY (SIGNATURE):	
RELINQUISHED BY (SIGNATURE):	2/7/90 2:57pm	RECEIVED BY (SIGNATURE):	2-16-90 4:30pm	RELINQUISHED BY (SIGNATURE):		RECEIVED BY (SIGNATURE):	
RELINQUISHED BY (SIGNATURE):		RECEIVED FOR LABORATORY BY (SIGNATURE):		DATE / TIME		REMARKS:	



**CHEMTRON
TECHNICAL SERVICE DIVISION**

Chemtron Corporation
35850 Schneider Court
Avon, Ohio 44011

Cleveland: 216-871-8048
Lorain: 216-937-6348

R & R International, Inc.
1234 S. Cleveland-Massillon Road
P.O. Box 4383
Akron, OH 44321

Attn: Mr. Sam Reed

SITE NAME: Ravenna Arsenal, Project No. 100214

Reference: Partially Completed W.P.S.

The following parameters and detection limits were determined for disposal at Chemtron Corp.

As Received:

pH 10% H ₂ O Extract	7
Color	Dark Brown
Texture	Thick Viscous
Odor	Moderate
Layers	None
Flash Point	185°F
NVM (105°C 24 Hrs.)	18.38%
Ash (900°C to Constant Wt.)	8.65%
BTU	8,070/Lb.
Halogens as Chlorine	.28%
Cyanide (Total)	<1 ppm
Sulfide (Total)	<100 ppm
Density g/cc	Not Applicable

GC Scan for Matrix: Static Pressure/Direct GC Technique

Methanol	<.1%
Ethanol	
Acetone	
Isopropanol	
Tertiary Butanol	
Methyl Ethyl Ketone	
n-Butanol	
Benzene	
Hexane	
Methyl Isobutyl Ketone	<.1%

Date Received: 2-16-90
Date Reported: 2-27-90
Customer ID#: Tank #1 12:40 Sludge
2-7-90 - 2,000 Gals.
PO#: 2616
Lab: A900216-1
Description: Dark Brown Liquid

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be discarded after 30 days. Re-evaluation will be free of charge only if discrepancies exist. Reproduction of this report for other than clients internal use is prohibited without written consent.



R & R International, Inc.

Date Received: _____

Date Reported: _____

Customer ID#: _____

PO#: _____

Lab: A900216-1

Description: _____

GC Scan for Matrix - Cont'd.

Butyl Acetate	<.1%
Toluene	
Xylene	
Cresols	
Cresylic Acid	
Phenols	
Nitrobenzene	
Carbon Disulfide	
Isobutanol	
Pyridine	
2-ethoxy-ethanol	
2-nitropropane	
Methylene Chloride	
1,1,1 Trichloroethane	
Carbon Tetrachloride	
Trichloroethylene	
Tetrachloroethylene	
Chlorobenzene	
1,1,2 Trichloro-1,2,2 Trifluoroethane	
Orthodichlorobenzene	
Trichlorofluoromethane	
1,1,2 Trichloroethane	
Chlorinated Fluorocarbons	<.1%
Diesel Fuel	80.0%
PCB's	<1 ppm



R & R International, Inc.

Date Received: _____

Date Reported: _____

Customer ID#: _____

PO#: _____

Lab: A900216-1

Description: _____

EP Toxic Extraction Procedure (SW-846; Method 1310)

Reported as mg/l

Arsenic	0.02
Barium	1.05
Cadmium	0.03
Chromium	2.26
Lead	0.28
Mercury	<0.01
Selenium	0.01
Silver	<0.01

Robert D. Haddad
Technical Administrator

RDH:lw



CHEMTRON
TECHNICAL SERVICE DIVISION

Chemtron Corporation
 35850 Schneider Court
 Avon, Ohio 44011

Cleveland: 216-871-8048
 Lorain: 216-937-6348

R & R International, Inc.
 1234 S. Cleveland-Massillon Road
 P.O. Box 4383
 Akron, OH 44321

Attn: Mr. Sam Reed

SITE NAME: Ravenna Arsenal, Project No. 100214

Reference: Partially Completed W.P.S.

The following parameters and detection limits were determined for disposal at Chemtron Corp.

As Received:

pH 10% H ₂ O Dispersion	7
Color	Dark Brown - Black
Texture	Thick Viscous
Odor	Moderate
* Layers	See Below
Flash Point	180°F
NVM (105°C 24 Hrs.)	25.37%
Ash (900°C to Constant Wt.)	13.43%
BTU	7,060/Lb.
Halogens as Chlorine	.14%
Cyanide (Total)	<1 ppm
Sulfide (Total)	<100 ppm
Density g/cc	Not Applicable
Layers:	None visible, appears to be emulsions. Sample contains appreciable water.

GC Scan for Matrix: Static Pressure/Direct GC Technique

Methanol	<.1%
Ethanol	
Acetone	
Isopropanol	
Tertiary Butanol	
Methyl Ethyl Ketone	
n-Butanol	
Benzene	
Hexane	
Methyl Isobutyl Ketone	<.1%

Date Received: 2-16-90
 Date Reported: 2-27-90
 Customer ID#: Tank #2
 PO#: 2616
 Lab: A900216-2
 Description: Liquid In Amber Bottle

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be discarded after 30 days. Re-evaluation will be free of charge only if discrepancies exist. Reproduction of this report for other than clients internal use is prohibited without written consent.



R & R International, Inc.

Date Received: _____

Date Reported: _____

Customer ID#: _____

PO#: _____

Lab: A900216-2

Description: _____

GC Scan for Matrix - Cont'd.

Butyl Acetate	<.1%
Toluene	
Xylene	
Cresols	
Cresylic Acid	
Phenols	
Nitrobenzene	
Carbon Disulfide	
Isobutanol	
Pyridine	
2-ethoxy-ethanol	
2-nitropropane	
Methylene Chloride	
1,1,1 Trichloroethane	
Carbon Tetrachloride	
Trichloroethylene	
Tetrachloroethylene	
Chlorobenzene	
1,1,2 Trichloro-1,2,2, Trifluoroethane	
Orthodichlorobenzene	
Trichlorofluoromethane	
1,1,2 Trichloroethane	
Chlorinated Fluorocarbons	<.1%
Diesel Fuel	35.0%
PCB's	<1 ppm



R & R International, Inc.

Date Received: _____

Date Reported: _____

Customer ID#: _____

PO#: _____

Lab: A900216-2

Description: _____

EP Toxic Extraction Procedure (SW-846; Method 1310)

Reported as mg/l

Arsenic	0.05
Barium	0.13
Cadmium	0.02
Chromium	0.04
Lead	2.92
Mercury	<0.01
Selenium	<0.01
Silver	<0.01

Robert D. Haddad
Technical Administrator

RDH:lw



CHEMTRON
TECHNICAL SERVICE DIVISION

Chemtron Corporation
 35850 Schneider Court
 Avon, Ohio 44011

Cleveland: 216-871-8048
 Lorain: 216-937-6348

R & R International, Inc.
 1234 S. Cleveland-Massillon Road
 P.O. Box 4383
 Akron, OH 44321

Attn: Mr. Sam Reed

SITE NAME: Ravenna Arsenal, Project No. 100214

Reference: Partially Completed W.P.S.

The following parameters and detection limits were determined for disposal at Chemtron Corp.

As Received:

pH 10% H ₂ O Extract	5
Color	Brown
Texture	Viscous Liquid
Odor	Moderate
* Layers	See Below
Flash Point	183°F
NVM (105°C 24 Hrs.)	25.57%
Ash (900°C to Constant Wt.)	3.41%
BTU	11,530/Lb.
Halogens as Chlorine	.42%
Cyanide (Total)	<1 ppm
Sulfide (total)	<100 ppm
Density g/cc	Not Applicable

* Layers: None visible, appears to be emulsions. Sample contains appreciable water.

GC Scan for Matrix: Static Pressure/Direct GC Technique

Methanol	<.1%
Ethanol	
Acetone	
Isopropanol	
Tertiary Butanol	
Methyl Ethyl Ketone	
n-Butanol	
Benzene	
Hexane	
Methyl Isobutyl Ketone	<.1%

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be discarded after 30 days. Re-evaluation will be free of charge only if discrepancies exist. Reproduction of this report for other than clients internal use is prohibited without written consent.

Date Received: 2-16-90

Date Reported: 2-17-90

Customer ID#: Tank #3

PO#: 2616

Lab: A900216-3

Description: Liquid In Amber Bottle



R & R International, Inc.

Date Received: _____

Date Reported: _____

Customer ID#: _____

PO#: _____

Lab: A900216-3

Description: _____

GC Scan for Matrix - Cont'd.

Butyl Acetate	<.1%
Toluene	
Xylene	
Cresols	
Cresylic Acid	
Phenols	
Nitrobenzene	
Carbon Disulfide	
Isobutanol	
Pyridine	
2-ethoxy-ethanol	
2-nitropropane	
Methylene Chloride	
1,1,1 Trichloroethane	
Carbon Tetrachloride	
Trichloroethylene	
Tetrachloroethylene	
Chlorobenzene	
1,1,2 Trichloro-1,2,2 Trifluoroethane	
Orthodichlorobenzene	
Trichlorofluoromethane	
1,1,1 Trichloroethane	
Chlorinated Fluorocarbons	<.1%
Diesel Fuel	30.0%

PCB's < 1 ppm

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be discarded after 30 days. Re-evaluation will be free of charge only if discrepancies exist. Reproduction of this report for other than clients internal use is prohibited without written consent.



R & R International, Inc.

Date Received: _____

Date Reported: _____

Customer ID#: _____

PO#: _____

Lab: A900216-3

Description: _____

EP Toxic Extraction Procedure (SW-846; Method 1310)

Reported as mg/l

Arsenic	0.07
Barium	0.10
Cadmium	<0.01
Chromium	0.02
Lead	0.19
Mercury	<0.01
Selenium	<0.01
Silver	<0.01

Robert D. Haddad
Technical Administrator

RDH:lw



CHEMTRON
TECHNICAL SERVICE DIVISION

Chemtron Corporation
 35850 Schneider Court
 Avon, Ohio 44011

Cleveland: 216-871-8048
 Lorain: 216-937-6348

R & R International, Inc.
 1234 S. Cleveland-Massillon Road
 P.O. Box 4383
 Akron, OH 44321

Attn: Mr. Sam Reed

SITE NAME: Ravenna Arsenal, Project No. 100214

Reference: Partially Completed W.P.S.

The following parameters and detection limits were determined for disposal at Chemtron Corp.

As Received:

pH 10% H ₂ O Extract	6
Color	Dark Brown
Texture	Viscous Liquid
Odor	Moderate
* Layers	See Below
Flash Point	>200°F
NVM (105°C 24 Hrs.)	21.64%
Ash (900°C to Constant Wt.)	5.26%
BTU	9,870/Lb.
Halogens as Chlorine	.28%
Cyanide (Total)	<1 ppm
Sulfide (total)	<100 ppm
Density g/cc	Not Applicable

* Layers: None visible, appears to be emulsions. Sample contained appreciable water.

GC Scan for Matrix: Static Pressure/Direct GC Technique

Methanol	<.1%	
Ethanol		
Acetone		
Isopropanol		
Tertiary Butanol		
Methyl Ethyl Ketone		
n-Butanol		
Benzene		
Hexane		<.1%

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be discarded after 30 days. Re-evaluation will be free of charge only if discrepancies exist. Reproduction of this report for other than clients internal use is prohibited without written consent.

Date Received: 2-16-90
 Date Reported: 2-27-90
 Customer ID#: Tank #4
 PO#: 2616
 Lab: A900216-4
 Description: Liquid In Amber Bottle



R & R International, Inc.

Date Received: _____

Date Reported: _____

Customer ID#: _____

PO#: _____

Lab: A900216-4

Description: _____

GC Scan for Matrix - Cont'd.

Methyl Isobutyl Ketone	<.1%
Butyl Acetate	
Toluene	
Xylene	
Cresols	
Cresylic Acid	
Phenols	
Nitrobenzene	
Carbon Disulfide	
Isobutanol	
Pyridine	
2-ethoxy-ethanol	
2-nitropropane	
Methylene Chloride	
1,1,1 Trichloroethane	
Carbon Tetrachloride	
Trichloroethylene	
Tetrachloroethylene	
Chlorobenzene	
1,1,2 Trichloro-1,2,2 Trifluoroethane	
Orthodichlorobenzene	
Trichlorofluoromethane	
1,1,2 Trichloroethane	
Chlorinated Fluorocarbons	<.1%
Diesel Fuel	21.0%
PCB's	<1 ppm



R & R International, Inc.

Date Received: _____

Date Reported: _____

Customer ID#: _____

PO#: _____

Lab: A900216-4

Description: _____


EP Toxic Extraction Procedure (SW-846; Method 1310)

Reported as mg/l

Arsenic	0.04
Barium	0.26
Cadmium	<0.01
Chromium	0.02
Lead	0.07
Mercury	<0.01
Selenium	<0.01
Silver	<0.01

Robert D. Haddad
Technical Administrator

RDH:lw



RECEIVED

APR 12 1990

holub iron & steel co., inc.

470 NORTH ARLINGTON STREET/AKRON, OHIO 44305/216-253-3165

April 5, 1990

R & R International
1234 South Cleveland-Massillon Road
Akron, Ohio 44231

Dear Sir:

On February 13 and 14, 1990 R & R International delivered three(3) clean 15,000 gallon underground storage tanks to the Holub Iron & Steel Company, 470 N. Arlington Street Akron, Ohio for scrap.

On the same two (2) days above mentioned tanks were cut into 2'x5' scrap material.

Sincerely,

THE HOLUB IRON & STEEL COMPANY

Calvin Cartier
Supervisor

CC:cf

E. 79th Scrap & Auto Wrecking

Cutting & Disposing

3205 E. 79th Street Cleveland, Ohio

Received 1-2,000 gallon steel oil storage
tank for R & R International from Ravenna
Arsenal. Cut up and scrap.

Jack Fox



RAVENNA ARSENAL, INC.
8451 STATE ROUTE 5, RAVENNA, OHIO 44266-9297
TELEPHONE: (216) 358-7111 • FAX: (216) 297-3216

March 29, 1990

THRU: Contracting Officer's Representative
Ravenna Army Ammunition Plant
8451 State Route 5
Ravenna, Ohio 44266-9297

TO: Commander
U.S. Army Armament, Munitions and Chemical Command
ATTN: AMSMC-ISE (Mr. Cyril Onewokae)
Rock Island, IL 61299-6000

Subject: Underground Storage Tanks Progress Report

Dear Sir:

Of the 17 registered underground storage tanks at Ravenna Army Ammunition Plant, nine were declared abandoned and were designated for removal. The remaining tanks were tested for tightness in accordance with regulatory requirements in January, 1990. Test results indicated three of the eight were leaking. The three leaking tanks were immediately emptied and designated for removal; the non-leaking tanks remain in service.

FY89 Environmental Restoration Project 5892910-007 (CLIN 46AD, MOD 88) provided \$186,100 for the removal of 12 underground storage tanks (including the nine abandoned registered tanks) at Ravenna AAP. FY90 Environmental Restoration Project 5902910-04 (CLIN 46AE, MOD92) provided \$94,000 to remove four underground storage tanks (including the three registered tanks) which were found to be leaking by tank tightness tests.

All tanks on both projects have been removed, cleaned, and disposed. All contaminated soil with the exception of Tank No. 10 at the Charlestown Gate has been excavated and the confirmatory soil analysis from the walls of the excavations appear to be acceptable based on comments from the State Fire Marshal's Office. The State Fire Marshal's Office has not formally accepted the tank removals yet so there is a remote chance that additional work may be required.

Tank No. 10 soil analysis indicated the hole is still contaminated with the contamination extending under a large floor slab and foundation of the old gate house. In order to determine the limits of the contamination and to remove the contaminated soil, it is necessary to remove the concrete. A request for additional funding to complete this project was submitted to AMSMC-PCG-B on March 26, 1990.

Point of contact concerning this subject at this installation is Susan McCauslin, AV346-3220.

Sincerely,

RAVENNA ARSENAL, INC.



H.R. Cooper
Plant Engineer

HRC/SM/ade/90009


cc: N. Wulff
W. Carkido
T. Chanda
S. McCauslin
File

7 FEB 1990

AMSMC-ISE
SUBJECT: Underground Storage Tanks (USTs)

6. The point of contact for this action is Mr. Cyril Onewokae, AMSMC-ISE-E, AUTOVON 793-1350.

FOR THE COMMANDER:



RONALD T. SHINBORI
Chief, Environmental Quality Div

DISTRIBUTION:

Commander, Holston Army Ammunition Plant, ATTN: SMCHO-EN, Kingsport,
TN 37660-9982

Commander, Kansas Army Ammunition Plant, ATTN: SMCKA-OR, Parsons,
KS 67357-9107

Commander, Louisiana Army Ammunition Plant, ATTN: SMCLA-SF, P.O. Box 30058,
Shreveport, LA 71130-0058

Commander, Newport Army Ammunition Plant, ATTN: SMCNE-EN, Newport,
IN 47966-0121

Commander, Pine Bluff Arsenal, ATTN: SMCPB-EM, Pine Bluff, AR 71602-9500

Commander, Sunflower Army Ammunition Plant, ATTN: SMCSU-EV, P.O. Box 640,
DeSoto, KS 66018-0640

Commander's Representative, Alabama Army Ammunition Plant, ATTN: SMCAL,
110 Highway No. 235, Childersburg, AL 35044-1021

Commander's Representative, Joliet Army Ammunition Plant, ATTN: SMCJO-EN,
Joliet, IL 60436-5000

✓ Commander's Representative, Ravenna Army Ammunition Plant, ATTN: SMCRV,
8451 State Route 5, Ravenna, OH 44266-9297



RAVENNA ARSENAL INC.

8451 STATE ROUTE 5
RAVENNA, OHIO 44266-9297

Telephone (216) 358-7111

Autovon 346-3210

March 19, 1990

THRU: Contracting Officer's Representative
Ravenna Army Ammunition Plant
8451 State Route 5
Ravenna, Ohio 44266-9297

TO: Ohio Department of Commerce - Division of State Fire Marshal
Bureau of Underground Storage Tank Regulations
ATTN: Michelle Tarka, Site Coordinator
7510 East Main Street
P.O. Box 525
Reynoldsburg, Ohio 43068-3395

Subject: Incident 679298-02, RVAAP Tank #11, Total Lead Results

Dear Ms. Tarka:

As a follow up to our February 23, 1990 site investigation report for leaking underground storage tanks enclosed you will find total lead results for samples taken in the excavated tank pit RV11 after tank removal.

This submission will complete our Site Investigation Report for the subject incident. Please feel free to contact Susan McCauslin, Environmental Specialist at (216) 297-3220 if you have any questions or require further information regarding this subject.

Sincerely,

Ravenna Arsenal, Inc.

H.R. Cooper
Plant Engineer

HRC:SM:ade:90005

cc: N. Wulff
W. Carkido
S. McCauslin
File

cf: Commander
AMCCOM
AMSMC-ISE

HOLK ENVIRONMENTAL SERVICES, INC.

7777 Wall Street
 Valley View, Ohio 44125
 (216) 524-0888
 FAX (216) 524-2090

Date Received: 2/15/90
 Date Reported: 3/14/90

Client Sample I.D.: Ravenna Arsenal
 HOLK Sample I.D.: B9015-2-8,10-11
 Sampled By: Client
 P.O.#: vb. VM/JO
 Sample Description: brown soils

Nozzle New, Inc.
 34412 Pettibone Road
 Solon, Ohio 44139

CLIENT SAMPLE I.D.	HOLK SAMPLE I.D.	TOTAL LEAD (ppm)	REAGENT BLANK (mg/l)	STANDARD RECOVERY (%)
RV #11 Tank #2 East	B9015-2	6.74	<0.01	101
Tank #2 Center	B9015-3	5.69	<0.01	101
Tank #2 West	B9015-4	5.84	<0.01	101
RV #22 Tank #3 North	B9015-5	3.47	<0.01	101
Tank #3 Center	B9015-6	2.62	<0.01	101
Tank #3 South	B9015-7	2.92	<0.01	101
RV #33 Tank #1 North	B9015-8	15.0	<0.01	101
Tank #1 South	B9015-10	10.8	<0.01	101
RV #23 Tank #4 North	B9015-11	37.0	<0.01	86
Tank #4 Center	B9015-12	23.4	<0.01	86
Tank #4 South	B9015-13	28.1	<0.01	86

Ronald A. Baraona
 Ronald A. Baraona
 LABORATORY MANAGER

RAB/tig

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be disposed of after 30 days.



RAVENNA ARSENAL INC.

8451 STATE ROUTE 5
RAVENNA, OHIO 44266-9297

Telephone (216) 358-7111

Autovon 346-3210

March 19, 1990

THRU: Contracting Officer's Representative
Ravenna Army Ammunition Plant
8451 State Route 5
Ravenna, Ohio 44266-9297

TO: Ohio Department of Commerce - Division of State Fire Marshal
Bureau of Underground Storage Tank Regulations
ATTN: Michelle Tarka, Site Coordinator
7510 East Main Street
P.O. Box 525
Reynoldsburg, Ohio 43068-3395

Subject: Incident 679298-00, RVAAP Tank #23, Total Lead Results

Dear Ms. Tarka:

As a follow up to our February 23, 1990 site investigation report for leaking underground storage tanks enclosed you will find total lead results for samples taken in the excavated tank pit RV23 after tank removal.

This submission will complete our Site Investigation Report for the subject incident. Please feel free to contact Susan McCauslin, Environmental Specialist at (216) 297-3220 if you have any questions or require further information regarding this subject.

Sincerely,

Ravenna Arsenal, Inc.

H.R. Cooper

H.R. Cooper
Plant Engineer

HRC:SM:ade:90005

cc: N. Wulff
W. Carkido
S. McCauslin
File

cf: Commander
AMCCOM
AMSMC-ISE

HOLK ENVIRONMENTAL SERVICES, INC.

7777 Wall Street
 Valley View, Ohio 44125
 (216) 524-0888
 FAX (216) 524-2090

Date Received: 2/15/90
 Date Reported: 3/14/90

Client Sample I.D.: Ravenna Arsenal
 HOLK Sample I.D.: B9015-2-8,10-13
 Sampled By: Client
 P.O.#: vb. VM/JO
 Sample Description: brown soils

Nozzle New, Inc.
 34412 Pettibone Road
 Solon, Ohio 44139

CLIENT SAMPLE I.D.	HOLK SAMPLE I.D.	TOTAL LEAD (ppm)	REAGENT BLANK (mg/l)	STANDARD RECOVERY (%)
RU #11 Tank #2 East	B9015-2	6.74	<0.01	101
Tank #2 Center	B9015-3	5.69	<0.01	101
Tank #2 West	B9015-4	5.84	<0.01	101
RU #22 Tank #3 North	B9015-5	3.47	<0.01	101
Tank #3 Center	B9015-6	2.62	<0.01	101
Tank #3 South	B9015-7	2.92	<0.01	101
RU #33 Tank #1 North	B9015-8	15.0	<0.01	101
Tank #1 South	B9015-10	10.8	<0.01	101
RU #23 Tank #4 North	B9015-11	37.0	<0.01	86
Tank #4 Center	B9015-12	23.4	<0.01	86
Tank #4 South	B9015-13	28.1	<0.01	86

Ronald A. Baraona
 Ronald A. Baraona
 LABORATORY MANAGER

RAB/tlg

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be disposed of after 30 days.



RAVENNA ARSENAL INC.

8451 STATE ROUTE 5
RAVENNA, OHIO 44266-9297

Telephone (216) 358-7111

Autovon 346-3210

March 19, 1990

THRU: Contracting Officer's Representative
Ravenna Army Ammunition Plant
8451 State Route 5
Ravenna, Ohio 44266-9297

TO: Ohio Department of Commerce - Division of State Fire Marshal
Bureau of Underground Storage Tank Regulations
ATTN: Michelle Tarka, Site Coordinator
7510 East Main Street
P.O. Box 525
Reynoldsburg, Ohio 43068-3395

Subject: Incident 679298-01, RVAAP Tank #33, Total Lead Results

Dear Ms. Tarka:

As a follow up to our February 23, 1990 site investigation report for leaking underground storage tanks enclosed you will find total lead results for samples taken in the excavated tank pit RV33 after tank removal.

This submission will complete our Site Investigation Report for the subject incident. Please feel free to contact Susan McCauslin, Environmental Specialist at (216)297-3220 if you have any questions or require further information regarding this subject.

Sincerely,

Ravenna Arsenal, Inc.

H.R. Cooper
H.R. Cooper
Plant Engineer

HRC:SM:ade:90005

cc: N. Wulff
W. Carkido
S. McCauslin
File

cf: Commander
AMCCOM
AMSMC-ISE

HOLK ENVIRONMENTAL SERVICES, INC.

7777 Wall Street
Valley View, Ohio 44125
(216) 524-0888
FAX (216) 524-2090

Date Received: 2/15/90
Date Reported: 3/14/90

Nozzle New, Inc.
34412 Pettibone Road
Solon, Ohio 44139

Client Sample I.D.: Ravenna
Arsenal
HOLK Sample I.D.: B9015-2-8,10-13
Sampled By: Client
P.O.#: vb. VM/JO
Sample Description: brown soils

CLIENT SAMPLE I.D.	HOLK SAMPLE I.D.	TOTAL LEAD (ppm)	REAGENT BLANK (mg/l)	STANDARD RECOVERY (%)
RV #11 Tank #2 East	B9015-2	6.74	<0.01	101
Tank #2 Center	B9015-3	5.69	<0.01	101
Tank #2 West	B9015-4	5.84	<0.01	101
RV #22 Tank #3 North	B9015-5	3.47	<0.01	101
Tank #3 Center	B9015-6	2.62	<0.01	101
Tank #3 South	B9015-7	2.92	<0.01	101
RV #33 Tank #1 North	B9015-8	15.0	<0.01	101
Tank #1 South	B9015-10	10.8	<0.01	101
RV #23 Tank #4 North	B9015-11	37.0	<0.01	86
Tank #4 Center	B9015-12	23.4	<0.01	86
Tank #4 South	B9015-13	28.1	<0.01	86

Ronald A. Baraona
Ronald A. Baraona
LABORATORY MANAGER

RAB/tig

The foregoing is limited to findings based upon material received & analysis and/or information furnished by client. Samples received will be disposed of after 30 days.

HOLLAND ENVIRONMENTAL SERVICES, INC.

7 Wall Street
 Valley View, Ohio 44125
 (216) 524-0888
 (216) 524-2090

Date Received: 2/15/90
 Date Reported: 3/14/90

Client Sample I.D.: Ravenna Arsenal
 HOLC Sample I.D.: B9015-2-8,10-13
 Sampled By: Client
 P.O.#: vb. VM/JO
 Sample Description: brown soils

HOLLAND New, Inc.
 34412 Pettibone Road
 Solon, Ohio 44139

CLIENT SAMPLE I.D.	HOLC SAMPLE I.D.	TOTAL LEAD (ppm)	REAGENT BLANK (mg/l)	STANDARD RECOVERY (%)
RV #11 Tank #2 East	B9015-2	6.74	<0.01	101
Tank #2 Center	B9015-3	5.69	<0.01	101
Tank #2 West	B9015-4	5.84	<0.01	101
RV #22 Tank #3 North	B9015-5	3.47	<0.01	101
Tank #3 Center	B9015-6	2.62	<0.01	101
Tank #3 South	B9015-7	2.92	<0.01	101
RV #33 Tank #1 North	B9015-8	15.0	<0.01	101
Tank #1 South	B9015-10	10.8	<0.01	101
RV #23 Tank #4 North	B9015-11	37.0	<0.01	86
Tank #4 Center	B9015-12	23.4	<0.01	86
Tank #4 South	B9015-13	28.1	<0.01	86

Ronald A. Baraona
 Ronald A. Baraona
 LABORATORY MANAGER

RAB/tig

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be disposed of after 30 days.

HOLK ENVIRONMENTAL SERVICES, INC.

7777 Wall Street
Valley View, Ohio 44125
(216) 524-0888
FAX (216) 524-2090


Date Received: 3-5-90Customer I.D.: Rayenna Arsenal
Tank #1 Center

Nozzle New, Inc.
34412 Pettibone Road
Solon, Ohio 44139
Attn: Mr. Vince Marek

P.O.#: vb. VM/JODate Reported: 3-6-90HOLK-Lab #: B9015-9Description: soil sample

Lead (Total)

5.02 ppm



Ronald A. Baraona
LABORATORY MANAGER

RAB/tlg

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be disposed of after 30 days.

IMPORTANT FAX INFORMATION



1234 S. Cleveland-Massillon Rd.
Akron, Ohio 44321
(216) 666-2200
FAX: (216) 666-7374

Please deliver immediately to: SUSAN M.

Company: RAVENNA ARSENAL

Fax #: 1-297-3216

Reference: LEAD TEST RESULT

Response Requested:	Y <input type="checkbox"/>	N <input checked="" type="checkbox"/>
Hardcopy to follow by mail:	Y <input checked="" type="checkbox"/>	N <input type="checkbox"/>

No. of pages (including cover sheet): 2 Date: 9 MARCH 1990

Please contact _____ if all pages not received.

Comments: SUSAN

THIS IS THE ONLY SAMPLE WE HAD TESTED.
IF YOU NEED MORE, LET ME KNOW

For Inter Use Only: _____

B. J. JENKINS
MAR 9 1990

Signed By:
SAM REED

Rev 3/9/89

Form 585

*Notified Sam Reed that specification requires additional sample.
R+R has material; will sample; results first of the week. 3/12/90.*

*B. Jenkins
3/9/90*

IMPORTANT FAX INFORMATION



1234 S. Cleveland-Massillon Rd.
Akron, Ohio 44321
(216) 666-2200
FAX: (216) 666-7874

Please deliver immediately to: SUSAN M.

Company: RAVENNA ARSENAL

Fax #: 1-297-3216

Reference: SLUDGE DISPOSAL

Response Requested:	Y <input checked="" type="checkbox"/>	N <input type="checkbox"/>
Hardcopy to follow by mail:	Y <input type="checkbox"/>	N <input checked="" type="checkbox"/>

No. of pages (including cover sheet): 14 Date: 8 MARCH 1990

Please contact MARY if all pages not received.

Comments: SUSAN,
LET ME KNOW A.S.A.P. IF THE ENCLOSED
WASTE PROFILE FORM IS ACCEPTABLE TO YOU. ALSO,
FOR ITEM "G", I WILL NEED THE DOT SHIPPING
DESCRIPTION.

For Internal Use Only:

Signed By:

SAM REED

Rev 3/9/89

Form 585



CHEMTRON CORPORATION

WASTE PROFILE DATA FORM

WASTE PROFILE NO

Q

A GENERATOR NAME: Ravenna Army Ammunition Plant B GENERATOR EPA ID NO: OH 5210020736
 C FACILITY ADDRESS: 8451 State Route 5 - Ravenna STATE: OH ZIP: 44266-9297
 BILLING ADDRESS: 1234 S. Cleveland-Massillon Rd. - Akron STATE: OH ZIP: 44321
 D BUSINESS CONTACT: Mr. Bill Jenkins TITLE: Purchasing Manager PHONE: (216) 297-3107
 E TECHNICAL CONTACT: Mr. Wayne Carkido TITLE: Project Engineer PHONE: (216) 297-3237

F GENERATOR'S COMMON NAME FOR THE WASTE: Diesel Fuel EPA HAZARDOUS WASTE NUMBER(S): D001

G DOT SHIPPING DESCRIPTION: Fuel Oil, ~~no. 2~~ DOT HAZARDOUS CLASS: Combustible Liquid UN/NA: 1993

H PROCESS GENERATING WASTE: Sludges from tank cleaning operations

I ANNUAL QUANTITY: 22 UNIT OF MEASURE: _____ WILL BE SHIPPED PER
 WEEK MONTH QUARTER YEAR ONE TIME OTHER. Specify: _____

J CHEMICAL COMPOSITION

CONSTITUENT	ANALYSIS (%)	RANGE (%)
WATER	30	
Diesel	30	
Dirt, Grease & Oil	40	

K PHYSICAL PROPERTIES

COLOR: Brown to Black DOOR: NONE STRONG MILD
 DESCRIBE: _____
 PHYSICAL STATE AT 70°F:
 SOLID LIQUID SEMI-SOLID POWDER
 PHASE LAYERING:
 NONE BILAYERED MULTILAYERED
 pH: 0 2-4 7-9 > 12.5 N/A
 < 2 4-7 9-12.5 EXACT
 FLASH POINT: < 70°F 70°F-100°F 101°F-140°F NO FLASH
 EXACT
 CLOSED CUP OPEN CUP
 SPECIFIC GRAVITY:
 1.1-1.2 1.13-1.4 > 1.5 1.8-2.0
 1.5-1.8 > 1.8
 HAZARDOUS CHARACTERISTICS
 REACTIVITY: NONE PYROPHORIC SHOCK SENSITIVE
 EXPLOSIVE WATER REACTIVE OTHER: _____
 SOLIDS: _____ BY WEIGHT 30-502 BY VOLUME
 BTU/GAL _____ BTU/LB 7060

INORGANIC METALS

Extraction Procedure (mg/l) Total (ppm)
 BARIUM: 1.05 mg/l SILVER: <0.01 mg/l
 CADMIUM: 0.03 mg/l ALUMINUM: _____
 CHROMIUM: 2.26 mg/l BERYLLIUM: _____
 COPPER: _____
 MANGANESE: <0.01 mg/l NICKEL: _____
 MERCURY: 2.92 mg/l ZINC: _____
 THALLIUM: _____

NON METALS

Extraction Procedure (mg/l) Total (ppm)
 ARSENIC: 0.07 mg/l TOTAL PHOSPHOROUS: _____
 HALOGENS AS CHLORINE: 0.42% TOTAL SULFUR: _____
 FLUORINE: _____ SULFIDES: <100 ppm
 CYANIDE: <1 ppm NITRATES: _____

L Does the waste contain any of the following:
 Halogenated Aromatics (e.g. PCB, PBB); Aromatic Amines; Peroxides; Gases;
 Thioureas, Cyclic Nitrogen (e.g. Pyridine); Phenols; Quinones; Phosphorus
 Compounds; Polycyclic Organics; Asbestos; Radioactive Material; Biological
 Materials; Infectious Agents.
 YES NO

If YES Attach Detailed Analysis

M Special Handling Procedures: _____

I hereby certify that I have personally examined and am familiar with the information submitted in this and all attached documents. Based upon my inquiry of those individuals immediately responsible for obtaining the information, I believe that the submitted information is true, accurate and complete to the best of my knowledge and that all known and suspected hazards have been disclosed in accordance with 40 CFR 261.

SIGNATURE

TITLE

DATE

WHITE/OFFICE

YELLOW/CUSTOMER

PINK/LAB

GOLD/CUSTOMER ACCEPTANCE COPY



CHEMTRON
TECHNICAL SERVICE DIVISION

10000 W. 130th St.
Overland Park, MO 66204
913-641-1400

10000 W. 130th St.
Overland Park, MO 66204

Date Received: 2-16-90
Date Reported: 2-27-90
Customer ID#: Tank #1 12:40 Sludge
2-7-90 - 2,000 Gal.
PO#: 2616
Lab: A900216-1
Description: Dark Brown Liquid

R & R International, Inc.
1234 S. Cleveland-Massillon Road
P.O. Box 4383
Akron, OH 44321

Attn: Mr. Sam Reed

SITE NAME: Ravenna Arsenal, Project No. 100214

Reference: Partially Completed W.P.S.

The following parameters and detection limits were determined for disposal at Chemtron Corp.

As Received:

pH 10% H ₂ O Extract	7
Color	Dark Brown
Texture	Thick Viscous
Odor	Moderate
Layers	None
Flash Point	185°F
NVM (105°C 24 Hrs.)	18.38%
Ash (900°C to Constant Wt.)	8.65%
BTU	8,070/Lb.
Halogens as Chlorine	.28%
Cyanide (Total)	<1 ppm
Sulfide (Total)	<100 ppm
Density g/cc	Not Applicable

GC Scan for Matrix: Static Pressure/Direct GC Technique

- Methanol
- Ethanol
- Acetone
- Isopropanol
- Tertiary Butanol
- Methyl Ethyl Ketone
- n-Butanol
- Benzene
- Hexane
- Methyl Isobutyl Ketone



This report is the property of Chemtron Corp. and contains information furnished by client. Samples received will be discarded after 30 days. Recirculation of this report is prohibited without written consent.



R & K International, Inc.

Date Received: _____
 Date Reported: _____
 Customer ID#: _____
 PO#: _____
 Lab: A900216-1
 Description: _____

GC Scan for Matrix - Cont'd.

- Butyl Acetate
- Toluene
- Xylene
- Cresols
- Cresol Acid
- Phenols
- Nitrobenzene
- Carbon Disulfide
- Isobutanol
- Pyridine
- 2-ethoxy-ethanol
- 2-nitropropane
- Methylene Chloride
- 1,1,1 Trichloroethane
- Carbon Tetrachloride
- Trichloroethylene
- Tetrachloroethylene
- Chlorobenzene
- 1,1,2 Trichloro-1,2,2 Trifluoroethane
- Orthodichlorobenzene
- Trichlorofluoromethane
- 1,1,2 Trichloroethane
- Chlorinated Fluorocarbons
- Diesel Fuel

<.1%
 <.1%
 80.0%
 <1 ppm

PCB's

This report was prepared by the laboratory of R & K International, Inc. The information furnished by clients is not to be used for any other purpose without written consent. Samples received will be discarded after 30 days. An amount of 10% of the total sample weight is retained for 90 days. All other samples are destroyed without return.



R & E International, Inc.

Date Received: _____
 Date Reported: _____
 Customer ID#: _____
 PO#: _____
 Lab: A900216-1
 Description: _____

EP Toxic Extraction Procedure (SW-846; Method 1310)

Reported as mg/l

Arsenic	0.02
Barium	1.05
Cadmium	0.05
Chromium	<u>2.26</u>
Lead	<u>0.28</u>
Mercury	<0.01
Selenium	0.01
Silver	<0.01

Robert D. Haddad
 Robert D. Haddad
 Technical Administrator

RPH:lw



CHEMTRON
TECHNICAL SERVICE DIVISION

Chemtron Corp.
10000
Akron, OH 44316

Chemtron Corp.
10000

Date Received: 2-16-90
Date Reported: 2-27-90
Customer ID#: Tank #2
PO#: 2616
Lab: A800216-2
Description: Liquid In Amber Bottle

R & R International, Inc.
1234 S. Cleveland-Massillon Road
P.O. Box 4383
Akron, OH 44321

Attn: Mr. Sam Reed

SITE NAME: Ravenna Arsenal, Project No. 100214

Reference: Partially Completed W.P.S.

The following parameters and detection limits were determined for disposal at Chemtron Corp.

As Received:

pH 10% H ₂ O Dispersion	7
Color	Dark Brown - Black
Texture	Thick Viscous
Odor	Moderate
* Layers	See Below
Flash Point	180°F
NVM (105°C 24 Hrs.)	25.37%
Ash (900°C to Constant Wt)	13.43%
BTU	7,060/lb.
Halogens as Chlorine	.14%
Cyanide (Total)	<1 ppm
Sulfide (Total)	<100 ppm
Density g/cc	Not Applicable
Layers:	None visible, appears to be emulsions. Sample contains appreciable water.

GC Scan for Matrix: Static Pressure/Direct GC Technique

Methanol
Ethanol
Acetone
Isopropanol
Tertiary Butanol
Methyl Ethyl Ketone
n-Butanol
Benzene
Hexane
Methyl Isobutyl Ketone



Chemtron Corp. is not responsible for the analysis and/or information furnished by others. Samples received will be disposed after analysis. Re-evaluation will be made if necessary. Reproduction of this report for other than client's internal use is prohibited without written consent.



R & R International, Inc.

Date Received: _____
 Date Reported: _____
 Customer ID#: _____
 PO#: _____
 Lab: A900216-2
 Description: _____

GC Scan for Matrix - Cont'd.

Butyl Acetate	<.1%
Toluene	
Xylene	
Cresols	
Cresylic Acid	
Phenols	
Nitrobenzene	
Carbon Disulfide	
Isobutanol	
Pyridine	
2-nitroxy-ethanol	
2-nitropropane	
Methylene Chloride	
1,1,1 Trichloroethane	
Carbon Tetrachloride	
Trichloroethylene	
Tetrachloroethylene	
Chlorobenzene	
1,1,2 Trichloro-1,2,2, Trifluoroethane	
Orthodichlorobenzene	
Trichlorofluoromethane	
1,1,2 Trichloroethane	
Chlorinated Fluorocarbons	<.1%
Diesel Fuel	35.0%
PM10	<1 ppm

Chemtron Corporation, 10000 West 10th Avenue, Denver, CO 80231. All rights reserved. This report is the property of Chemtron Corporation and is not to be distributed outside of your company. Samples received will be analyzed within 30 days. The expiration date of the report is 90 days from the date of analysis. If you have any questions, please contact your account manager or call 1-800-451-7777.



R & R International, Inc.

Date Received: _____
 Date Reported: _____
 Customer ID#: _____
 PO#: _____
 Lab: A900216-2
 Description: _____

HP Toxic Extraction Procedure (SW-846; Method 1310)

Reported as mg/l

Arsenic	0.03
Barium	0.13
Cadmium	0.02
Chromium	0.04
Lead	2.92
Mercury	<0.01
Selenium	<0.01
Silver	<0.01

Robert D. Haddad
Technical Administrator

RDH:lw



CHEMTRON
TECHNICAL SERVICE DIVISION

10000
10000
10000

10000
10000

R & R International, Inc.
1234 S. Cleveland-Massillon Road
P.O. Box 4567
Akron, OH 44321

Attn: Mr. Dan Reed

SITE NAME: Ravenna Arsenal, Project No. 100214

Reference: Partially Completed W.P.S.

Date Received: 2-16-90
Date Reported: 2-17-90
Customer ID#: Tank #3
PO#: 2616
Lab: A900216-3
Description: Liquid In Amber Bottle

The following parameters and detection limits were determined for disposal at Chemtron Corp.

As Received:

pH 10% H ₂ O Extract	5
Color	Brown
Texture	Viscous Liquid
Odor	Moderate
* Layers	See Below
Flash Point	163°F
NVM (105°C 24 Hrs.)	25.57%
Ash (900°C to Constant Wt.)	3.41%
BTI	11,530/lb.
Halogens as Chlorine	.42%
Cyanide (Total)	<1 ppm
Sulfide (total)	<100 ppm
Density 20°C	Not Applicable

* Layers: None visible, appears to be emulsions. Sample contains appreciable water.

GC Scan for Matrix: Static Pressure/Direct GC Technique

Methanol	<.1%
Ethanol	
Acetone	
Isopropanol	
Tertiary Butanol	
Methyl Ethyl Ketone	
n-Butanol	
Benzene	
Hexane	
Methyl Isobutyl Ketone	<.1%

Chemtron Corp. is not responsible for any analysis of data information furnished by client. Sample received will be analyzed as requested. Reproduction of this report for use by other clients is prohibited without written consent.



R & R International, Inc.

Date Received: _____
 Date Reported: _____
 Customer ID#: _____
 PO#: _____
 Lab: A900216-3
 Description: _____

GC Scan for Matrix - Coptid.

Butyl Acetate	<.1%
Toluene	
Xylene	
Cresols	
Crotylic Acid	
Phenol	
Nitrobenzene	
Carbon Disulfide	
Isobutanol	
Pyridine	
2-ethoxy-ethanol	
2-nitropropane	
Methylene Chloride	
1,1,1 Trichloroethane	
Carbon Tetrachloride	
Trichloroethylene	
Tetrachloroethylene	
Chlorobenzene	
1,1,2 Trichloro-1,2,2 Trifluoroethane	
Orthodichlorobenzene	
Trichlorofluoromethane	
1,1,1 Trichloroethane	
Chlorinated Fluorocarbons	<.1%
Diesel Fuel	30.0%
PCIV's	< 1 ppm

This report is the property of Chemtron Corp. and is loaned to your organization. It is to be used for the purpose stated only. Samples received will be analyzed after 30 days. No explanation will be given for results that are abnormal unless a plus flag is noted within written contract.




R & K International, Inc.

Date Received: _____
 Date Reported: _____
 Customer ID#: _____
 PO#: _____
 Lab A900216-3
 Description: _____

EP Toxic Extraction Procedure (SW-846; Method 1310)

Reported as mg/l

Arsenic	0.07
Barium	0.10
Cadmium	<0.01
Chromium	0.02
Lead	0.19
Mercury	<0.01
Selenium	<0.01
Silver	<0.01


 Robert D. Hindad
 Technical Administrator

KDH:ls

This report was prepared by R & K International, Inc. based on data furnished by the client. Samples received will be discarded after six days. No liability is assumed for errors in analysis or for any other cause. R & K International, Inc. is not responsible for any errors in analysis or for any other cause.



CHEMTRON
TECHNICAL SERVICE DIVISION

Chemtron Corp.
1234 S. Cleveland-Massillon Road
Akron, OH 44321

Phone: (216) 333-1111
Fax: (216) 333-1112

Date Received: 2-16-90
Date Reported: 2-27-90
Customer ID#: Tank #4
PO#: 2616
Lab: A900216-4
Description: Liquid In Amber Bottle

R & R International, Inc.
1234 S. Cleveland-Massillon Road
P.O. Box 4383
Akron, OH 44321

Attn: Mr. Sam Reed

SITE NAME: Ravenna Arsenal, Project No. 100214

Reference: Partially Completed W.P.S.

The following parameters and detection limits were determined for disposal at Chemtron Corp.

As Received:

pH 10% H ₂ O Extract	0
Color	Dark Brown
Texture	Viscous Liquid
Odor	Moderate
* Layers	See Below
Flash Point	>200° F
NVM (105°C 24 Hrs.)	21.64%
Ash (900°C to Constant Wt.)	5.26%
BTU	9,870/Lb.
Halogens as Chlorine	.28%
Cyanide (Total)	<1 ppm
Sulfide (total)	<100 ppm
Density g/cc	Not Applicable

* Layers: none visible, appears to be emulsions. Sample contained appreciable water.

GC Scan for Matrix: Static Pressure/Direct GC Technique

Methanol	<.1%
Ethanol	
Acetone	
Isopropanol	
Tertiary Butanol	
Methyl Ethyl Ketone	
n-butanol	
Benzene	
Hexane	<.1%

Chemtron Corp. is not responsible for the accuracy of the analysis and/or information furnished by client. Samples received will be discarded after 30 days. No evaluation will be made if samples are not analyzed within 30 days of receipt. It is prohibited without written consent.



R & R International, Inc.

Date Received: _____

Date Reported: _____

Customer ID#: _____

PO#: _____

Lab: A900216-4

Description: _____

GC Scan for Matrix - Cont'd.

Methyl Isobutyl Ketone	
Ethyl Acetate	<.1%
Toluene	
Xylene	
Cresols	
Cresylic Acid	
Phenols	
Nitrobenzene	
Carbon Disulfide	
Isobutanol	
Pyridine	
2-ethoxy-ethyl	
2-nitropropane	
Methylene Chloride	
1,1,1 Trichloroethane	
Carbon Tetrachloride	
Trichloroethylene	
Tetrachloroethylene	
Chlorobenzene	
1,1,2 Trichloro-1,2,2 Trifluoroethane	
Orthodichlorobenzene	
Trichlorofluoromethane	
1,1,2 Trichloroethane	
Chlorinated Fluorocarbons	<.1%
Diesel Fuel	21.0%
PCB's	<1 ppm

Chemtronic Corporation, 10000 West 10th Avenue, Denver, CO 80231. All rights reserved. This report is the property of Chemtronic Corporation and is to be used only for the purposes stated. No other use is permitted without written consent.



Radian International, Inc.

Date Received: _____

Date Reported: _____

Customer ID#: _____

PO#: _____

Lab. A900216-4

Description: _____

EP Toxic Extraction Procedure (SW-846; Method 1310)

Reported as mg/l

Antimony	0.04
Barium	0.26
Calcium	<0.01
Chromium	0.02
Lead	0.07
Mercury	<0.01
Selenium	<0.01
Silver	<0.01

Robert D. Haddad
Technical Administrator

RDH:lw

HOLK ENVIRONMENTAL SERVICES, INC.

7777 Wall Street
Valley View, Ohio 44125
(216) 524-0888
FAX (216) 524-2090

March 2, 1990

Mr. Paul Felice
Norton Landfill
9100 Market Place
Broadview Hts., Ohio 44147


Dear Paul,

Enclosed are the analytical results for the composite of soils from Tanks #1 - #4 removed from Ravenna Arsenal. This soil was removed in the excavation of underground storage tanks. Please note that this soil is non-hazardous in that it does not exhibit the characteristic of ignitability nor does it exhibit the characteristic of EP Toxicity.

Mr. Vince Marek of Nozzle New is the contractor on this project. He will call you to confirm approval for landfilling and a date to transport it to your disposal site.

Thank you for your assistance.

Sincerely,



Joseph A. O'Brien
Director, Sales and Marketing

JAO/tlg

Enclosure

HOLK ENVIRONMENTAL SERVICES, INC.

7777 Wall Street
Valley View, Ohio 44125
(216) 524-0888
FAX (216) 524-2090

Date Received: 2-15-90

Customer I.D.: Ravenna Arsenal

Nozzle New, Inc.
34412 Pettibone Road
Solon, Ohio 44139
Attn: Mr. Vince Marek

P.O.#: vb. VM/JO

Date Reported: 2-20-90

HOLK-Lab #: B9015-1

Description: Composite of

Tanks #1 - #4

Flash Point (PMCC)

>140 F

Paint Filter Test


No Free Liquid Present

TPH

71 ppm

EP TOXIC EXTRACTION PROCEDURE (SW-846; Method 1310)

	<u>Results (mg/l)</u>	<u>EP Tox Standard (mg/l)</u>
Arsenic	<0.01	5.0
Barium	0.09	100.0
Cadmium	<0.01	1.0
Chromium	<0.01	5.0
Lead	<0.01	5.0
Mercury	<0.01	0.2
Selenium	<0.01	1.0
Silver	<0.01	5.0



Thomas H. Richert
Director of Analytical Services

HR/tlg

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be disposed of after 30 days.

HOLK ENVIRONMENTAL SERVICES, INC.

7777 Wall Street
Valley View, Ohio 44125
(216) 524-0888
FAX (216) 524-2090

Date Received: 2-15-90

Customer I.D.: Ravenna Arsenal

Nozzle New, Inc.
34412 Pettibone Road
Solon, Ohio 44139
Attn: Mr. Vince Marek

P.O.#: vb. VM/JO


Date Reported: 2-20-90

HOLK-Lab #: B9015-1

Description: Composite of

Tanks #1 - #4

Benzene	<2 ppb
Toluene	<2 ppb
Ethylbenzene	<2 ppb
Xylene	<2 ppb



Thomas H. Richert
Director of Analytical Services

HR/tlg

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be disposed of after 30 days.

TELEPHONE CONVERSATION RECORD

MARCH 6, 1990

TO: MS. MICHELLE TARKA, STATE FIRE MARSHALL'S OFFICE, B.U.S.T.
PHONE: (614)752-7938

FROM: SUSAN MCCAUSLIN, ENVIRONMENTAL ENGINEERING
PHONE: (216)297-3220

SUBJECT: MS. TARKA'S LETTER DATED MARCH 1, 1990

I called Ms. Tarka to ask her why we received subject letter when we have already accomplished the required tasks set out in the letter. She indicated that the letter was sent after the fact and can be simply filed and ignored at this point.

Note: The incident number on the letter refers to Tank #23 Bldg. 1045 not the railroad yard.



Susan McCauslin

SM:ade:030690.pr

cc: COR
N. Wulff
H.R. Cooper
W. Carkido
File

TELEPHONE CONVERSATION RECORD

MARCH 2, 1990

TO: BILL BLACK, OEPA, NEDO, DIVISION SOLID & HAZARDOUS
WASTE MANAGEMENT PHONE: 425-9171

FROM: SUSAN MCCAUSLIN, ENVIRONMENTAL ENGINEERING
PHONE: 297-3220

SUBJECT: REMOVAL OF EXCAVATED SOIL FROM R&R UST REMOVAL PROJECT

I called Mr. Black to see if he wanted copies of the laboratory results for subject solid waste prior to removal from RVAAP for disposal. He indicated that he would not need to review the results and that if Norton Landfill agreed to accept the soil it could be removed for disposal.



Susan McCauslin

SM:ade
cc: W. Carkido
B. Jenkins
H. Cooper
File




Ohio Department of Commerce

Richard F. Celeste, Governor

Division of State Fire Marshal • Bureau of Underground Storage Tank Regulations
7510 E. Main St., P.O. Box 525 • Reynoldsburg, OH 43068-3395 • (614) 752-8200

Linda K. Page, Director



NOTICE OF VIOLATION

March 1, 1990

Ravenna Army Ammunition Plant
Attn: Sue McCuaslin
8451 State Rt. 5
Ravenna, OH 44266-9297

RE: Ravenna Army Ammunition
Plant, Railroad yard
South Service Road
8451 State Rt. 5
Ravenna, OH 44266-9297
Portage County
Incident 679298-00

Dear Ms. McCauslin:

Section 3737.882 of the Ohio Revised Code authorizes the State Fire Marshal to implement the corrective action program for releases of petroleum from underground storage tank systems within the state. Under the program, the owner/operator of the underground storage tank system is responsible for investigating suspected releases of petroleum from the tank system so as to either confirm or disprove that a release of petroleum has actually occurred. This office has been notified of a suspected release at the aforementioned facility.

As the owner and/or operator of the underground storage tank system you are subject to the state and federal regulations governing such systems. Rule 1301:7-7-28 (K) (1) of the Ohio Administrative Code (OAC) specifically lists testing, monitoring, or sampling results indicate a release may have occurred as constituting a suspected release of petroleum from underground storage tank systems. Pursuant to OAC Rule 1301:7-7-36 (C) (1), you are required to investigate the suspected release at the aforementioned site in a manner consistent with OAC Rule 1301:7-7-28 (K) so as to either confirm or disprove whether a release has actually occurred. Specifically, in order to comply with OAC Rules 1301:7-7-28 and 1301:7-7-36, you need to undertake the following activities:

1. On or before March 9, 1990, conduct a tightness test (precision test) of the tanks and piping which comprise the system to determine if a release may have occurred. The precision testing shall be done in accordance with the criteria listed in the National Fire Protection Association (NFPA) pamphlet No. 329.

Ms. Sue McCauslin
Page #2
March 1, 1990

2. On or before March 22, 1990, conduct an analysis of soil core samples for hydrocarbon and/or chemical contamination in the unsaturated zone under the underground storage tank system, or, if the groundwater is no more than twenty (20) feet from the ground surface, an analysis of groundwater samples for hydrocarbon and/or chemical contamination shall be conducted. Sampling shall be done in accordance with the enclosed "Sampling Guidelines". If any obvious signs of contamination (visual and/or odors) are found during the investigation the local fire official and State Fire Marshal, Bureau of Underground Storage Tank Regulations shall be immediately notified and corrective actions shall be initiated in accordance with OAC 1301:7-7-36.
3. Within three days of your receiving the results of the tightness tests and sample analysis, submit copies of the results to the State Fire Marshal, Bureau of Underground Storage Tank Regulations.

As an alternative to the requirements described in items 1 through 3 above, the owner/operator may elect to remove and replace, or close the underground storage tank system. In this case the owner/operator shall follow the enclosed "Closure Site Assessment Requirements" and, perform such activities under the following deadlines and conditions:

1. On or before April 1, 1990, the underground storage tank system shall be removed and sampling shall be conducted.
2. If any obvious signs of contamination (visual and/or odors) are present during closure, the local Fire Official and the State Fire Marshal, Bureau of Underground Storage Tank Regulations shall be notified immediately, and corrective actions shall be initiated in accordance with OAC 1301:7-7-36.
3. Within three days of receipt of written sample results the owner/operator shall submit the Closure Site Assessment report and all associated sample results to the State Fire Marshal and local Fire Official.

Depending on the closure deadline indicated, the owner/operator may have a short time period in which to obtain the written closure or change in service permit. If the permit is to be obtained from the State Fire Marshal, the owner/operator must contact the State Fire Marshal, Bureau of Underground Storage Tank Regulations and Inspection Bureau. Arrangements can then be made to expedite the permitting process in order to help the owner/operator comply with the deadline line given.

When soil and groundwater samples are to be collected the owner/operator shall follow the protocols described in the enclosed Sampling Guidelines or Closure Site Assessment Guidelines. At a minimum these guidelines shall be followed in order for the sample results to be considered valid.

Ms. Sue McCauslin
Page #3
March 1, 1990

To assist you in understanding your responsibilities, I have enclosed a copy of OAC Rules 1301:7-7-28 and 1301:7-7-36. I have also enclosed copies of Sections 3737.882 and 3737.99 (I) of the Ohio Revised Code. Please note that failure to comply with the requirements of OAC Rules 1301:7-7-28 and 1301:7-7-36 could subject you to civil penalties under Section 3737.882 (C) of the Ohio Revised Code and the criminal penalties under Section 3737.99 (I) of the Ohio Revised Code.

To assist our office in expediting a review of your correspondence, reference the incident number (679298-00) and place it in the upper right hand corner of all of your correspondence. Thank you for your cooperation, and if you have any questions regarding this matter, please contact me at (614) 752-7938.

Sincerely,



Michelle Tarka
Site Coordinator
Bureau of Underground
Storage Tank Regulations

MT:ag

Enclosures

cc: File #679298-00
Dwayne Porter, Portage County Health Dept.

TELEPHONE CONVERSATION RECORD

FEBRUARY 28, 1990

TO: MICHELLE TARKA, B.U.S.T./STATE FIRE MARSHALL

PHONE: (614)752-7938

FROM: SUSAN MCCAUSLIN, ENVIRONMENTAL ENGINEERING

PHONE: 297-3220

SUBJECT: SITE INVESTIGATION REPORT FOR LEAKING TANKS RV #11,
RV #23, AND RV #33

Ms. Tarka had received the subject report. Upon looking at the lab results provided with the report, Ms. Tarka indicated that no further work would be necessary at Tank #11, and probably no further work would be needed at Tank #23. She wants to see our report on all tanks being removed before a definite decision is made regarding further corrective action that may be needed. Tank #33 has been turned over to OEPA jurisdiction, P.O.C. Harley Bowers.

Ms. Tarka also provided the following incident numbers for the leaking tanks: #679298-00 for Tank #23; #670298-01 for Tank #33; and 679298-02 for Tank #11.



Susan McCauslin

SM:ade

cc: RVAAP COR Office

W. Carkido

B. Jenkins

H. Cooper

File



RAVENNA ARSENAL INC.

8451 STATE ROUTE 5
RAVENNA, OHIO 44266-9297

Telephone (216) 358-7111

Autovon 346-3210

February 23, 1990

~~THRU: Contracting Officer's Representative
Ravenna Army Ammunition Plant
8451 State Route 5
Ravenna, Ohio 44266-9297~~

[Handwritten signature]
23 Feb 90

TO: Ohio Department of Commerce
Division of State Fire Marshal
Bureau of Underground Storage Tank Regulations
ATTN: Michelle Tarka, Site Coordinator
7510 East Main Street
P.O. Box 525
Reynoldsburg, Ohio 43068-3395

Subject: Site investigation report for leaking underground storage tanks.

Dear Ms. Tarka:

Pursuant to Rule 1303:7-7-36 of the Ohio Administrative Code, following is the Site Investigation Report for leaking underground storage tanks at the Ravenna Army Ammunition Plant (RVAAP).

Your office was notified that three underground storage tanks at RVAAP failed their tank tightness tests. Tank #11 contained #2 fuel oil; leakage indicated by the test was .353 gph. Tank #23 contained #2 fuel oil; leakage indicated by the test was .3005 gph. Tank #33 contained #2 fuel oil; leakage indicated by the test was .065 gph.

The tanks were drained immediately upon learning of the test results. Quantity of product released is unknown, however, it is believed to be minimal. Soils surrounding the tanks are generally a low permeability silty clay loam. No free product was observed in the surrounding soils.

R&R International Inc. has cleaned, removed and disposed of the tanks. Any visibly contaminated soils, or soils suspected to be contaminated based on PID screening, were excavated. R&R collected samples from the sidewalls and bottom of the excavated pits for Tanks #23 and #33. Bedrock was encountered during the excavation

of Tank #11, and samples were taken from soils in two sidewalls and the excavation pit bottom. The two remaining sidewalls were excavated to bedrock, no samples were taken from these areas. Groundwater was not encountered in any of the excavations. Samples collected from the excavated areas were tested for benzene, ethyl benzene, toluene, and xylene (BTEX), total lead, and total petroleum hydrocarbons (TPH), using methods set forth in SW-846. Analytical results for TPH and BTEX have been received and are enclosed. The remaining results are expected to be received by February 26, 1990. These results will be immediately forwarded to your attention upon receipt.


Excavated soils were sampled to characterize them for disposal. These samples will be analyzed for TPH, E.P. Toxicity, percent solids and flash point using methods set forth in SW-846.

Groundwater is currently the exclusive source of water supply for RVAAP. The location of active groundwater production wells is shown in Attachment #1. None of these wells is located with 1,000 ft. of the leaking tanks. A description of soil characteristics and a map showing subsurface soil distribution on site is shown in Attachment #2. Local climatological conditions are shown in Attachment #3. Surrounding land use is residential; the closest residence to a leaking tank location on the installation is approximately 4,000 ft.

This installation's point of contact for this subject is Susan McCauslin, Environmental Specialist, (216)297-3220.

Sincerely,

Ravenna Arsenal, Inc.



H.R. Cooper
Plant Engineer

HRC:SM:ade:90002

cf: Commander
AMCCOM
AMSMC-ISE
Rock Island, IL 61299-6000

cc: N. Wulff
File

HOLK ENVIRONMENTAL SERVICES, INC.

7777 Wall Street
Valley View, Ohio 44125
(216) 524-0888
FAX (216) 524-2090

Date Received: 2-15-90

Customer I.D.: Ravenna Arsenal

Nozzle New, Inc.
34412 Pettibone Road
Solon, Ohio 44139
Attn: Mr. Vince Marek

P.O.#: vb. VM/JO

Date Reported: 2-20-90

HOLK-Lab #: B9015-8-13

Description: soil samples

<u>Customer I.D.</u>	<u>HOLK-Lab #</u>	<u>BTEX*</u>
Tank #1 (RV 33) (North)	B9015-8	<2 ppb
Tank #1 (Center)	B9015-9	<2 ppb
Tank #1 (South)	B9015-10	<2 ppb
Tank #4 (RV 23) (North)	B9015-11	<2 ppb
Tank #4 (Center)	B9015-12	<2 ppb
Tank #4 (South)	B9015-13	<2 ppb

* Benzene, Toluene, Ethylbenzene, Xylene.


Thomas H. Richert
Director of Analytical Services

THR/tlg

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be disposed of after 30 days.

HOLK ENVIRONMENTAL SERVICES, INC.

7777 Wall Street
Valley View, Ohio 44125
(216) 524-0888
FAX (216) 524-2090


Date Received: 2-15-90Customer I.D.: Ravenna Arsenal

Nozzle New, Inc.
34412 Pettibone Road
Solon, Ohio 44139
Attn: Mr. Vince Marek

P.O.#: vb. VM/JODate Reported: 2-20-90HOLK-Lab #: B9015-2-7Description: soil samples

<u>Customer I.D.</u>	<u>HOLK-Lab #</u>	<u>BTEX*</u>
Tank #2 (RU 11) (East)	B9015-2	<2 ppb
Tank #2 (Center)	B9015-3	<2 ppb
Tank #2 (West)	B9015-4	<2 ppb
Tank #3 (RU 22) (North)	B9015-5	<2 ppb
Tank #3 (Center)	B9015-6	<2 ppb
Tank #3 (South)	B9015-7	<2 ppb

* Benzene, Toluene, Ethylbenzene, Xylene.


Thomas H. Richert
Director of Analytical Services

THR/tlg

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be disposed of after 30 days.

HOLK ENVIRONMENTAL SERVICES, INC.


7777 Wall Street
Valley View, Ohio 44125
(216) 524-0888
FAX (216) 524-2090

Date Received: 2-15-90Customer I.D.: Ravenna Arsenal

Nozzle New, Inc.
34412 Pettibone Road
Solon, Ohio 44139
Attn: Mr. Vince Marek

P.O.#: vb. VM/JODate Reported: 2-20-90HOLK-Lab #: B9015-2-7Description: soil samples

<u>Customer I.D.</u>	<u>HOLK-Lab #</u>	<u>TPH</u>
Tank #2 (RU11) (East)	B9015-2	22 ppm
Tank #2 (Center)	B9015-3	18 ppm
Tank #2 (West)	B9015-4	17 ppm
Tank #3 (RU 22) (North)	B9015-5	23 ppm
Tank #3 (Center)	B9015-6	18 ppm
Tank #3 (South)	B9015-7	44 ppm



Thomas H. Richert
Director of Analytical Services

THR/tlg

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be disposed of after 30 days.

P. 2

(3)

HOLK ENVIRONMENTAL SERVICES, INC.

7777 Wall Street
Valley View, Ohio 44125
(216) 524-0888
FAX (216) 524-2090

Date Received: 2-15-90

Customer I.D.: Ravenna Arsenal

Nozzle New, Inc.
34412 Pettibone Road
Solon, Ohio 44139
Attn: Mr. Vince Marek


P.O.#: vb, VM/JO

Date Reported: 2-20-90

HOLK-Lab #: B9015-8-13

Description: soil samples


<u>Customer I.D.</u>	<u>HOLK-Lab #</u>	<u>TPH</u>
Tank #1 (North) (RV 33)	B9015-8	149 ppm
Tank #1 (Center)	B9015-9	305 ppm
Tank #1 (South)	B9015-10	158 ppm
Tank #4 (North) (RV 23)	B9015-11	37 ppm
Tank #4 (Center)	B9015-12	67 ppm
Tank #4 (South)	B9015-13	394 ppm


Thomas H. Richert
Director of Analytical Services

THR/tlg

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be disposed of after 30 days.

MAP OF RAAP, SHOWING LOCATION OF PRODUCTION WELLS



Soil Characteristics.*

(1) Distribution. RAAP contains three distinct soil associations; their distribution is depicted on Figure 1. Most of the installation is mantled by somewhat poorly drained and slowly permeable silt loams which have developed over silty clay loam or clay loam glacial till. The till soils in the western quarter of RAAP contain a restrictive, cemented subsoil layer (fragipan). The northeastern fringe of RAAP contains poorly drained but moderately permeable silt loams formed in silty, stream-deposited, alluvium on flood plains.

(2) Description.




(a) Mahoning-Ellsworth Soil Association. The topsoil consists of 8 inches of friable, dark grayish-brown silt loam; the subsoil consists of 52 inches of firm brown silty clay loam. The top 3 to 4 feet possess a pH ranging from 4.5 to 7.3; however, below that the soil is alkaline (7.4-8.4). These soils display slow to very slow permeability.


(b) Wadsworth-Rittman Soil Association. The topsoil consists of 8 inches of friable, dark grayish-brown silt loam; the subsoil consists of 19 inches of yellowish-brown silty clay loam over 21 to 33 inches of brown, very firm and brittle cemented, clay loam or silty clay loam (fragipan). These soils have a pH ranging from 4.5 to 7.8 and display slow permeability.

(c) Sebring-Holly Soil Association. The topsoil consists of 10 inches of friable gray silt loam; the subsoil contains 50 inches of gray silt loam to silty clay loam. The soil pH ranges from 5.1 to 7.3, and the soil permeability is moderately slow to moderately rapid.

* Source of information is "An Inventory of Ohio Soils, Portage County," Ohio Department of Natural Resources, Progress Report No. 38 (1973)


EXPLANATION OF SOIL ASSOCIATION:

-  - MAIRNING-ELLSWORTH, SLOWLY PERMEABLE SILT LOAM DEVELOPED ON GLACIAL TILL
-  - WADSWORTH-RITTMAN, SLOWLY PERMEABLE SILT LOAM WITH A FRAGIPAN SUBSOIL
-  - SEBRING-HOLLY, MODERATELY PERMEABLE SILT LOAM DEVELOPED ON ALLUVIUM



MAP OF RAAP, SHOWING SOIL GROUP DISTRIBUTION

The plant site has a continental climate with temperature extremes of -21°F in January and 100°F in July. The annual mean precipitation is 36 inches. The annual mean snowfall is 48 inches. The prevailing winds are south and southwest and average 10 miles/hour.



IMPORTANT TAX INFORMATION



1234 S. Cleveland-Massillon Rd.
Akron, Ohio 44321
(216) 666-2200
FAX: (216) 666-7874

Please deliver immediately to: Mr. Bill Jenkins

Company: Ravenna Arsenal, Inc.

Fax #: 1-297-3216

Reference: UST Removal

Response Requested:	Y <input type="checkbox"/>	N <input type="checkbox"/>
Hardcopy to follow by mail:	Y <input type="checkbox"/>	N <input type="checkbox"/>

No. of pages (including cover sheet): _____ Date: _____

Please contact Mayer if all pages not received.

B. J. JENKINS
FEB 22 1990

Comments: _____
cc: Susan McCauley
Wayne Carlsdo
BDA
2/22/90

For Internal Use Only: _____

Signed By: Sam Reed



B. J. JENKINS

FEB 2 1990

cc: Wayne Carlsdo
Susan mc cauli

HAZARDOUS WASTE LANDFILLS

Michigan Disposal, Inc. (MDI) - Detroit Michigan

NOT Acceptable

Envirosafe (Founemcy Fundessey) - Toledo, Ohio

Acceptable

Waste Management, Inc. (Model Cities) - Niagara Falls, New York

Acceptable

CECOS - Niagara Falls, New York

Acceptable

DISPOSAL LANDFILLS

Peerless Oil Service - North Olmsted, Ohio

Environmental Transportation Services (ETS) - 1-800-234-3872
- Mark Cawthorne

7-7 Inc. 262-3877 - Richard Brown

Chem. Freight (Erieway) - Tom Holschum

CONTAMINATED LANDFILLS

Norton Landfill - 82-77 Broadview Hts.

Inland Landfill - Richmond Road - Glen Willow

Need to inspect

NON-HAZARDOUS LANDFILLS

North Coast Disposal Co. - 8650 Brookpark

Harvard Landfill - Cleveland

UNDERGROUND STORAGE INSTALLER CERTIFICATES

CN 90-159

CN 90-160

IMPORTANT FAX INFORMATION



1234 S. Cleveland-Massillon Rd.
Akron, Ohio 44321
(216) 666-2200
FAX: (216) 666-7874

Please deliver immediately to: MR. BILL JENKINS

Company: RAVENNA ARSENAL, INC.

B. J. JENKINS

Fax #: 1-297-3216

FEB 21 1990
cc: Susan McCaslin
Wayne Calkins

Reference: UST REMOVAL

Response Requested:	Y <input type="checkbox"/>	N <input checked="" type="checkbox"/>
Hardcopy to follow by mail:	Y <input checked="" type="checkbox"/>	N <input type="checkbox"/>

No. of pages (including cover sheet): 7 Date: 21 FEB 1990

Please contact _____ if all pages not received.

Comments: MR. JENKINS - THE ATTACHED SHEETS INCLUDE:

2 SHEETS OF TEST RESULTS FOR "CONTAMINATED" SOIL (SHEET 2+3)

2 SHEETS OF TPH RESULTS FOR ALL 4 TANKS (SHEETS 4+5)

2 PAGE LETTER REGARDING TESTING OF SLUDGES.

* BTEX RESULTS SHOULD FOLLOW LATER TODAY

For Internal Use Only: _____

Signed By:

SAM REED

RAVENNA ARSENAL, INC.

INTEROFFICE MEMO

TO: MR. BILL JENKINS, PURCHASING

FROM: T. M. CHANDA, ENVIRONMENTAL ENGINEER

DATE: FEBRUARY 19, 1990

SUBJECT: INSPECTION OF THE NORTON/ROYALTON ROAD LANDFILL FOR
THE DISPOSAL OF ANALYTICALLY DETERMINED RVAAP NON-
HAZARDOUS PETROLEUM CONTAMINATED SOIL

=====

PURPOSE: To determine the environmental acceptableness of subject landfill by personal observation of all phases of the activity which includes site inspection, interview with the landfill operator, and interview of appropriate Ohio EPA site inspector. This action was enacted to insure proper disposal of petroleum product contaminated soil (analytically determined as non-hazardous) generated by the removal of 4 (ea) RVAAP Underground Storage Tanks (USTs) that failed regulated tank tightness testing. Subject disposal action is to be performed by RVAAP subcontractor R & R International, Inc. The inspection/survey was administered under a format established by Olin Corporation's procedure No. CSP 54, Appendix C.

FINDINGS: In the completion of this survey and personal contact with landfill and regulatory personnel it's been determined that the Norton/Royalton Road Landfill is acceptable for disposal of non-hazardous RVAAP petroleum contaminated soil.

I - PERSONAL OBSERVATIONS & CONTACT

A. Installation Personnel Performing Inspection/Interview:

Thomas M. Chanda
RAI Environmental Engineer

B. Inspection Date: February 13, 1990 at 0930 hrs.

C. Persons Contacted/Interviewed:

- 1.) Mr. John Felice
Norton Landfill Manager
- 2.) Mr. William Black, Sanitarian
Ohio EPA, Northeast District Office
Regulatory Agency's Landfill Inspector
for the Norton Landfill

D. General:

The Norton Landfill is owned and operated by the Norton Construction Co., North Royalton, Ohio.

The existing landfill is a 140 acre site with a remaining working capacity of 6 months. An additional 20 acres of adjacent land located to the immediate East is in readiness to commence landfill operations following Ohio EPA approval of engineering plans for site expansion. The existing site rises approximately 125 ft. in elevation attributed from previous landfill activity; this same elevation is proposed for 20 acre expansion site. The site is 1/4 mile North of the main thoroughfare of Royalton Rd. and is, therefore, non-visible to the general public. To the immediate South and Southwest of the landfill is an industrial park complex which houses both office and small manufacturing facilities; this area is well kept. The North and West boundaries of the site abut to wooded areas with the East being somewhat open field till meeting Interstate I-77 approximately one-half mile away. Vehicular access to the landfill can only be reached from the South through a gated entrance. Prior to entering the landfill proper, all transport vehicles are checked in at receiving station which consists of a trailered office area which is manned by landfill personnel. The only fencing observed was on the site's Southern boundary.

The site operations are considered to be small to medium activity with a traffic flow of one incoming waste load every 10-15 minutes. It was noted by the site manager that 12 municipalities have been turned down from disposing at the site in order to slow the rate of filling up the remaining active portion of the landfill.

E. Environmental Considerations:

1. Drinking water wells are of no consequence to the site. All portable water provided to surrounding communities are accomplished via a district municipal treatment facility and distribution system.
2. The site collects its leachate/run-off waters which are channelled into the local sewer collection system. The local sewer authority requires periodic testing of the landfills discharge, but does not impose any pre-treatment standards. Analyses is performed by an independent lab which forwards the results to the sewer authority. No objections have been raised to the leachate's characteristics and their contribution to the sewage system. No NPDES permits are maintained. There were no nearby streams, creeks, or waterways that may be impacted by the landfill.
3. There are 30 methane gas collection wells upon the landfill site. The gas is burned off/flushed to atmosphere. No air permits have been required of the landfill using this process of methane gas evacuation.
4. The site exhibited good maintenance, adequate cover, good housekeeping practices, no odors, and no presence of vermin. The site's cover material is imported with an adequate amount stockpiled. Access roads to and from the working face of the site were sound and adequate to support heavy bearing loads. There was noticed some paper blowing at the work site from a load that had just been dropped, but due to the high wind that day and appearance of the rest of the site's surrounding areas blowing debris is effectively policed.
5. The site does not maintain or have present any retention lagoons or ponds.
6. A current 1990 Ohio EPA Solid Waste Landfill permit/license was reviewed with a permit identification No. 8. The landfill is permitted to receive non-hazardous solid waste generated from commercial, industrial, and municipal/domestic sources. The landfill is not designated or permitted to receive regulated asbestos containing materials.
7. To the best recollection of the landfill manager, Olin Corporation wastes have never been received at the site.
8. Post closure care of the filled portions of the site were well maintained with adequate cover and no evidence of ponding.

9. Being owned by a construction type company the landfill site has an adequate amount of earth moving equipment available immediately adjacent to the site. Earth moving equipment included several 10-20 ton dump trucks, crawler cranes with dragline, earth scrapers, bulldozers, and compactors (Bull-Mags). The working face area had in operation one compactor and a bulldozer in standby.
10. The landfill operation maintains 6 groundwater monitoring wells; 2 upgradient and 4 down gradient. Analytical results are reported to be acceptable to primary drinking water standards. Other analytical parameters that are monitored for, are uncertain of acceptability due to Ohio EPA not having standards for those recognized non-drinking water quality constituents. Ohio EPA has never raised any objections to any of the landfill's monitoring well data.

F. Regulatory Agency Interview:

Mr. William Black from Ohio EPA's Northeast District, who's the inspector for the Norton Landfill's operation, was interviewed on February 13, 1990. Mr. Black commented upon the landfill as follows:

- The Norton Landfill is "substantially compliant"
- No noted violations, discrepancies, or restrictions have been administered against the landfill in the last six months.
- He was pleased with the management practices that were demonstrated at the landfill and the efforts to maintain a clean operation.
- There were no objections to the use of the landfill by RVAAP for the disposal of non-hazardous characterized petroleum contaminated soil. Other businesses/industries have used the Norton Landfill for similar waste disposal.


G. Other considerations prior to physical disposal of RVAAP petroleum contaminated soil by R & R International, Inc.

1. Analytical soil data shall include determination for total petroleum hydrocarbons (TPH), benzene, ethylene, toluene and xylene (BETX), percent solids content, ignitability, EP toxicity (metals), and polychlorinated biphenyls (PCBs).

2. All analytical data will be forwarded over to Mr. Black of Ohio EPA and Mr. Felice, Norton Landfill, prior to first receipt of waste. Approvals will be confirmed by both parties prior to RVAAP soil removal off-site.
3. R & R International, Inc. will be expected to pay in full for all fees waged by the landfill one day following the last load received for disposal at the Norton Landfill; this comment emphasized by Mr. Felice.

cc: RVAAP COR
N. Wulff
H. Cooper
S. McCauslin
File

cc: N. Wulff
T. Chanda/S. McCauslin
W. Carkido
B. Jenkins
File



RAVENNA ARSENAL INC.

8451 STATE ROUTE 5
RAVENNA, OHIO 44266-9297

Telephone (216) 358-7111

Autovon 346-3210

February 16, 1990

Contracting Officer's Representative
Ravenna Army Ammunition Plant
8451 State Route 5
Ravenna, Ohio 44226-9297

SUBJECT: UNDERGROUND STORAGE TANK (USTS) UPDATE

Dear Sir:

The Ravenna Army Ammunition Plant is currently in the process of removing 16 USTs. The 16 USTs being removed are broken into two (2) separate jobs:

- 1) 12 USTs declared abandoned are currently being removed by Cardamone Construction.
- 2) 4 USTs which failed their tank tightness tests are currently being removed by R & R International, Inc.

A breakdown of work completed in each job is as follows:

- I. Cardamone has pulled all 12 USTs and their related appendages. Each excavation has been cleaned of all contamination and sampled, based on PID screenings during excavation. The apparent contaminated soil has been stockpiled while awaiting sample results per all EPA regulations.

The subcontractor is currently cleaning each tank of any leftover sludges and residues. Upon completion of cleaning, a sludge sample shall be taken for disposal purposes and the cleaned tank may be properly disposed of. Cleaning shall be completed by Tuesday, February 20, 1990.

Based on sample results, the subcontractor will either do further excavation then backfill or backfill each hole. The subcontractor will also be able to dispose of any contaminated materials at this time. The sample results are expected back no later than Friday, Feb. 23, 1990 and completion of project is expected by Friday, March 2, 1990.


- II. R & R has cleaned, removed and disposed of all 4 USTs. R & R has taken all samples required, and based on PID screenings at the time of excavation, R & R decided to line each excavation with plastic and backfill each hole.

R & R is currently awaiting sample results to arrange for disposal of all contaminated materials. If test results warrant further excavation, they will do so. If test results come back clean, their job will be considered complete. Sample results are due back by Friday 2/23/90. Based on sample results, projected completion date shall be 2/23/90 or 3/2/90.

In summary, the actual work needed to complete both jobs is minor and the only element dictating an actual completion date is the time element in receiving results. In both cases, all work should be completed by 2 March 90 pending no unforeseen delays in receiving all sample results.

Sincerely,

RAVENNA ARSENAL, INC.



H. R. Cooper
Plant Engineer

WAC/wt/wc90003

HOLK ENVIRONMENTAL SERVICES, INC.

7777 Wall Street
 Valley View, Ohio 44125
 (216) 524-0888
 FAX (216) 524-2090

Date Received: 2-15-90

Customer I.D.: Ravenna Arsenal

Nozzle New, Inc.
 34412 Pettibone Road
 Solon, Ohio 44139
 Attn: Mr. Vince Marek

P.O.#: vb. VM/JO

Date Reported: 2-20-90

HOLK-Lab #: B9015-8-13

Description: soil samples

<u>Customer I.D.</u>	<u>HOLK-Lab #</u>	<u>BTEX*</u>
Tank #1 (RV 33) (North)	B9015-8	<2 ppb
Tank #1 (Center)	B9015-9	<2 ppb
Tank #1 (South)	B9015-10	<2 ppb
Tank #4 (RV 23) (North)	B9015-11	<2 ppb
Tank #4 (Center)	B9015-12	<2 ppb
Tank #4 (South)	B9015-13	<2 ppb

* Benzene, Toluene, Ethylbenzene, Xylene.

Thomas H. Richert
 Thomas H. Richert
 Director of Analytical Services

THR/tlg

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be disposed of after 30 days.

HOLK ENVIRONMENTAL SERVICES, INC.

7777 Wall Street
Valley View, Ohio 44125
(216) 524-0888
FAX (216) 524-2090

Date Received: 2-15-90Customer I.D.: Ravenna Arsenal

Nozzle New, Inc.
34412 Pettibone Road
Solon, Ohio 44139
Attn: Mr. Vince Marek

P.O.#: vb. VM/JODate Reported: 2-20-90HOLK-Lab #: B9015-2-7Description: soil samples

<u>Customer I.D.</u>	<u>HOLK-Lab #</u>	<u>BTEX*</u>
Tank #2 (RU 11) (East)	B9015-2	<2 ppb
Tank #2 (Center)	B9015-3	<2 ppb
Tank #2 (West)	B9015-4	<2 ppb
Tank #3 (RU 22) (North)	B9015-5	<2 ppb
Tank #3 (Center)	B9015-6	<2 ppb
Tank #3 (South)	B9015-7	<2 ppb

* Benzene, Toluene, Ethylbenzene, Xylene.


Thomas H. Richert
Director of Analytical Services

THR/tlg

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be disposed of after 30 days.

HOLK ENVIRONMENTAL SERVICES, INC.


7777 Wall Street
Valley View, Ohio 44125
(216) 524-0888
FAX (216) 524-2090

Date Received: 2-15-90Customer I.D.: Ravenna Arsenal

Nozzle New, Inc.
34412 Pettibone Road
Solon, Ohio 44139
Attn: Mr. Vince Marek

P.O.#: vb. VM/JODate Reported: 2-20-90HOLK-Lab #: B9015-2-7Description: soil samples

<u>Customer I.D.</u>	<u>HOLK-Lab #</u>	<u>TPH</u>
Tank #2 (RU11) (East)	B9015-2	22 ppm
Tank #2 (Center)	B9015-3	18 ppm
Tank #2 (West)	B9015-4	17 ppm
Tank #3 (RU 22) (North)	B9015-5	23 ppm
Tank #3 (Center)	B9015-6	18 ppm
Tank #3 (South)	B9015-7	44 ppm



Thomas H. Richert
Director of Analytical Services

THR/tig

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be disposed of after 30 days.

HOLK ENVIRONMENTAL SERVICES, INC.

7777 Wall Street
Valley View, Ohio 44125
(216) 524-0888
FAX (216) 524-2090

Date Received: 2-15-90

Customer I.D.: Ravenna Arsenal

Nozzle New, Inc.
34412 Pettibone Road
Solon, Ohio 44139
Attn: Mr. Vince Marek

P.O.#: vb. VM/JO

Date Reported: 2-20-90

HOLK-Lab #: B9015-8-13

Description: soil samples

<u>Customer I.D.</u>	<u>HOLK-Lab #</u>	<u>TPH</u>
Tank #1 (North) (RV 33)	B9015-8	149 ppm
Tank #1 (Center)	B9015-9	305 ppm
Tank #1 (South)	B9015-10	158 ppm
Tank #4 (North) (RV 23)	B9015-11	37 ppm
Tank #4 (Center)	B9015-12	67 ppm
Tank #4 (South)	B9015-13	394 ppm



Thomas H. Richert
Director of Analytical Services

THR/tlg

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be disposed of after 30 days.

HOLK ENVIRONMENTAL SERVICES, INC.

7777 Wall Street
Valley View, Ohio 44125
(216) 524-0888
FAX (216) 524-2090

4

Date Received: 2-15-90

Customer I.D.: Ravenna Arsenal

Nozzle New, Inc.
34412 Pettibone Road
Solon, Ohio 44139
Attn: Mr. Vince Marek

P.O.#: vb. VM/JO

Date Reported: 2-20-90

HOLK-Lab #: B9015-1

Description: Composite of
Tanks #1 - #4

Flash Point (FMCC)
Paint Filter Test
TPH

>140 F
No Free Liquid Present
71 ppm

EP TOXIC EXTRACTION PROCEDURE (SW-846; Method 1310)

	<u>Results (mg/l)</u>	<u>EP Tox Standard (mg/l)</u>
Arsenic	<0.01	5.0
Barium	0.09	100.0
Cadmium	<0.01	1.0
Chromium	<0.01	5.0
Lead	<0.01	5.0
Mercury	<0.01	0.2
Selenium	<0.01	1.0
Silver	<0.01	5.0

Thomas H. Richert
Director of Analytical Services

THR/tlg

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be disposed of after 30 days.

HOLK ENVIRONMENTAL SERVICES, INC.

7777 Wall Street
Valley View, Ohio 44125
(216) 524-0888
FAX (216) 524-2090

Date Received: 2-15-90

Customer I.D.: Ravenna Arsenal

Nozzle New, Inc.
34412 Pettibone Road
Solon, Ohio 44139
Attn: Mr. Vince Marek


P.O.#: vb, VM/JO

Date Reported: 2-20-90

HOLK-Lab #: B9015-1

Description: Composite of
Tanks #1 - #4

Benzene	<2 ppb
Toluene	<2 ppb
Ethylbenzene	<2 ppb
Xylene	<2 ppb


Thomas H. Richert
Director of Analytical Services

THR/tlg

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be disposed of after 30 days.

HOLK ENVIRONMENTAL SERVICES, INC.

7777 Wall Street
Valley View, Ohio 44125
(216) 524-0888
FAX (216) 524-2090

Date Received: 2-15-90

Customer I.D.: Ravenna Arsenal

Nozzle New, Inc.
34412 Pettibone Road
Solon, Ohio 44139
Attn: Mr. Vince Marek

P.O.#: vb, VM/JO

Date Reported: 2-20-90

HOLK-Lab #: B9015-1

Description: Composite of
Tanks #1 - #4

Flash Point (PMCC)
Paint Filter Test
TPH

>140 F
No Free Liquid Present
71 ppm

EP TOXIC EXTRACTION PROCEDURE (SW-846; Method 1310)

	Results (mg/l)	EP Tox Standard (mg/l)
Arsenic	<0.01	5.0
Barium	0.09	100.0
Cadmium	<0.01	1.0
Chromium	<0.01	5.0
Lead	<0.01	5.0
Mercury	<0.01	0.2
Selenium	<0.01	1.0
Silver	<0.01	5.0

Thomas H. Richert
Director of Analytical Services

THR/tlg

The foregoing is limited to findings based upon material received for analysis and/or information furnished by client. Samples received will be disposed of after 30 days.



Ohio Department of Commerce

Richard F. Celeste, Governor

Division of State Fire Marshal • Bureau of Underground Storage Tank Regulations
7510 E. Main St., P.O. Box 525 • Reynoldsburg, OH 43068-3395 • (614) 752-8200

Linda K. Page, Director

February 13, 1990

Ravenna Army Ammunition Depot
Attn: Sue McCauslin
8451 S.R. 5
Ravenna, OH 44266

Dear Ms. McCauslin:

Enclosed is a copy of the current guidance document and a copy of the OAC 1301.
If you have any questions regarding this matter, please call me at (614) 752-7938.

Sincerely,

A handwritten signature in cursive script, appearing to read "Michelle Tarka".

Michelle Tarka
Site Coordinator
Bureau of Underground
Storage Tank Regulations

MT:ag

Enclosures

cc: File #679298-00

OHIO DEPARTMENT OF COMMERCE
DIVISION OF STATE FIRE MARSHAL

REGULATIONS PERTAINING TO PETROLEUM UNDERGROUND STORAGE TANK
SUSPECTED RELEASE INVESTIGATIONS AND CORRECTIVE ACTIONS

OAC 1301:7-7-28 (A), (E), (I), (J), AND (K)
OAC 1301:7-7-36
Ohio Revised Code 3737.882 and 3737.99(1)

1301:7-7-28. Article 28: FLAMMABLE AND COMBUSTIBLE LIQUIDS

Note: This reproduction of the Ohio Administrative Code does not contain the full text of Article 28 of the Ohio Fire Code, OAC 1301:7-7-28. The text of this printing contains only those paragraphs of Article 28 that pertain directly to petroleum underground storage tank suspected and confirmed releases and the typical tank repair or replacement activities conducted during release investigations and corrective actions. Other sections of the Ohio Fire Code may apply.

(A) Section F-2800.0. General.

- (1) FM-2800.1. Scope: This rule shall apply to the transportation, storage, handling and processing of flammable and combustible liquids and to any underground storage tank system as defined in paragraph (B) of rule 1301:7-7-02 of the Administrative Code (F-201.0). The provisions of NFIPA 30, NFIPA 30A, NFIPA 329, PEI RP 100-87, API 1604, API 1631 and ASTM G57-78 listed in rule 1301:7-7-34 of the Administrative Code shall apply where the provisions of this rule do not specifically cover conditions and operations.
- (2) FM-2800.2. Permit required: A permit shall be obtained from the fire official for each of the following:
 - (a) To install, remove, repair or alter in any way a stationary tank for the storage of flammable or combustible liquids, or to modify or replace any line.
 - (b) To install, repair or alter in any way, an underground storage tank, to modify or replace any piping connected thereto, to take such tank system temporarily or permanently out of service, or to place an out-of-service tank system back into service. When such a permit is not required by the local fire official the permit shall be obtained from the fire marshal.
 - (c) For the storage, handling or use of class I liquids in excess of five gallons in a dwelling or other place of human habitation, or in excess of ten gallons in any other building or other occupancy, or in excess of sixty gallons outside of any building except that no permit shall be required for the following:
 - (i) For the storage or use of flammable liquids in the fuel tank of a motor vehicle, aircraft, motorboat, mobile power plant or mobile heating plant; or
 - (ii) For the storage or use of paints, oils, varnishes or similar mixtures when such liquids are stored for painting or maintenance, or similar purposes upon the premises, and which are not stored for a period exceeding thirty days.
 - (d) Storage, handling or use of class II combustible liquids or class III combustible liquids in excess of twenty-five gallons in a building, or in excess of sixty gallons outside of a building, except for fuel oil used in connection with oil burning equipment in single-family residential buildings.
 - (e) For the manufacture, processing, blending or refining of flammable or combustible liquids.
 - (f) For the storage of flammable or combustible liquids in stationary tanks.
 - (g) For placing any flammable or combustible liquid stationary tank temporarily or permanently out of service and to place said tank back into service (see paragraph (E)-(9) below [FM-2804.9]).
 - (h) Permits shall be obtained from the fire marshal for above-ground flammable and combustible liquid tank installations in bulk plants. This paragraph applies only

where a permit is not obtained from another officer mentioned in section 3737.14 of the Revised Code.

- (3) FM-2800.3. Permit application: The application for a permit shall be submitted in such form as the fire official may prescribe and shall be accompanied by drawings and such additional information as may be required by the fire official. Permit and inspection fees which are required by ordinance shall accompany all applications. When a permit required by paragraph (A)(2)(b) of this rule is obtained from the fire marshal, an inspection fee in the amount of fifty dollars shall be paid to the fire marshal for each underground storage tank permit.
 - (4) F-2800.3.1. Stationary tank information: The application to install, remove, repair or alter any stationary tank for the storage of flammable or combustible liquids shall contain a general description of the proposed work and shall include two copies of a drawing indicating location, use, capacity and piping arrangement of all existing and proposed tanks located, or which are to be located, upon the premises and all adjacent buildings and property lines. Information which confirms that the tank meets the design requirements in paragraph (B)(2) below (F-2801.2) shall be attached to or made a part of the application.
- (E) Section 2804.0. Underground storage tanks.
- (1) FM-2804.1. Underground storage tank program compliance. All underground storage tank systems containing flammable or combustible liquids shall comply with the requirements of rule 1301:7-7-35 of the Administrative Code.
 - (2) FM-2804.2. Location: Underground storage tanks containing flammable or combustible liquids shall be located at least five feet from any wall, foundation or property line. The top of flammable liquid tanks shall be below the lowest floor level of any building within twenty feet of said tanks. Tanks shall not be located in or under any building unless said building and tank installation is constructed in accordance with the building code and NFIPA 30 listed in rule 1301:7-7-34 of the Administrative Code. A distance of at least one foot shall be maintained between underground tanks in multiple tank installations.
 - (3) FM-2804.3. Special conditions: The fire official may require greater separations or he may limit the storage capacity when the installation is subject to a severe exposure hazard or topographical conditions when necessary for the safety of the general public.
 - (4) FM-2804.4. Tank protection installation: Underground storage tanks containing flammable or combustible liquids shall comply with the following installation requirements:
 - (a) Steel tanks. Cathodically protected steel or approved noncorrosive coated steel underground storage tanks shall be set on a firm foundation and surrounded with at least six inches of noncorrosive inert material such as clean sand or gravel well tamped in place. Tanks, and the six inches of protective material, shall be covered with a minimum of two feet of earth or shall be covered with eighteen inches of earth, on top of which shall be placed a slab of reinforced concrete not less than four inches thick. When underground tanks are, or are likely to be, subjected to vehicular traffic, they shall be protected against damage by at least eighteen inches of earth, over the six inches of protective material, plus six inches of reinforced concrete or eight inches of asphaltic concrete. The reinforced concrete or asphaltic concrete protective cover shall extend at least one foot horizontally beyond the outline of the tank. When new tanks are located in an area that may be subjected to flooding or corrosion, applicable precautions shall be used in accordance with NFIPA 30 listed in rule 1301:7-7-34 of the Administrative Code.
 - (b) Fiberglass-reinforced plastic (FRP) tanks shall be installed in accordance with the manufacturer's specifications.
 - (5) FM-2804.5. Tank construction: Underground storage tanks containing flammable or combustible liquids shall meet the following requirements:
 - (a) Tanks shall be designed and built to prevent releases due to corrosion or structural failure for the operational life of the tank, using noncorrosive material or cathodi-

cally protected steel.

- (b) The material used in constructing or lining the tank shall be compatible with the substance to be stored.
 - (c) Steel tank systems shall be cathodically protected by an impressed current cathodic protection system, sacrificial anodes, or some other type of equivalent protection. If a cathodic protection system is used, it shall be maintained in accordance with paragraph (e)(5)(d) below. Selection of the type of protection to be employed shall be based upon the corrosion history of the area and the judgment of a qualified engineer. If a soil test conducted in accordance with ASTM standard G57-78, or another standard approved by the fire marshal, indicates that soil resistivity in an installation location is twelve thousand ohms per centimeter or more (unless a more stringent standard is prescribed by the fire marshal by rule), a storage tank without corrosion protection may be installed in that location during the period until new standards are promulgated by the administrator of the United States environmental protection agency.
 - (d) If a cathodic protection system is installed, an ongoing preventative maintenance program shall be used. Where sacrificial anodes have been installed, their proper operation shall be confirmed by the installer within six to twelve months of installation and one year thereafter. If these tests confirm proper operation, subsequent inspection intervals can be extended to five years. However, if underground work is performed at a protected site, cathodic protection should be remonitored six to twelve weeks after work is completed and one year thereafter before again extending the inspection interval. If an impressed current cathodic protection system is installed, the operator shall verify, at least once a month, that it is operating, and a qualified person shall conduct an on-site test and inspection, at least once a year, to measure the structure to soil and structure-to-structure potentials and the rectifier voltage and current output.
- (6) F-2804.6. Vent piping: Vent pipes from underground tanks containing flammable liquids shall be so located that the discharge point is outside of buildings, higher than the fill pipe opening and not less than twelve feet above the adjacent ground level. Vent pipes shall discharge only upward in order to disperse vapors. Each tank shall be vented through piping adequate in size as specified in the standards listed in rule 1301:7-7-34 of the Administrative Code, to prevent flow-back of vapor or liquid at the fill opening while the tank is being filled. Threaded joints and connections shall be liquid-tight with a suitable lubricant or piping compound.
- (7) F-2804.7. Fill piping: Fill piping passing through concrete shall be located in sleeves, mastic or the equivalent to protect against settlement, frost action and vibration. Welded or screwed joints or approved connectors shall be used. Threaded joints and connections shall be made liquid-tight and shall be made tight with a suitable lubricant or piping compound. Fill pipes shall terminate within six inches of the bottom of the tank.
- (8) FM-2804.8. Testing: All underground storage tanks containing flammable or combustible liquids shall be subjected to the following tests.
- (a) All tanks shall be strength tested before they are placed in service in accordance with the applicable provisions of the code or standard under which they were built. The "American Society of Mechanical Engineers" (ASME) code stamp, "American Petroleum Institute" (API) monogram, the label of the "Under writer's Laboratories, Inc." (UL), or the "Underwriter's Laboratories of Canada" (ULC) or an approved equivalent identification label on a tank shall be evidence of compliance with the strength test.
 - (b) Before tanks are placed into the hole they shall be tested with not less than three psi or more than five psi air pressure. All leaks or deformations shall be corrected in a manner approved by the fire official before the tanks are placed into the hole. Mechanical caulking is not permitted for correcting leaks in welded tanks.
 - (c) After the tank is set in the excavation and all lines are connected another air test

- shall be conducted. This test must be conducted before the lines and the tank are covered over and before the tank is filled with product.
- (d) When the vertical length of the fill and vent pipes is such that when filled with liquid the static head imposed upon the bottom of the tank exceeds ten psig, the tank and related piping shall be tested hydrostatically to a pressure equal to the static head thus imposed. In special cases where the height of the vent above the top of the tank is excessive, the hydrostatic test pressure shall be specified by the fire official.
 - (e) Periodic tests of underground tank storage systems may be required by the fire official to determine that leakage has not occurred. Testing shall be done in accordance with NFIPA 329 listed in rule 1301:7-7-34 of the Administrative Code.
- (9) FM-2804.9. Abandonment of tanks: A permit shall be obtained from the fire official to remove, abandon, place temporarily out of service or otherwise dispose of any underground storage tank containing flammable or combustible liquids. When such a permit is not required from the local fire official the permit shall be obtained from the fire marshal.
- (a) Tanks "temporarily out of service" shall have the fill line, gauge opening and pump connection secured against tampering. Vent lines shall remain open and be maintained in accordance with the requirements of this rule for vent lines.
 - (b) Any tank not used for a period of ninety days shall be properly safeguarded or removed in a manner approved by the fire official.
 - (c) Any tank which has been abandoned for a period of one year shall be removed from the property in a manner approved by the fire official and the site restored in an approved manner. When the fire official determines that the removal of the tank is not necessary, he may permit the tank to be abandoned in place in accordance with API 1604 listed in rule 1301:7-7-34 of the Administrative Code, and including the following methods:
 - (i) Remove all flammable or combustible liquid from the tank and all connecting lines.
 - (ii) Disconnect the suction, inlet, gauge, and vent lines.
 - (iii) Fill the tank completely with an inert solid material. Cap remaining underground piping.
 - (iv) Keep a record of tank size, location, date of abandonment, and method used for placing the abandoned tank in a safe condition.
 - (d) Tanks which are to be reinstalled for flammable or combustible liquid service shall comply with all the provisions of this rule.
 - (e) Tanks which are to be returned to service shall be tested in accordance with NFIPA 329 listed in rule 1301:7-7-34 of the Administrative Code.
- (1) Section FM-2808.0. Tank lining. Procedure for the interior coating and repair of leaking and/or deteriorated underground storage tanks containing flammable or combustible liquids (both steel and nonmetallic).
- (1) FM-2808.1. The local fire official shall determine whether or not the repair of leaking and/or deteriorating underground storage tanks containing flammable or combustible liquids shall be permitted within its jurisdiction. If such repair is permitted by the local fire official, it shall be accomplished in the manner prescribed in paragraphs (1)(2) and (1)(5) below.
 - (2) FM-2808.2. Manufacturers desiring to have their product used in Ohio shall register the specifications for the internal coating system for the repair of underground storage tanks containing flammable or combustible liquids with the fire marshal. The specifications shall

clearly describe the composition of the product, strength, limitations on use, preparation procedures, application procedures, quality control techniques, curing times and temperatures, field thickness testing procedures, field hardness testing procedures, and a method for determining whether an existing tank is repairable. This information, along with the results of the standards tests, shall be signed and sealed by a registered professional engineer.

- (3) FM-2808.3. Each manufacturer who has registered an internal coating system must submit to the fire marshal a list of qualified applicators. It is the responsibility of the manufacturer to keep this list current. The list shall indicate that the applicator is qualified to seal metal tanks, nonmetallic tanks or both. The internal coating procedure shall be in accordance with API 1631 listed in rule 1301:7-7-34 of the Administrative Code.
- (4) FM-2808.4. The applicator shall inform the following officials of the location of each project in the following manner:
 - (a) The local fire authority shall have in its possession a written notice stating the location of the project and the applicator's anticipated timetable for each stage of the project, prior to the commencement of the project. A copy of such written notice shall be mailed to the fire marshal simultaneously with its delivery to the local fire authority.
 - (b) Any applicator failing to make proper notification of the project location will be removed, for a period of six months, from the qualified applicator list on file with the fire marshal. Reinstatement can be accomplished only by the manufacturer resubmitting the applicator's name after the six-month period has elapsed.
 - (c) A current "Certificate of Insurance" covering the liability of the applicator shall be filed with the fire marshal.
 - (d) A sample of the "Application for Tank Repairs" may be obtained from the fire marshal.
- (5) FM-2808.5. A "Certificate of Performance" shall be utilized as follows:
 - (a) A "Certificate of Performance" on each field application shall be submitted to the local fire authority. The certificate (to be designed by the fire marshal and printed and supplied by the contractor) shall be signed by the qualified applicator and will confirm that the tank preparation and product application complies with the sealant manufacturer's specifications which are registered with the fire marshal.
 - (b) A sample of the "Certificate of Performance" may be obtained from the fire marshal.
- (J) Section FM-2809.0. Leak detection. Inventory records for underground storage tanks containing flammable and combustible liquids shall be maintained by the owner or operator of such tank. The procedures for inventory control are as follows:
 - (1) FM-2809.1. Daily inventory records shall be kept for each tank at each location by the operator. Such records shall be available at the location for inspection at any time by a proper authority and shall cover at least ninety days prior to the date of inspection.
 - (2) FM-2809.2. The inventory referred to in paragraph (J)(1) above shall be based on the actual measurement of tank liquid levels daily. The written record of such testing shall include a computation of daily gain or loss. The operator of the location shall be responsible for taking action to correct any abnormal loss or gain not explainable by temperature variations or other causes. Such abnormal loss or gain shall be reported promptly by the operator to the local fire official and fire marshal pursuant to paragraph (K) of this rule (FM-2810.0).
 - (3) FM-2809.3. The mere recording of pump meter readings combined with shipment records shall not constitute adequate inventory records for the purpose of this rule.
 - (4) FM-2809.4. Exemptions. The requirements for daily inventory records shall not apply in the following situations:

- (a) Daily inventories are not required to be maintained when an installation is not in operation, except that during such an operation when an inventory must be taken at least once every seven days.
 - (b) Daily inventories need not be maintained for storage tanks connected to oil burning equipment.
 - (c) Daily inventories need not be maintained for storage tanks connected to manufacturing equipment.
- (5) FM-2809.5. The following actions shall be taken by the operator daily:
- (a) The operator shall record all meter totalizer readings, immediately gauge and record all tank measurements and balance inventory and product transferred.
 - (b) The operator shall record and make adjustments for all transfers of product occurring during gauging period.
 - (c) The operator shall retain all of the aforementioned records.
 - (d) The operator shall check all tanks for water. Experience will indicate whether daily checks are required or if they can be made less frequently. In any circumstances, the check must be made once a week. Tanks should be checked for water after a thaw and after a delivery.
- (K) Section FM-2810.0. Underground storage tank release reporting and confirmation.
- (1) FM-2810.1. Suspected releases requiring reporting. All owners and operators of underground storage tank containing flammable or combustible liquids shall report within twenty-four hours to the fire official and the fire marshal any of the following conditions:
- (a) Test, sampling, or monitoring results from a release detection method specified under paragraph (J) of this rule (FM-2809.0), Or any other release detection method used, that indicates a release may have occurred;
 - (b) Unusual operating conditions such as erratic behavior of product dispensing equipment, the sudden loss of product from a tank system, an unexplained presence of water in the tank or the physical presence of water in the tank, or the physical presence of the regulated substance or an unusual level of vapors on the site that are of an unknown origin;
 - (c) Impacts in the surrounding area, such as evidence of regulated substances or resulting vapors in soils, basements, sewer and utility lines, and nearby surface water;
 - (d) An indication from a gas chromatography or equivalent method that there is a concentration of at least one hundred parts per million of total hydrocarbons in a soil sample; and
 - (e) Any spill or overflow of petroleum that exceeds twenty-five gallons or causes a sheen on any surface water. Any spill or overflow of petroleum of twenty-five gallons or less must be contained and cleaned up immediately, and if such cleanup cannot be accomplished within twenty-four hours, the fire official and the fire marshal shall be notified within twenty-four hours of the spill or overflow.
- (2) FM-2810.2. Release investigation and confirmation. Unless corrective action is initiated by the owner or operator under rule 1301:7-7-36 of the Administrative Code for releases of petroleum, or as otherwise directed by the fire marshal, all suspected releases requiring reporting under this paragraph must be immediately investigated by the owner or operator using one of the following applicable procedures of this paragraph. Confirmation of a petroleum release by one of these methods will require the owner and operator to comply with the requirements for corrective action under rule 1301:7-7-36 of the Administrative Code.

- (a) In the case of an underground storage system having secondary containment, an investigation of a possible release into the interstitial area between the underground storage tank and the secondary barrier using procedures that will determine if the interstitial monitoring is working properly;
- (b) In the case of a failed tank or piping tightness test, an investigation in the following manner:
 - (i) A check of inventory records to detect a discrepancy that indicates a release may have occurred in accordance with the requirements of paragraph (J) of this rule.
 - (ii) Isolation from the tank and retesting of the piping within seven days of the initial reporting to the fire marshal to determine if a release may have occurred in accordance with the requirements in paragraph (J) of this rule;
 - (iii) Isolation from the piping and retesting of the tank within seven days of the initial reporting to the implementing agency to determine if a release may have occurred in accordance with the requirements in paragraph (J) of this rule (after the top of the tank has been excavated and all loose fitting vent pipes or other equipment has been checked, replaced or tightened); and
 - (iv) Analysis of soil core samples for hydrocarbon and/or chemical contamination in the unsaturated zone under the underground storage tank system, or, when the ground water is no more than twenty feet from the ground surface, analysis of ground-water samples for hydrocarbon and/or chemical contamination.
- (c) In the case of a discrepancy during inventory reconciliation in accordance with paragraph (J) of this rule, or any other suspected release, an investigation conducted in the following manner:
 - (i) A tightness test of the tanks and piping that is conducted within seven days of the initial reporting to the fire marshal to determine if a release may have occurred; and
 - (ii) Analysis of soil core samples for hydrocarbon and/or chemical contamination in the unsaturated zone under the underground storage tank system, or, when the ground water is no more than twenty feet from the ground surface, analysis of ground-water samples for hydrocarbon and/or chemical contamination.
- (d) A site-specific investigation, under the direction of the fire marshal, of the suspected release incident to determine if a release has occurred and reached soils outside of the excavation zone or ground water;
- (e) Any other investigation procedure that is no less stringent than any of the procedures in paragraphs (a) to (c) of this rule and is approved for that underground storage tank system by the fire marshal.

Effective: 5/9/88

Original Signed
Certification

April 29, 1988
Date

Promulgated Under: 119.03 + 3737.86
Authorized By: 3737.02 + 3737.82
Amplifies: 3737.82
Prior Effective Date: 7/1/79
6/1/85.

1301:7-7-36. CORRECTIVE ACTIONS AND COST RECOVERY STANDARDS FOR PETROLEUM UNDERGROUND STORAGE TANK RELEASES.

(A) General

- (1) Purpose. For the purpose of prescribing rules pursuant to section 3737.88 of the Revised Code, the fire marshal hereby adopts this rule to establish standards for corrective actions for releases of petroleum from underground storage tanks and standards for the recovery of costs for undertaking corrective or enforcement actions with respect to such releases. This rule is adopted by the fire marshal in accordance with Chapter 119. of the Revised Code and shall not be considered a part of the "Ohio Fire Code."
 - (2) Scope. This rule shall apply to any suspected or confirmed release of petroleum from an underground storage tank as defined in paragraph (B) of rule 1301:7-7-35 of the Administrative Code.
 - (3) Requirement. All owners and operators of UST systems, in response to a suspected or confirmed release of petroleum from a UST system, shall comply with the requirements of this rule. These provisions apply to all UST systems containing petroleum as defined in paragraph (B) of rule 1301:7-7-35 of the Administrative Code.
 - (4) Fire marshal corrective actions. All corrective actions undertaken by the fire marshal or assistant fire marshal pursuant to division (A)(3) of section 3737.88 of the Revised Code shall be consistent with the requirements of this rule.
- (B) Definitions. When used in this rule, the terms shall have the same meaning as those defined in paragraph (B) of rule 1301:7-7-35 of the Administrative Code.
- (C) Initial abatement requirements, procedures, and evaluation.
- (1) Suspected release confirmation. All suspected releases requiring reporting under paragraph (K) of rule 1301:7-7-28 of the Administrative Code shall be investigated and confirmed or disproved by the owner or operator in a manner consistent with paragraph (K) of rule 1301:7-7-28 of the Administrative Code to establish whether the corrective action requirements of this rule shall be followed.
 - (2) Upon confirmation of an actual release in accordance with paragraph (K) of rule 1301:7-7-28 of the Administrative Code, or discovery of a release in any other manner, the owners and operators shall:
 - (a) Report the release to the fire official and fire marshal within twenty-four hours pursuant to paragraph (K) of rule 1301:7-7-28 of the Administrative Code;
 - (b) Stop any further release from the UST system;
 - (c) Mitigate all fire, explosion, and safety hazards;
 - (d) Remove and properly dispose of all visibly contaminated soil and any associated groundwater from the excavation zone;
 - (e) Conduct an investigation to determine the possible presence of free product and initiate removal of any free product found as soon as practicable;
 - (f) Report all initial corrective action taken pursuant to this paragraph, including a verification of tank repair or closure if appropriate, to the fire official and the fire marshal within twenty days of the confirmation or discovery of the release.
 - (3) Site investigation. The owner and operator shall perform a site investigation for contaminated soil, groundwater, or free product and shall assemble from such an investigation, or from other sources (e.g., USGS maps, SCS soil maps, ODNR, OEPA, and other agencies), any information deemed necessary by the fire marshal. The site investigation and information shall include, but is not limited to, the following:

- (a) Data on the nature and estimated quantity of the released substance;
 - (b) Data from surface and subsurface soil sampling and analyses;
 - (c) Data from groundwater and/or surface-water sampling and analyses; and
 - (d) Data from available sources and/or site investigations concerning background levels prior to the release, water quality and use, well locations, subsurface soil conditions, climatological conditions, land use, and surrounding populations.
- (4) Reporting. The results of this site investigation and all required information shall be reported to the fire marshal within twenty days of the confirmation or discovery of the release unless otherwise directed by the fire marshal. The fire marshal may request the collection and submission of additional information and/or a corrective action plan for additional soil, surface-water, and groundwater cleanup.
- (D) Free product removal. At sites where an owner or operator's investigations under paragraph (C)(2) of this rule indicate the presence of a free product, the owner or operator shall remove free-floating product to the maximum extent practicable while continuing, as necessary, any action initiated under paragraph (C) of this rule, and while preparing for subsequent actions required under paragraph (E) or (F) of this rule. In meeting the requirements of this paragraph, the owner or operator shall:
- (1) Conduct free product recovery in such a manner that such actions do not spread contamination into previously uncontaminated areas through untreated discharge or improper disposal techniques.
 - (2) Conduct free product recovery in such a manner that such actions do not produce vapors in the atmosphere at levels such that they pose a health and safety threat to previously uncontaminated areas.
 - (3) Handle any flammable products in a safe and competent manner to prevent fires or explosions.
 - (4) Unless directed to do otherwise by the fire marshal, prepare and submit, within thirty days of the confirmation or discovery of the release, a free product removal report to the fire marshal. The report shall provide, but is not limited to, the following information:
 - (a) The name of the person(s) responsible for implementing the plan;
 - (b) The estimated quantity and type of product on site and the product thickness in wells, boreholes, and excavations;
 - (c) Details of the product recovery system;
 - (d) Whether any discharge will take place on or off site during the recovery operation;
 - (e) The type of treatment and expected effluent quality from any discharge; and
 - (f) The disposition of the recovered product.
- (E) Site assessment. Whenever an investigation under paragraph (C)(3) of this rule indicates that there may be remnant soil contamination from the release, or that the released product or product from contaminated soil may have reached groundwater, or as otherwise directed by the fire marshal, the owners and operators shall:
- (1) Conduct additional investigations of the release, the release site, and the surrounding area possibly affected by the release, to determine the full extent and location of the soils contaminated by the release.
 - (2) Conduct additional investigations of the release, the release site, and the surrounding area possibly affected by the release to determine the presence of dissolved contamination due to the release in the ground water.

- (3) When directed by the fire marshal, conduct an exposure assessment to determine the extent of exposure of, or potential for exposure of, individuals to petroleum from the release. Such assessment shall be based on such factors as the nature and extent of contamination and the existence of or potential for pathways of human exposure, the size of the community within the likely pathways of exposure, and the comparison of expected human exposure levels to the short-term and long-term health effects associated with identified contaminants and any available recommended exposure or tolerance limits for such contaminants.
 - (4) The information collected by the owners and operators during the course of the investigations under this paragraph shall be submitted in accordance with a schedule established by the fire marshal.
 - (5) The fire marshal may request the submission of a corrective action plan for additional soil and/or ground-water cleanup.
- (F) Soil and ground-water cleanup.
- (1) Owners and operators required by the fire marshal under this rule to develop and submit a corrective action plan for responding to any contaminated soils, surface waters, or ground waters shall submit such a plan according to a schedule established by the fire marshal.
 - (2) The fire marshal shall approve the corrective action plan only if it assures that implementation of the plan will provide adequate protection of human health, safety, and the environment. In making this determination, the fire marshal shall consider:
 - (a) The physical and chemical characteristics of the petroleum substance, including its toxicity, persistence, and potential for migration;
 - (b) The hydrogeologic characteristics of the facility and the surrounding land;
 - (c) The proximity, quality, and current and future uses of ground water and surface waters; and
 - (d) The results of an exposure assessment when such an assessment is required.
 - (3) Upon approval of the corrective action plan, the owners and operators shall implement the plan and monitor, evaluate, and report the results of implementation, as required by the fire marshal.
- (G) Public participation.
- (1) Corrective action plans. For each corrective action plan submitted to the fire marshal under paragraph (F) of this rule, and prior to the approval of such plan, the fire marshal shall provide an opportunity for public review and comment on the plan. The fire marshal shall provide notice to the public by means designed to reach those members of the public most directly affected by the release and the planned corrective action. Public notice shall provide adequate time for the review of the submitted plan by the affected public. Such notice may include, but is not limited to, public notice in local newspapers, including block advertisements, public service announcements, or letters to individual households.
 - (2) If there is sufficient public interest, or for any other reason, the fire marshal may hold a public meeting to consider comments on the corrective action plan. The fire marshal shall hold a public meeting in any case where implementation of an approved corrective action plan does not achieve the established cleanup levels and termination of that plan is under consideration by the fire marshal.
 - (3) In deciding whether to approve or modify the corrective action plan, the fire marshal shall consider and respond to the comments from the public.
- (H) Owner or operator liable for costs. The owner or operator of an underground storage tank from which a release of petroleum has occurred is liable to the state for any costs incurred for any corrective or enforcement action undertaken by the fire marshal, assistant fire marshal, or attorney general, that

is conducted pursuant to section 3737.88 of the Revised Code. The liability under this paragraph shall be construed to be the standard of liability which obtains under section 311 of the Federal Clean Water Pollution Act.

- (1) Cost recovery. In determining the equities for seeking the recovery of costs under this rule, the fire marshal may consider the amount of financial responsibility required to be maintained under subsections (C) and (D)(5) of section 9003 of the Resource Conservation and Recovery Act, as amended, and the factors considered in establishing such amount under subsection (D)(5) of such act.
- (2) Effect on liability.
 - (a) No transfer of liability. No indemnification, hold harmless, or similar agreement or conveyance shall be effective to transfer from the owner or operator of any underground storage tank or from any person who may be liable for a release or threat of release under this paragraph, to any other person the liability imposed under this paragraph.
 - (b) No bar to cause of action. Nothing in this paragraph, including the provisions of paragraph (H)(2)(a) of this rule, shall bar a cause of action that an owner or operator or any person subject to liability under this rule, or a guarantor, has or would have, by reason of subrogation or otherwise against any person.

Effective: 5/9/88

ORIGINAL SIGNED
certification

APRIL 29, 1988
date

promulgated under: 119.03 + 3737.86
Authorized by: 3737.88
Amplifies: 3737.88
Prior effective date: none.

Sec. 3737.882. (A) If, after an examination or inspection, the fire marshal or an assistant fire marshal finds that a release of petroleum is suspected, he shall take such action as he considers necessary to ensure that a suspected release is confirmed or disproved and, if the occurrence of a release is confirmed, to correct the release. These actions may include one or more of the following:

(1) Issuance of a citation and order requiring the responsible person to undertake, in a manner consistent with the requirements of section 9003 of the "Resource Conservation and Recovery Act of 1976," 98 Stat. 3279, 42 U.S.C.A. 6991b, as amended, applicable regulations adopted thereunder, and rules adopted under division (B) of this section, such actions as are necessary to protect human health and the environment, including, without limitation, the investigation of a suspected release.

(2) Requesting the attorney general to bring a civil action for appropriate relief, including a temporary restraining order or preliminary or permanent injunction, in the court of common pleas of the county in which a suspected release is located or in which the release occurred, to obtain the corrective action necessary to protect human health and the environment. In granting any such relief, the court shall ensure that the terms of the temporary restraining order or injunction are sufficient to provide comprehensive corrective action to protect human health and the environment.

(3) Entry onto premises and undertaking corrective action with respect to a release of petroleum if, in his judgment, such action is necessary to protect human health and the environment. Any corrective action undertaken by the fire marshal or assistant fire marshal under division (A)(3) of this section shall be consistent with the requirements of sections 9003 and 9005 of the "Resource Conservation and Recovery Act of 1976," 98 Stat. 3279, 42 U.S.C.A. 6991b, and 98 Stat. 3284, 42 U.S.C.A. 6991e, respectively, as amended, applicable regulations adopted thereunder, and rules adopted under division (B) of this section.

(B) The fire marshal shall adopt, and may amend and rescind, such rules as he considers necessary to establish standards for corrective actions for suspected and confirmed releases of petroleum and standards for the recovery of costs incurred for undertaking corrective or enforcement actions with respect to such releases. The rules also shall include requirements for financial responsibility for the cost of corrective actions for and compensation of bodily injury and property damage incurred by third parties that are caused by releases of petroleum. Rules regarding financial responsibility shall, without limitation, require responsible persons to provide evidence that the parties guaranteeing payment of the deductible amount established under division (E) or (F) of section 3737.91 of the Revised Code are, at a minimum, secondarily liable for all corrective action and third-party liability costs incurred within the scope of the deductible amount. The rules shall be consistent with sections 9003 and 9005 of the "Resource Conservation and Recovery Act of 1976," 98 Stat. 3279, 42 U.S.C.A. 6991b, and 98 Stat. 3284, 42 U.S.C.A. 6991e, respectively, as amended, and applicable regulations adopted thereunder.

(C)(1) No person shall violate or fail to comply with a rule adopted under division (A) of section 3737.88 of the Revised Code or division (B) of this section, and no person shall violate or fail to comply with the terms of any order issued under division (A) of section 3737.88 of the Revised Code or division (A)(1) of this section.

(2) Whoever violates division (C)(1) of this section or division (F) of section 3737.881 of the Revised Code shall pay a civil penalty of not more than ten thousand dollars for each day that the violation continues. The fire marshal may, by order, assess a civil penalty under this division, or he may request the attorney general to bring a civil action for imposition of the civil penalty in the court of common pleas of the county in which the violation occurred. If the fire marshal determines that a responsible person is in violation of division (C)(1) of this section or division (F) of section 3737.881 of the Revised Code, the fire marshal may request the attorney general to bring a civil action for appropriate relief, including a temporary restraining order or preliminary or permanent injunction, in the court of common pleas of the county in which the underground storage tank or, in the case of a violation of division (F)(3) of section 3737.881 of the Revised Code, the training program that is the subject of the violation is located. The court shall issue a temporary restraining order or an injunction upon a demonstration that a violation of division (C)(1) of this section or division (F) of section 3737.881 of the Revised Code has occurred or is occurring.

Any action brought by the attorney general under this division is a civil action, governed by the rules of civil procedure and other rules of practice and procedure applicable to civil actions.

(D) Orders issued under division (A) of section 3737.88 of the Revised Code and divisions (A)(1) and (C) of this section, and appeals thereof, are subject to and governed by Chapter 3745. of the Revised Code. Such orders shall be issued without the necessity for issuance of a proposed action under that chapter. For purpose of appeals of any such orders, the term "director" as used in Chapter 3745. of the Revised Code includes the fire marshal and an assistant fire marshal.

Sec. 3737.99

(I) Whoever knowingly violates division (C) of section 3737.882 of the Revised Code is guilty of an unclassified felony and shall be fined not more than twenty-five thousand dollars or imprisoned for not more than fourteen months, or both. Whoever recklessly violates division (C) of section 3737.882 of the Revised Code is guilty of a misdemeanor of the first degree.

OHIO DEPARTMENT OF COMMERCE
DIVISION OF STATE FIRE MARSHAL
BUREAU OF UNDERGROUND STORAGE TANK REGULATIONS

CORRECTIVE ACTION GUIDANCE
FOR PETROLEUM RELEASES

January 15, 1988

Section 3737.88 of the Ohio Revised Code requires that when the State Fire Marshal finds that a release of petroleum from an underground storage tank has occurred, he shall take actions necessary to protect human health and the environment.

This list of corrective action steps for petroleum releases from UST systems have been prepared to assist UST owners and operators in conducting the corrective action activities required by the State Fire Marshal when a release is discovered. Nothing in this guidance is intended to supercede any action taken by the Fire Marshal or any other local, state, or federal agency or regulation, nor does this list relieve the UST system owner or operator from compliance with any applicable local, state or federal regulations.

General Requirements

These requirements apply to any suspected or confirmed release of petroleum from an underground storage tank. All owners and operators of UST systems, in response to a suspected or confirmed release of petroleum from an UST system, shall comply with these requirements.

Unless otherwise indicated, all reports required by the State Fire Marshal must be submitted in writing to:

Ohio Division of State Fire Marshal
Bureau of Underground Storage Tank Regulation
7510 East Main Street
P.O. Box 525
Reynoldsburg, Ohio 43068-3395

Suspected Release Confirmation

- (A) All suspected releases of petroleum from UST systems must be reported to the local fire department and the State Fire Marshal within 24 hours of their discovery. The report to the State Fire Marshal may be made by calling 614-752-7938 or 1-800-686-2878.

Any suspected release that affects surface or drinking water supplies must be reported to the Ohio Environmental Protection Agency at 1-800-282-9378.

Any suspected release that threaten's Ohio's wildlife must be reported to the Ohio Department of Natural Resources at 614-265-4300.

- (B) Suspected releases must be immediately investigated and either confirmed or disproved by a method acceptable to the local fire department and the State Fire Marshal.
- (C) If a suspected release is confirmed, the owners and operators of the UST system must undertake all required corrective actions.

Initial Corrective Actions

The following steps must be taken at all confirmed petroleum releases sites:

- (A) Upon confirmation of an actual release, or discovery of a release in any other manner, the owners and operators of the UST system must:
 - (1) Report the confirmed releases to the local fire department and the State Fire Marshal within twenty-four hours.
 - (2) Stop any further release from the UST system;
 - (3) Mitigate all fire, explosion, and safety hazards;
 - (4) Remove and properly dispose of all visibly contaminated soil and any associated groundwater from the excavation zone. The disposal of contaminated soil or water must comply with all applicable local, state and federal regulations;
 - (5) Conduct an investigation to determine the possible presence of free product and initiate removal of any free product found as soon as practicable;
 - (6) Report all initial corrective action taken, including a verification of tank repair or closure if appropriate, to the local fire department and the State Fire Marshal within twenty days of the confirmation or discovery of the release.
 - (7) All UST system repairs, removals, abandonment, installation, and replacement must comply with the requirements of the Ohio Fire Code and all other local and state regulations. The Ohio Fire Code requires a permit from the fire official for all such actions.
- (B) Site investigation. The owner and operator must perform a site investigation for contaminated soil, groundwater, or free product and assemble from the investigation, or from other sources (e.g., USGS maps, SCS soil maps, Ohio Department of Natural Resources Division of Water, Ohio Environmental Protection Agency, and other agencies), any information deemed necessary by the State Fire Marshal. The site investigation and information must include, but is not limited to, the following:
 - (1) Data on the nature and estimated quantity of the released substance;
 - (2) Data from surface and subsurface soil sampling and analyses;

- (3) Data from groundwater and/or surface water sampling and analyses; and
 - (4) Data from available sources and/or site investigations concerning background levels prior to the release, water quality and use, well locations, subsurface soil conditions, climatological conditions, land use, and surrounding populations.
- (C) Reporting. The results of this site investigation and all required information must be reported to the State Fire Marshal within twenty days of the confirmation or discovery of the release unless otherwise directed by the Fire marshal. The State Fire Marshal may request the collection and submission of additional information and/or a corrective action plan for additional soil, surface water, and groundwater cleanup.

Free Product Removal

The following steps must be taken at **all release sites where free product has been found**:

- (A) At sites where an owner or operator's investigations indicate the presence of a free product, the owner or operator must remove free floating product to the maximum extent practicable while continuing, as necessary, all other corrective action steps initiated, and while preparing for subsequent long term corrective actions. In meeting this requirement, the owner or operator shall:
 - (1) Conduct free product recovery in such a manner that such actions do not:
 - (a) spread contamination into previously uncontaminated areas through untreated discharge or improper disposal techniques, or
 - (b) produce vapors in the atmosphere at levels such that they pose a health and safety threat to previously uncontaminated areas.
 - (2) Handle any flammable products in a safe and competent manner to prevent fires or explosions.
- (B) Unless directed to do otherwise by the State Fire Marshal, prepare and submit, within thirty days of the confirmation or discovery of the release, a free product removal report to the State Fire Marshal. The report shall provide, but is not limited to, the following information:
 - (1) The name of the person(s) responsible for implementing the plan;
 - (2) The estimated quantity and type of product on site and the product thickness in wells, boreholes, and excavations;
 - (3) Details of the product recovery system;

- (4) Whether any discharge will take place on or off site during the recovery operation;
- (5) The type of treatment and expected effluent quality from any discharge; and
- (6) The disposition of the recovered product.

Site Assessment

The following steps must be taken at all **release sites where remaining soil or groundwater contamination has been found**:

- (A) Whenever an investigation indicates that there may be remaining soil contamination from the release, or that the released product or product from contaminated soil may have reached groundwater, or as otherwise directed by the State Fire Marshal, the owners and operators must:
 - (1) Conduct additional investigations of the release, the release site, and the surrounding area possibly affected by the release, to determine the full extent and location of the soils contaminated by the release; and
 - (2) Conduct additional investigations of the release, the release site, and the surrounding area possibly affected by the release to determine the presence of dissolved contamination due to the release in the groundwater.
- (B) When directed by the State Fire Marshal, conduct an exposure assessment to determine the extent of exposure of, or potential exposure for exposure of, individuals to petroleum from the release. Such assessment shall be based on such factors as the nature and extent of contamination and the existence of or potential for pathways of human exposure, the size of the community within the likely pathways of exposure, and the comparison of expected human exposure levels to the short-term and long-term health effects associated with identified contaminants and any available recommended exposure or tolerance limits for such contaminants.
- (C) The information collected by the owners and operators during the course of this site assessment shall be submitted in accordance with a schedule established by the State Fire Marshal.
- (D) The State Fire Marshal may request the submission of a corrective action plan for additional soil and/or groundwater cleanup.

Long Term Corrective Action

The following steps must be taken when **long term soil and/or groundwater cleanup** is required by the State Fire Marshal:

- (A) Owners and operators must develop and submit a corrective action plan for responding to any contaminated soils, surface waters, or groundwaters shall submit such a plan according to a schedule established by the State Fire Marshal.
- (B) The State Fire Marshal shall approve the corrective action plan only if it assures that implementation of the plan will provide adequate protection of human health, safety, and the environment. In making this determination, the State Fire Marshal shall consider:
 - (1) The physical and chemical characteristics of the petroleum substance, including its toxicity, persistence, and potential for migration;
 - (2) The hydrogeologic characteristics of the facility and the surrounding land;
 - (3) The proximity, quality, and current and future uses of groundwater and surface waters; and
 - (4) The results of an exposure assessment when such an assessment is required.
- (C) Upon approval of the corrective action plan, the owners and operators shall implement the plan and monitor, evaluate, and report the results of implementation, as required by the State Fire Marshal.
- (D) Public participation.
 - (1) Prior to the approval of each long term corrective action plan submitted, the State Fire Marshal will provide an opportunity for public review and comment on the plan.
 - (2) If there is sufficient public interest, or for any other reason, the State Fire Marshal may hold a public meeting to consider comments on the corrective action plan. A public meeting will be conducted in any case where implementation of an approved corrective action plan does not achieve the established cleanup levels and termination of that plan is under consideration.
 - (3) In deciding whether to approve or modify the corrective action plan, the fire marshal will consider and respond to the comments from the public.

Cost Recovery

The owner or operator of an underground storage tank from which a release of petroleum has occurred is liable to the state for any costs incurred for any corrective or enforcement action undertaken by the State that is conducted pursuant to section 3737.88 of the Ohio Revised Code.

cc: N. Wulff
W. Carkido
T. Chanda
File



RAVENNA ARSENAL INC.

8451 STATE ROUTE 5
RAVENNA, OHIO 44266-9297

Telephone (216) 358-7111

Autovon 346-3210

February 8, 1990

THRU: Contracting Officer's Representative
Ravenna Army Ammunition Plant
8451 State Route 5
Ravenna, Ohio 44266-9297

TO: Commander
U. S. Army Armament, Munitions and Chemical Command
ATTN: AMSMC-PCG-B (Shirlene Wise)
Rock Island, IL 61299-6000

Subject: Specification For Removal of Four (4) Ea. Underground
Storage Tanks (USTs)
(Ref. Phone Conversation on 1 Feb. 1990 @ 1400 Hrs. SAB)

Dear Sir:

Attached are the specifications for removal of the four (4) USTs which failed their required tank tightness tests. The four tanks are as follows:

1. Tank 33 DEAC
2. Tank 23 Bldg. 1045
3. Tank 22 Rail Yard
4. Tank 11 Rail Yard

The specifications were written by a consulting engineering firm registered in the State of Ohio. The specifications were originally drawn up for the removal of 12 registered USTs declared abandoned at the Ravenna Army Ammunition Plant, but may be used for the removal of any UST at the RVAAP.

Sincerely,

RAVENNA ARSENAL, INC.

H. R. Cooper
Plant Engineer

HRC/WAC/wt/wc90002

Attachment

2/8/90 @ 17:15 hrs.

Sue,

I spoke to a Sam Reed Fm/ R & R last night. ChemTron their sludge disposer, requires a sludge characteristic profile be performed; which includes PCB analysis. He said we could sign a waiver to dispense Fm/ PCB Analysis if we would provide statement that there wasn't any PCBs in the sludge. I said No, we would not sign such a waiver being that we really don't know what's been dumped into those tanks other than fuel oil. The problem is that neither of us know if the tank removal specs. (he's got a copy) specifically call for PCB analyses or if the specs. state the responsibility of the contractor to perform all required analyses upon the sludge to assure proper disposal. In any case, if the specs. in some manner don't put the responsibility of costs upon the contractor to test for PCBs then this will be interpreted as an additional cost. If it's determined to be an additional cost, he's been advised to contact Jenkins before PCB analysis is performed. I think!!! There is a general statement to the effect that the contractor is responsible for all required analyses upon the sludge. I've put the tank removal plan on your desk. Let Jenkins & Wayne ^{know} of this discussion in case Reed feels this is an additional cost.


Also, Reed said, since ChemTron wants to perform an analytical profile on the sludge, the 5 drums can't be taken off site for disposal. Reed assured me the drums were weather & spill protected — You or Wayne might want to check this out.

Have a Nice Day

Chenda Fm/ R & BWA



Message 11



Date: FRI, 02 FEB 90 09:18:41 CST

From: Robert J. Kasper <ORVAAP@RIA-EMH1.ARMY.MIL>

To: op01@ria-emh1.army.mil, oppxpg@ria-emh1.army.mil, oincdr@ria-emh1.army.mil

SMCRV-CR (200)

2 February 1990

MEMORANDUM FOR Commander, U.S. Army Armament, Munitions and Chemical Command,
ATTN: AMSMC-PL/Mr. Woodhouse, Rock Island, IL 61299-6000

SUBJECT: Update on Underground Storage Tanks Testing/Removal, RVAAP

1. Status of original project for removal of 12 abandoned USTs.
 - a. Ground cover removed and all tanks exposed.
 - b. Hazardous hauler to drain and remove any remaining material, 2 Feb 90.
 - c. State Fire Marshal to inspect 5 Feb 90.
 - d. If State Fire Marshal approves, cleaning of the tanks to begin.
 - e. State Fire Marshal to inspect after cleaning. Upon Fire Marshal's approval, removal will begin with a projected completion date of 30 Mar 90 for all tanks.
2. An additional 8 tanks that were in service were tested. 3 tanks were found to be leaking and were drained and required removal. A 4th tank requires removal with the 3 leaking tanks because it is adjacent to one of the leaking tanks and will have to be removed with the leaking tank. The 4th tank was considered in the cost estimate for removal. It was also drained. Status of removal of the 4 tanks is as follows.
 - a. \$94,000 has been funded for removal of 4 tanks.
 - b. Subcontract to be let 2 Feb 90.
 - c. Same procedures with State Fire Marshal inspection/approval apply as for 12 tanks in paragraph 1 above.
 - d. Estimated completion for removal of additional 4 tanks is also 30 Mar 90.
3. Request for 20 day leniency extension from the Division of State Fire Marshal, Ohio Department of Commerce to complete removal was verbally approved 1 Feb 90.
4. POC is Mr. John Cicero, AUTOVON 346-3127.

FOR THE COMMANDER:

ROBERT J. KASPER
Commander's Representative

CF:
Cdr, INAAP

TELEPHONE CONVERSATION RECORD

DATE: February 1, 1990

PERSON CALLING: Michelle Tarka
Site Coordinator
Div. State Fire Marshal


PHONE:

PERSON CALLED: H. R. Cooper
Plant Engineer

PHONE: 297-3240

SUBJECT: Request For Extension of Time to Complete
Investigation of Leaking UST
Ref. Ltr. Dated 30 Jan. 1990

Ms. Tarka called to say that there are no problems with our request for a 20 day extension.


H. R. Cooper

cc: COR RVAAP Office
N. Wulff
T. Chanda
W. Carkido
File

hcust.pr

CC-M. Chan So
W. C. K. So
f-e P.02

UNCLAS

01 01 011520Z FEB 90 RR UUUU 0311400

CDR AMCCOM ROCK ISL IL//AMSMC-PCG-B (R)//

FEB 01 1990

CDR RVAAP RAVENNA OH//SMCRV-CA//

N. WULFF

UNCLAS (715K)

SGD EMIL E. MASLANKA, CONTRACTING OFFICER

SUBJ UNILATERAL OBLIGATION OF FUNDS

1. THE FOL IS UNIL OBLIG FOR PERFORMANCE UNDER CONTRACT DAAA09-88-Z-0001:

CLIN: 0046AE PRON: M10PF628M1G2/01

ACRN: UNK AMS-CD: 4211052910**4210052910

ACCTG CLASS: 21-02034-0658251P4210-2572-S11173

AMT OBLIG: \$94,000.00 CUM CLIN AMT: \$94,000.00

DESC: FY 90 ENVIRONMENTAL RESTORATION PROJECT 5902910-04,
UNDERGROUND STORAGE TANK REMOVAL IAW RAI LETTERS OF 16, 19, AND
26 JAN 90.

2. THIS ACTION WILL BE FORMALIZED ON P00092.


3. REQUEST CONTRACTOR'S ACK OF RECEIPT OF THIS MSG.

4. POC IS SHIRLENE WISE, AMSMC-PCG-B (R), AUTOVON 793-3359. *2-1-90*

AMSMC-PCG (R)
AMSMC-PCG-B (R)
AMSMC-PDP-B (R)

AMSMC-CPF-LG (R)
AMSMC-BPA-P (R)

MS. WISE/CONTR SPEC/
AMSMC-PCG-B (R)/23359



TO	OFFICE	ACTION
<i>C</i>		
<i>C</i>		
	SAF	
	CPM	
	RETURN	

EMIL E. MASLANKA, CONTR OFF, AMSMC-PCG-B (R), 26628

UNCLAS

cc: N. Wulff
T. Chanda
W. Carkido
File



RAVENNA ARSENAL INC.

8451 STATE ROUTE 5
RAVENNA, OHIO 44266-9297

Telephone (216) 388-7111

Autovon 346-3210

January 30, 1990

THRU: Contracting Officer's Representative
Ravenna Army Ammunition Plant
8451 State Route 5
Ravenna, Ohio 44266-9297

TO: Ohio Department of Commerce
Division of State Fire Marshal
Bureau of Underground Storage Tank Regulations
ATTN: Michelle Tarka, Site Coordinator
7510 East Main Street
P.O. Box 525
Reynoldsburg, Ohio 43068-3395

Subject: Request For Extension Of Time To Complete Investigation
Of Leaking UST

Dear Ms. Tarka:

Your office has been notified about three tanks which failed their tank tightness tests.

The tanks were drained as soon as the test results were known. The earth surrounding the tanks are generally low permeability clay.

These tanks were included in a project to test eight tanks at the Ravenna Army Ammunition Plant. After each of the first tanks failed, the plant requested funding from the Army Command Headquarters to remove the tanks to comply with the requirements of OAC Rule 1301:7-7-36.

The command waited for the results of the last leak test so that it could be included in the same project if it failed. It failed its test on January 26, 1990.

We hereby request a 20 day extension to the allowed time of 20 days to remove a tank. The extension is requested for each tank. This will allow for the time delay in funding the removal of the first tanks while waiting on the results of the third test. It will also allow for approximately one week to process a contract modification and for the fact that the contractor has three tanks to remove almost simultaneously. We expect to have the tanks removed and the required samples taken by the requested extended deadlines.

Extension of Time for UST

-2-

A summary of the proposed dates are as follows:

	<u>Date Reported</u>	<u>20 Days</u>	<u>20 Day Extension</u>
Tank No. 33	January 15	Feb. 4	February 24
Tank No. 23	January 19	Feb. 8	February 28
Tank No. 11	January 26	Feb. 15	March 7

Sincerely,

RAVENNA ARSENAL, INC.



H. R. Cooper
Plant Engineer

HRC/wt/hc90008

cf: AMCCOM
AMSMC-PCG-B (Shirlene Wise)

AMCCOM
AMSMC-ISE-M (Ms. Ronnie DePorter)

cc: N. Wulff
R. Holford
J. Melnik
T. Chanda
File



RAVENNA ARSENAL INC.

8451 STATE ROUTE 5
RAVENNA, OHIO 44266-9297

Telephone (216) 358-7111

Autovon 346-3210

January 29, 1990

THRU Contracting Officer's Representative
Ravenna Army Ammunition Plant
8451 State Route 5
Ravenna, OH 44266-9297

TO Commander
U.S. Army Armament, Munitions and Chemical Command
Attn: AMSMC-ISE-M (Mr. Dennis Versluys)
Rock Island, IL 61299-6000

Subject: Reporting of a #2 Fuel Oil Leak from RVAAP's Underground Storage Tank
(UST), #RV22-Rail Yard Building 47-40; Following 26 January 1990
Failure to Pass State Required Tank Tightness Test

Dear Sir:

Attached is completed DARCOM Form 2647-R in response to subject leak incident.

This installation's point of contact will be Thomas M. Chanda, Environmental
Engineer, Autovon 346-3221.

Sincerely,

RAVENNA ARSENAL, INC.

H. R. Cooper
Plant Engineer

HRC:TMC:ade:TMC90002
Attachment

cf: INAAP
Attn: Col. Miller

1 February 1983

DARCOM Suppl 1 to AR 200-1

TELEPHONIC NOTIFICATION OF POLLUTION INCIDENT (ALL TIMES ARE LOCAL TIMES)		DATE/TIME REPORT RECEIVED
1. INSTALLATION Ravenna Army Ammunition Plant		26 January 1990
2. INSTALLATION COMMANDER Mr. Robert J. Kasper, Commander's Rep.		
3. PERSON REPORTING INCIDENT (Include Phone No. and Ext) T.M. Chanda AV 346-3221	4. PERSON RECEIVING REPORT (Include Office and Ext) Mr. Dennis Versluys AMSMC-ISE-M AV743-1870	5. INCIDENT DISCOVERY DATE AND TIME 26 January 1990 At 1430 Hrs.
NATURE OF INCIDENT		
6. TYPE AND AMOUNT OF MAT AND SOURCE No. 2 Fuel Oil at 0.353 Gals./Hr (0.05 gals/Hr max allowable)	7. SEVERITY <input type="checkbox"/> MINOR <input type="checkbox"/> MEDIUM <input type="checkbox"/> MAJOR <input type="checkbox"/> REPORTABLE <input checked="" type="checkbox"/> NON REPORTABLE	8. PERSONNEL INJURIES/PROPERTY LOSS None
9. CAUSE Tank tightness test failure Administered under regulatory standards	10. EQUIP/FAC INVOLVED (Location and Specific area) Railroad yard at Bldg. 47-40 - 15000 gal underground storage tank RV #22 - R.R. locomotive fueling station.	
11. DURATION/MAGNITUDE OF POLLUTION PRODUCED/RELEASED		
a. SOURCE OF RELEASE BEEN STOPPED. <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		
b. RELEASED MATERIAL BEEN RETAINED. <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		
c. REACH INTO NAVIGABLE WATERS. <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		
d. NAME OF RECEIVING STREAM OR WATERS. N/A		
e. PASS THE INSTALLATION BOUNDARY. <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		
f. NPDES PERMIT POINTS INVOLVED. <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO SPECIFY.		
g. SAMPLE BEING TAKEN FOR LEGAL RECORD. <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		
12. DAMAGE/IMPACT ON SURROUNDINGS (Ground water, wildlife, etc.) Contamination of subsurface soils within immediate area of Underground Storage Tank; vertical & horizontal migrational path unknown till remedial action undertaken.		
13. REMEDIAL ACTION TAKEN Product removed from tank immediately following tank tightness test failure; submitted funding request to AMCCOM PCO to implement remedial action.		
14. REMEDIAL ACTION PLANNED Tank & contaminated soil removal; soil sampling & analysis to determine extent of migrational path with subsequent abatement response.		15. DATE OF REMEDIAL ACTION COMPLETION (est or actual) By State 16 FEB 1990 STDS.
16. NOTIFICATIONS		
a. REGIONAL EPA. <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO WHEN?		
b. STATE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> WHEN? 26 January 1990		
c. COAST GUARD OR NATIONAL RESPONSE CENTER (800-424-8802) <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO WHEN?		
d. NEXT HIGHER HQ <input type="checkbox"/> <input type="checkbox"/> YES <input type="checkbox"/> NO WHEN?		
17. REACTION BY NEWS MEDIA/PUBLIC None		
18. DOLLAR VALUE OF MATERIAL SPILLED Unknown due to discovery of leak only after administering leak.	19. TOTAL COST CLEANUP ACTIVITIES (Est or Actual) \$59,000. (est.)	
DISTRIBUTION	<input checked="" type="checkbox"/> AMCCOM, AMSMC-ISE <input checked="" type="checkbox"/> RVAAP COR	<input checked="" type="checkbox"/> RVAAP CO. <input checked="" type="checkbox"/> RAI

TELEPHONE CONVERSATION RECORD

DATE: January 26, 1990

FROM: SUSAN MCCAUSLIN, ENVIRONMENTAL SPECIALIST PHONE 216-297-3220

TO: TODD PARFITT, STATE FIRE MARSHALL'S OFFICE PHONE 1-800-686-2878

SUBJECT: TANK TEST FAILURE, TANK #22 RAIL YARD

I called B.U.S.T. and spoke with Todd parfitt to report the tank leak test failure of Tank #22. Todd recorded all needed information and requested we mail him a map of the facility indicating the location of the leaking tanks.



Susan McCauslin

SM:ade:012690.PR

cc: N. Wulff
B. Jenkins
D. Kanavy
T. Chanda
W. Carkido
File



RAVENNA ARSENAL INC.

8451 STATE ROUTE 5
RAVENNA, OHIO 44266-9297

Telephone (216) 358-7111

Autovon 346-3210

January 26, 1990

THRU: Contracting Officer's Representative
Ravenna Army Ammunition Plant
8451 State Route 5
Ravenna, Ohio 44266-9297

TO: Commander
U. S. Army Armament, Munitions and Chemical Command
ATTN: AMSMC-PCG-B (Shirlene Wise)
Rock Island, IL 61299-6000

Subject: Corrective Action - Leaking Underground Storage Tank
Ref. RAI Letter January 16, 1990, Same Subject
RAI Letter January 19, 1990, Same Subject

Dear Sir:

The referenced letter advised you of the failure of a tank tightness test on two tanks during the testing of eight underground Storage Tanks at Ravenna AAP.

On the afternoon of January 26, 1990 a third tank (the Railroad Yard #2 Fuel Oil Dispensing Station), failed the tightness test. The leakage rate was approximately 0.30 gallons per hour vs. criteria of 0.05 gallons per hour. Per Ohio guidelines for tanks failing a tightness test the #2 Fuel Oil contents in the tank was removed to another tank thus eliminating the possibility of further loss.

As with prior two tanks discussed in the reference letter, we recommend removal of the tank rather than attempting to repair. This tank is steel construction and 49 years old. If the tank is rusted extensively, as we assume it is due to its age, it would not be able to be repaired. The removal of the 15,000 gallon tank in accordance with Ohio EPA requirements is estimated to cost \$59,000 depending upon the extent of ground contamination and assuming no ground water contamination. We believe these are reasonable assumptions because the sub surface soil is mostly clay. The reason for the higher cost is that a second tank of the same age is in the same excavation. Any attempt to remove the failed tank will affect the structural integrity of the other tank. In addition, these tanks have concrete vaults over part of them which will increase the subcontractors work. The work must be subcontracted because RAI is not certified by the State for tank removal.

Request that additional funds in the amount of \$59,000 be provided in the same way as the \$35,000 requested in the referenced letters for the Deactivation Furnace and Building 1045 Tanks. The total requirement is now \$94,000.

As explained in the referenced letter, the tank must be removed within 20 days from January 26, 1990 or by February 15, 1990. We will request an extension of 20 days (the maximum allowed) to March 7, 1990. To complete the physical work prior to March 7, 1990, we must be authorized to proceed by February 13, 1990. Failure to complete the removal of this tank by March 7, 1990 will result in the plant being in non-compliance with Ohio regulations.

As a reminder, the funding requested in the prior letters must be received by February 8, 1990 to avoid a non-compliance violation for those tanks.

Of the original eight tanks all have now been tested.

A 1383 Exhibit-1 and a DD Form 319-R are attached for the project. Also a DD Form 319-R for the first two tanks is attached.

Sincerely,

RAVENNA ARSENAL, INC.



H. R. Cooper
Plant Engineer

HRC/wt/hc90003

cf: AMCCOM
AMSMC-ISE (Ms. Ronnie DePorter)

AMCCOM
AMSMC-BPA-P

Attachment

Exhibit 1
1383 REPORT EXHIBIT 1
AMCCOM SUPPLEMENTAL INFORMATION SHEET

Installation Name: Ravenna Army Ammunition plant
Project Name: Underground Storage Tank Removal - 2 Leaking Tanks (Second group)

1. FUNDED: NO
2. PRON:
3. AMS CODE/PROGRAM ELEMENT (PE):
4. EXECUTING AGENCY: RVAAP OPERATING CONTRACTING
5. PRIORITY: HIGH
6. 319R #:
7. HAZMIN: YES
8. SOURCE STATUS: ACTIVE
9. TECH/ADMIN APPROVAL: YES
10. PERCENT CMPL: -0-
11. a. SUPPORTS PRODUCTION: NO
b. IF YES, SPECIFY:
12. TYPE EFFORT: CLOSURE
13. CORRECT NOV: NO
14. ON COMPLIANCE SCHEDULE/AGREEMENT: YES
15. NEPA DOCUMENTATION:
 - A. Prepared; Record of Environmental Consideration
 - B. Approved: YES, Installation Level Only
16. IMPACT IF NOT FUNDED: Ravenna Army ammunition Plant will not be in compliance with Ohio Administration Code Rule 1301-7-7-36(C)(2) which applies to UST's which fail a tightness test.

1383 REPORT EXHIBIT 1

SUPPLEMENTAL INFORMATION SHEET

DATE PREPARED: 1/25/90

GSA INVENTORY CONTROL NO: 20736

1. PROJECT NARRATIVE DESCRIPTION:

This project is to remove two leaking underground storage tanks (15,000 gallon capacities). The project includes abandonment of the tanks by removal according to an approved closure plan, removal and disposal of all visibly contaminated soils, testing of remaining soil, and completion of a closure report.

FUNDING TYPE: PAA INSTALLATION STATUS: Inactive
REQUIRED FOR MOBILIZATION: No; however, the removal of these tanks must be fully coordinated with revisions to the mobilization plan.

2. SPECIFIC TYPE OF POLLUTION/CONTAMINATION:

The tanks failed routine tank tightness tests on January 26, 1990. The subject tanks contained No. 2 fuel oils.

3. AMOUNT OF POLLUTION/CONTAMINATION:

The two (2) tanks to be removed have a combined capacity of 30,000 gals. Inventory checks have not indicated extensive product loss. Extent of contamination will be assessed during removal process.

4. POLLUTION SOURCE AND DISCHARGE, EMISSION OR DEPOSIT POINT:

Discharge is to the soil around the tanks.

5. EXISTING TREATMENT & OTHER CONTROL MEASURES: None

6. EFFECTIVENESS OF EXISTING TREATMENT CONTROL: Not applicable

7. REMEDIAL MEASURES PROPOSED & ESTIMATED EFFECT IN CORRECTING PROBLEMS: None

Tanks have been emptied of most fluid. The tanks remain in violation until removed or repaired and contamination is cleaned up.

8. APPLICABLE STANDARD: OAC 1301:7-7-36 (C)(2)

*9. OTHER RELEVANT INFORMATION:

The tanks must be removed within 40 days of discovery and contamination of the leak. (20 days per regulation plus the maximum extension allowed of 20 days). One tank was determined leaking January 26, 1990. Time to complete removal of both tanks is two weeks. Both tanks must be removed since they are in the same excavation and are 49 years old. One can't be removed without disturbing the other. Funding is needed by February 10, 1990.



Federal Agency Pollution Abatement Plan — Project Report

I. Facility Information

1. State Abbr.	2. Agency/Bureau	3. GSA Installation	4. EPA Region	5. Country	6. New Installation
O H	2-1-3-8	2-0-7-3-6	0 5	U S A	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
7. Name of the Installation RAVENNA ARMY AMMUNITION PLANT					
8. Street Address 8451 STATE ROUTE 5					
9. City Name RAVENNA OHIO				10. ZIP Code, if known 44266	
					11. Ownership Type C

II. Basic Project Information

1. Agency Project Number	2. Various Locations <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	3. Media S W	4. Pollutant Category L U S T	5. Funding Account 0 4	6. Year Funding Required 9 0
7. Project Name (Brief description) UNDEIRGROUND STORAGE TANK REMOVAL (2 TANKS) 2ND					
8. Project Contact Name TOM CHANDA			9. Contact Telephone 216-287-3221		10. Total Cost Estimate (in \$1,000)

11. Project Assessment		12. Compliance Status	
<input checked="" type="checkbox"/> High (H) Project critical to Agency program and/or cleanup of local environment	<input type="checkbox"/> Med (M) Project important to Agency program and/or cleanup of local environment	<input checked="" type="checkbox"/> ESOP Does not meet established standard and compliance deadline has passed	<input type="checkbox"/> ESOP Does not meet established standard and compliance deadline is in the future
<input type="checkbox"/> Low (L) Project desirable to Agency program and/or cleanup of local environment		<input type="checkbox"/> ESRO Meets established standard but need placement due to obsolescence	<input type="checkbox"/> ESRE Meets established standard but need placement due to need for expansion
		<input type="checkbox"/> ESOL Meets established standards but has demonstrate leadership	<input type="checkbox"/> OTHR Other

13. Project Cost			14. Project Milestones/Progress (All dates are monthly)		
Fiscal Year	Budgeted (\$1,000)	Funded (\$1,000)	Design/Plan Completion	Construction/Work	
				Start	Complete
90	59.0		0-1-90	0-1-90	0-2-90
			Final Compliance Required	Progress Code	Fiscal Year Complete
			0-2-90		
			For OGE User Only		
			Program ID	Field Office	

Project Narrative (including description of legal requirements and pollutants to be controlled)

SEE ATTACHED 1383 EXHIBIT

RAVENNA ARMY AMMUNITION PLANT

RECORD OF ENVIRONMENTAL CONSIDERATION (REC)

Ravenna Arsenal, Inc.

January 26, 1990

I. PROJECT TITLE/PROPOSED PROJECT

Underground Storage Tank Removal - 2 Leaking Tanks (Second Group)

II. PROJECT DESCRIPTION


RVAAP has 2 USTs which have failed tank tightness tests. In compliance with State and Federal EPA regulations said USTs and their appurtenances must be removed or repaired immediately. Due to the age of the tanks this project proposes removal.

III. ANTICIPATED DATE AND/OR DURATION OF PROPOSED ACTION

Expected to be performed in February 1990.


IV. REASON FOR USING RECORD OF ENVIRONMENTAL CONSIDERATION

The proposed action is categorically excluded under the provisions of Categorical Exclusion A-7, AR200-2, Appendix A (and no extraordinary circumstances exist as defined in paragraph 4-3) because subject action is in compliance with State and Federal EPA regulations pertaining to the removal of leaking USTs.




T. M. CHANDA
Environmental Engineer/Proponent

1-26-90
DATE


H. R. COOPER
Plant Engineer

1-26-90
DATE


ROBERT J. KASPER -
Commander's Representative Installation
Environmental Engineer

26 Jan 90
DATE

CURRENT OR BACKLOG OF DEFICIENCY IDENTIFICATION AND INDUSTRIAL PREPAREDNESS MEASURE (IPM)
(AMCCOM Suppl 1 to AR 700-90)

1. **INSTALLATION NAME/PIN**
Ravenna Army Ammunition Plant / PIN 995282

2. **DATE OF SUBMISSION**
ORIGINAL
Jan. 26, 1990

3. **REQUIREMENT CONTROL SYMBOL**
FEEDER FOR RCS CSCAB-205
ACTION OFFICE

4. LINE/AREA General	5. LINE/AREA STATUS CODE A	6. IPM NUMBER	7. REASON CODE C1
	9. IMPACT CODE E	10. IMPLEMENTATION CODE G	11. TIME IPM REQ AFTER M:DAY
15. ITEM/COMPONENT MANUFACTURED	16. ISN	17. PROD CAP (MAX) WITHOUT IPM	18. PROD LEVEL OFF TIME WITHOUT IPM
		19. RELATED IPMS	

a. N/A	N/A	N/A	N/A	N/A	N/A
b. N/A	N/A	N/A	N/A	N/A	N/A
c. N/A	N/A	N/A	N/A	N/A	N/A
d. N/A	N/A	N/A	N/A	N/A	N/A
e. N/A	N/A	N/A	N/A	N/A	N/A
f. N/A	N/A	N/A	N/A	N/A	N/A
g. N/A	N/A	N/A	N/A	N/A	N/A
h. N/A	N/A	N/A	N/A	N/A	N/A
i. N/A	N/A	N/A	N/A	N/A	N/A
j. N/A	N/A	N/A	N/A	N/A	N/A
k. N/A	N/A	N/A	N/A	N/A	N/A
l. N/A	N/A	N/A	N/A	N/A	N/A
m. N/A	N/A	N/A	N/A	N/A	N/A
n. N/A	N/A	N/A	N/A	N/A	N/A
o. N/A	N/A	N/A	N/A	N/A	N/A
p. N/A	N/A	N/A	N/A	N/A	N/A

23. **DEFICIENCY PROJECT TITLE**
P.O.C. R.J. Kasper COR AV 346-3124
W.A. Garkido AV346-3237

DESCRIPTION: (Bldg no, equipment, sq ft, length, quantity, etc.)
 a. REAL PROPERTY FAC CAT CODE NUMBER 12450
 b. EQUIPMENT

- Remove two (2) underground storage tanks which failed their required tank tightness tests.
1. Tank #33 DEAC Furnance - 2000 Gal. # 2 Fuel Oil
 2. Tank #23 Bldg. 1045 - 15000 Gal. #2 Fuel Oil
- The tanks must be removed within 40 days of discovery of leak(20 days/regulations plus 20 days maximum extension granted). The tanks were determined leaking on 1/15/90 and 1/18/90. Time to complete removal of both tanks is 2 weeks. Funding is needed by February 8, 1990.

24. **JUSTIFICATION** (includes impact on mobilization planning, effort, economics, etc.)
Ravenna Army Ammunition Plant will not be in compliance with Ohio Administration Code Rule 1301:7-7-36(c)(2) which applies to USTs which fail a tightness test.

20. OPERATIONAL IMPACT	<input checked="" type="checkbox"/> MISSION SUPPORT	<input type="checkbox"/> GENERAL SUPPORT
	<input type="checkbox"/> PROD SUPPORT	<input type="checkbox"/> ADMIN SUPPORT
21. LOCAL CONTROL NUMBER		
22. PROGRAM CONTROL NUMBER		
25. COST DATA (\$000)		
a. REAL PROPERTY	b. EQUIPMENT	
(1) LABOR COST	(1) LABOR COST	
(2) MATERIAL COST	(2) MATERIAL COST	
(3) SUBCONTRACT	(3) SUBCONTRACT	
(4) G&A COST	(4) G&A COST	
(5) FEE	(5) FEE	
(6) TOTAL EST COST	(6) TOTAL EST COST	
26. DD FORM 1391 PROCESSOR NUMBER		
27. AMCCOM PROJECT IDENTIFICATION NUMBER		

28. **VERIFIED**
 YES NO **CODE** _____
 OFFICE _____ DATE _____

29. **VAUDATED**
 YES NO **CODE** _____
 OFFICE _____ DATE _____
 SIGNATURE _____

CURRENT OR BACKLOG OF DEFICIENCY IDENTIFICATION AND INDUSTRIAL PREPAREDNESS MEASURE (IPM)
(AMCCOM Suppl 1 to AR 700-90)

1. **INSTALLATION NAME/PIN**
Ravenna Army Ammunition Plant /Pin 995282

2. **DATE OF SUBMISSION**
ORIGINAL
Jan. 26, 1990

REQUIREMENT CONTROL SYMBOL
FEEDER FOR RCS CSCAB-205
3. **ACTION OFFICE**

4. LINE/AREA General	5. LINE/AREA STATUS CODE A	6. IPM NUMBER	7. REASON CODE C1	8. PROG FUNDING CODE ICOMP DESIGN	9. TIME TO 13. TIME TO 14. STATE OF READ WITHOUT IPM WITH IPM
9. IMPACT CODE E	10. IMPLEMENTATION CODE G	11. TIME IPM REQ AFTER M-DAY	12. TIME TO 13. TIME TO 14. STATE OF READ WITHOUT IPM WITH IPM	15. PAA (ENTIR)	16. WKS 2

15. ITEM/COMPONENT MANUFACTURED	16. ISN	17. PROD CAP (MAX) WITHOUT IPM WITH IPM	18. PROD LEVEL OFF TIME WITHOUT IPM WITH IPM	19. RELATED IPMS
---------------------------------	---------	--	---	------------------

a. N/A	N/A	N/A	N/A	N/A	N/A
b. N/A	N/A	N/A	N/A	N/A	N/A
c. N/A	N/A	N/A	N/A	N/A	N/A
d. N/A	N/A	N/A	N/A	N/A	N/A
e. N/A	N/A	N/A	N/A	N/A	N/A
f. N/A	N/A	N/A	N/A	N/A	N/A
g. N/A	N/A	N/A	N/A	N/A	N/A
h. N/A	N/A	N/A	N/A	N/A	N/A
i. N/A	N/A	N/A	N/A	N/A	N/A
j. N/A	N/A	N/A	N/A	N/A	N/A
k. N/A	N/A	N/A	N/A	N/A	N/A
l. N/A	N/A	N/A	N/A	N/A	N/A
m. N/A	N/A	N/A	N/A	N/A	N/A
n. N/A	N/A	N/A	N/A	N/A	N/A
o. N/A	N/A	N/A	N/A	N/A	N/A
p. N/A	N/A	N/A	N/A	N/A	N/A

23. **DEFICIENCY PROJECT TITLE**
P.O.C. R.J. KASPER
AV346-3124

DESCRIPTION: (Bldg no, equipment, sq ft, length, quantity, etc.)
 a. **REAL PROPERTY** FAC CAT CODE NUMBER 12450
 b. **EQUIPMENT** W.A. Garkido
 AV346-3237

To remove one (1) underground storage tank (UST) which failed it required tightness test and one (1) UST adjacent to said UST (within 3 ft.) of the same size, age, and construction.
 1. Tank #22 Rail YD - 15000 Gal. - #2 Fuel Oil
 2. Tank #11 Rail YD - 15000 Gal. - #2 Fuel Oil
 The tanks must be removed within 40 days of discovery of leak(20 days/regulations, plus 20 days maximum extension granted) The tank was determined leaking on January 26, 1990. Time to complete removal of both tanks is 2 weeks. Funding is needed by February 10, 1990.

24. **JUSTIFICATION** (includes impact on mobilization planning, effort, economics, etc.)

Ravenna Army Ammunition Plant will not be in compliance with Ohio Administration Code 1301:7-7-36 (C) (2) which applies to USTs which fail a tightness test.

20. OPERATIONAL IMPACT
 MISSION SUPPORT
 PROD SUPPORT
 LOCAL CONTROL NUMBER

21. PROGRAM CONTROL NUMBER

22. PROGRAM CONTROL NUMBER

25. COST DATA (\$000)

a. REAL PROPERTY	b. EQUIPMENT
(1) LABOR COST	(1) LABOR COST
(2) MATERIAL COST	(2) MATERIAL COST
(3) SUBCONTRACT	(3) SUBCONTRACT
(4) G&A COST	(4) G&A COST
(5) FEE	(5) FEE
(6) TOTAL EST COST	(6) TOTAL EST COST

26. DD FORM 1391 PROCESSOR NUMBER

27. AMCCOM PROJECT IDENTIFICATION NUMBER

28. **VERIFIED**
 YES
 NO
 OFFICE _____ DATE _____

29. **VALIDATED**
 YES
 NO
 OFFICE _____ DATE _____

SIGNATURE _____
 OFFICE _____ DATE _____

cc: N. Wulff
T. Chanda
W. Carkido
File



RAVENNA ARSENAL INC.

8451 STATE ROUTE 5
RAVENNA, OHIO 44266-9297

Telephone (216) 358-7111

Autovon 346-3210

January 26, 1990

THRU: Contracting Officer's Representative
Ravenna Army Ammunition Plant
8451 State Route 5
Ravenna, Ohio 44266-9297

TO: Commander
U. S. Army Armament, Munitions and Chemical Command
ATTN: AMSMC-ISE-M (Ms. Ronnie DePorter)
Rock Island, IL 61299-6000

[Handwritten signature]
26 Jan 90

Subject: Corrective Action - Leaking Underground Storage Tank
Ref. RAI Letter January 16, 1990 - Same Subject
RAI Letter January 19, 1990 - Same Subject

Dear Sir:

Per your request, a 1383 Exhibit 1 and supporting documentation have been prepared for the removal of the two leaking tanks discussed in the referenced letters.

It is attached for further action.

Sincerely,

RAVENNA ARSENAL, INC.

H.R. Cooper

H. R. Cooper
Plant Engineer

HRC/wt/hc90005

Attachment

cf: AMCCOM
AMSMC-PCG-B



Federal Agency Pollution Abatement Plan — Project Report

I. Facility Information

1 State Alpha O H	2 Agency/Bureau 2 1 3 8	3 GSA Installation 2 0 7 3 6	4 EPA Region 0 5	5 Country U S A	6 New Installation <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
7 Name of the Installation R A V E N N A A R M Y A M M U N I T I O N P L A N T					
8 Street Address 8 4 5 1 S T A T E R O U T E 5					
9 City Name R A V E N N A O H I O			10 ZIP Code, if known 4 4 2 6 6 - 9 2 9 7		11 Ownership Type C

II. Basic Project Information

1 Agency Project Number	2. Various Locations <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	3. Media S W	4 Pollutant Category L U S T	5. Funding Account 0 4	6 Year Funding Required 9 0
7 Project Name (Brief description) U N D E R G R O U N D S T O R A G E T A N K R E M O V A L (2 T A N K S)					
8 Project Contact Name T O M C H A N D A		9 Contact Telephone 2 1 6 - 2 9 7 1 - 3 1 2 1 1		10. Total Cost Estimate (in \$1,000's)	

11 Project Assessment		12 Compliance Status			
<input checked="" type="checkbox"/> High (H) Project critical to Agency program and/or cleanup of local environment	<input type="checkbox"/> Med (M) Project important to Agency program and/or cleanup of local environment	<input checked="" type="checkbox"/> ESDP Does not meet established standard and compliance deadline has passed	<input type="checkbox"/> ESDP Does not meet established standard and compliance deadline is in the future	<input type="checkbox"/> PSDP Does not meet pending standard and compliance deadline is in the future	<input type="checkbox"/> ESRO Meets established standard but needs re-placement due to obsolescence
<input type="checkbox"/> Low (L) Project desirable to Agency program and/or cleanup of local environment		<input type="checkbox"/> ESRE Meets established standard but needs re-placement due to need for expansion	<input type="checkbox"/> ESDL Meets established standards but needs to demonstrate leadership	<input type="checkbox"/> OTHR Other	

13 Project Cost			14 Project Milestones/Progress (All dates are month/year)		
Fiscal Year	Budgeted (\$1,000)	Funded (\$1,000)	Design/Plan Completion	Construction/Work	
				Start	Completion
9 0	3 5 0		0 1 1 9 0	0 1 1 9 0	0 2 1 9 0
			Final Compliance Required	Progress Code	Fiscal Year Completed
			0 2 1 9 0		
			For DOE Use Only		
			Program ID	Field Office	

Project Narrative (including description of legal requirement and pollutants to be controlled)

SEE ATTACHED 1383 EXHIBIT 1

SUPPLEMENTAL INFORMATION SHEET

DATE PREPARED: 1/25/90

GSA INVENTORY CONTROL NO: 20736

1. PROJECT NARRATIVE DESCRIPTION:

This project is to remove two leaking underground storage tanks (2,000 and 15,000 gallon capacities). The project includes abandonment of the tanks by removal according to an approved closure plan, removal and disposal of all visibly contaminated soils, testing of remaining soil, and completion of a closure report.

FUNDING TYPE: PAA INSTALLATION STATUS: Inactive
REQUIRED FOR MOBILIZATION: No; however, the removal of these tanks must be fully coordinated with revisions to the mobilization plan.

2. SPECIFIC TYPE OF POLLUTION/CONTAMINATION:

The tanks failed routine tank tightness tests on January 15 and 18, 1990. The subject tanks contained No. 2 fuel oils.

3. AMOUNT OF POLLUTION/CONTAMINATION:

The two (2) tanks to be removed have a combined capacity of 17,000 gals. Inventory checks have not indicated extensive product loss. Extent of contamination will be assessed during removal process.

4. POLLUTION SOURCE AND DISCHARGE, EMISSION OR DEPOSIT POINT:

Discharge is to the soil around the tanks.

5. EXISTING TREATMENT & OTHER CONTROL MEASURES: None6. EFFECTIVENESS OF EXISTING TREATMENT CONTROL: Not applicable7. REMEDIAL MEASURES PROPOSED & ESTIMATED EFFECT IN CORRECTING PROBLEMS: None

Tanks have been emptied of most fluid. The tanks remain in violation until removed or repaired and contamination is cleaned up.

8. APPLICABLE STANDARD: OAC 1301:7-7-36 (C)(2)*9. OTHER RELEVANT INFORMATION:

The tanks must be removed within 40 days of discovery and contamination of the leak. (20 days per regulation plus the maximum extension allowed of 20 days). The tanks were determined leaking January 15 and 18, 1990. Time to complete removal of both tanks is two weeks. Funding is needed by February 8, 1990.

Exhibit 1
1383 REPORT EXHIBIT 1
AMCCOM SUPPLEMENTAL INFORMATION SHEET

Installation Name: Ravenna Army Ammunition plant
Project Name: Underground Storage Tank Removal - 2 Leaking Tanks

1. FUNDED: NO
2. PRON:
3. AMS CODE/PROGRAM ELEMENT (PE):
4. EXECUTING AGENCY: RVAAP OPERATING CONTRACTING
5. PRIORITY: HIGH
6. 319R #:
7. HAZMIN: YES
8. SOURCE STATUS: ACTIVE
9. TECH/ADMIN APPROVAL: YES
10. PERCENT CMPL: -0-
11. a. SUPPORTS PRODUCTION: NO
b. IF YES, SPECIFY:
12. TYPE EFFORT: CLOSURE
13. CORRECT NOV: NO
14. ON COMPLIANCE SCHEDULE/AGREEMENT: YES
15. NEPA DOCUMENTATION:
 - A. Prepared; Record of Environmental Consideration
 - B. Approved: YES, Installation Level Only
16. IMPACT IF NOT FUNDED: Ravenna Army ammunition Plant will not be in compliance with Ohio Administration Code Rule 1301-7-7-36(C)(2) which applies to UST's which fail a tightness test.

RECORD OF ENVIRONMENTAL CONSIDERATION (REC)

Ravenna Arsenal, Inc.

January 25, 1990

I. PROJECT TITLE/PROPOSED PROJECT

Underground Storage Tank Removal - 2 Leaking Tanks

II. PROJECT DESCRIPTION


RVAAP has 2 USTs which have failed tank tightness tests. In compliance with State and Federal EPA regulations said USTs and their appurtenances must be removed or repaired immediately. Due to the age of the tanks this project proposes removal.

III. ANTICIPATED DATE AND/OR DURATION OF PROPOSED ACTION

Expected to be performed in February 1990.

IV. REASON FOR USING RECORD OF ENVIRONMENTAL CONSIDERATION

The proposed action is categorically excluded under the provisions of Categorical Exclusion (CX) A-5 and A-12, AR200-2, Appendix A (and no extraordinary circumstances exist as defined in paragraph 4-3) because subject action is in compliance with State and Federal EPA regulations pertaining to the removal of leaking USTs.




T. M. CHANDA
Environmental Engineer

1-26-90
DATE



H. R. COOPER

1-26-90
DATE



ROBERT J. KASPER
Commander's Representative Installation
Environmental Engineer

26 Jan 90
DATE

TELEPHONE OR VERBAL CONVERSATION RECORD

For use of this form, see AR 340-15; the proponent agency is The Adjutant General's Office.

DATE

1-25-90

SUBJECT OF CONVERSATION

Need 1383's on failed underground STG. TANKS

INCOMING CALL


PERSON CALLING	ADDRESS	PHONE NUMBER AND EXTENSION
S. Wise	AMSMC-PCG-B	793-3359
PERSON CALLED	OFFICE	PHONE NUMBER AND EXTENSION
J. CICERO	SMCRU-CA	346-3127

OUTGOING CALL

PERSON CALLING	OFFICE	PHONE NUMBER AND EXTENSION
PERSON CALLED	ADDRESS	PHONE NUMBER AND EXTENSION

SUMMARY OF CONVERSATION

Need RAI To submit 1383's on failed
 Underground STG. TANK - DATA FAX To RONNIE
 DePorter + Shirlene WISE!



cc: RVAAP (CR (zero))
 Wolff
 Cooper
 file

TELEPHONE OR VERBAL CONVERSATION RECORD		DATE
For use of this form, see AR 340-15; the proponent agency is The Adjutant General's Office.		1/23/90
SUBJECT OF CONVERSATION <i>Extension Request For UST Remedial Action Following UST Tightness Failure</i>		
INCOMING CALL		
PERSON CALLING	ADDRESS	PHONE NUMBER AND EXTENSION
PERSON CALLED	OFFICE	PHONE NUMBER AND EXTENSION
OUTGOING CALL		
PERSON CALLING	OFFICE	PHONE NUMBER AND EXTENSION
<i>T.M. Chanda</i>	<i>RAI Environmental Engineering</i>	<i>816-297-3221</i>
PERSON CALLED	ADDRESS	PHONE NUMBER AND EXTENSION
<i>Richard Sissler</i>	<i>State Fire Marshal's Office Site Coordinator Columbus, GA</i>	<i>1-800-686-2878</i>
SUMMARY OF CONVERSATION		
<p><i>Mr. Sissler was posed with subject request in view of RVAAP's remedial action efforts being coordinated into one funded project. RVAAP still has one more UST to test; previously RVAAP had 2 (ea) UST fail tightness testing which requires a Feb. 5th & Feb 9th 1990 (respectively). Final corrective action. RVAAP would require an extension to finish UST testing, make funding requests, remove failed USTs, remove contaminated soil and/or product removal, and soil analysis.</i></p> <p><i>Sissler said that the State cannot formally grant extensions; but can demonstrate a 20 day leniency period following regulated deadlines. After which enforcement action takes over to any irresponsiveness.</i></p> <p><i>Sissler suggested RVAAP write an explanatory letter indicating inability to meet the initial 20 da. deadline; he cannot see any objection in allowing an additional 20 days to accomplish remediation under a One Project Scenario.</i></p>		

DA FORM 751 APR 66

REPLACES EDITION OF 1 FEB 58 WHICH WILL BE USED.

T.M. Chanda
 * GPO: 1965 O - 543-775, 54

IMPORTANT FAX INFORMATION



1234 S. Cleveland-Massillon Rd.
Akron, Ohio 44321
(216) 666-2200
FAX: (216) 666-7874

Please deliver immediately to: Mr. Bill Jenkins

Company: Ravenna Arsenal, Incorporated

Fax #: (216) 297-3216

Reference: _____

Response Requested:	Y _____	N _____
Hardcopy to follow by mail:	Y _____	N _____

No. of pages (including cover sheet): 3 Date: 1-23-90

Please contact Mary if all pages not received.


Comments: _____

B. J. JENKINS

JAN 23 1990

C. H. [Signature]

For Internal Use Only: _____



Signed By: _____

[Signature]



R&R

INTERNATIONAL, INC.

1234 S. CLEVELAND-MASSILLON ROAD
P.O. BOX 4383
AKRON, OHIO 44321
(216) 666-2200

January 23, 1990

B. J. JENKINS
JAN 23 1990

Mr. Bill Jenkins
Ravenna Arsenal, Incorporated
8451 State Route 5
Ravenna, Ohio 44266-9297

Reference: Removal of Two (2) 15,000 Gallon Tanks and Concrete Vault

Dear Mr. Jenkins:

Enclosed please find the following:

1. Cost Basis
2. Cost of Services

We are looking forward to working with you on this project. Please call us when we can be of assistance.

Respectfully,

R & R INTERNATIONAL, INC.

G. M. Rand, P.E.
President

GMR:mfp
Enclosure

B. J. JENKINS

JAN 23 1990

COST BASIS

Number of tanks to be removed:	2
Size	15,000 gallons

NOTE:

1. Ravenna Arsenal will pump out the water in the concrete vault and all contents (Number 2 fuel oil) from the tanks.
2. "Complete Removal of Tanks" - means excavation, transportation, disposal of the tanks and associated piping.
3. Included in the prices are cost of backfilling the hole with on-site soil, cost of analytical testing and closure report.

COST OF SERVICES

Two (2) tanks, 15,000 gallons, complete removal	\$ 18,400.00
Concrete Vault removed	1,400.00
Contaminated soil removal	68.00 per yard

Saw Reed R&R

Pds up front of landfill

Copy of soil analyses

- 7 PIT
- PCB
- BET X
- Final Pt.
- EP Tox.

Before material on-site
I.D. of job on the day

TELEPHONE CONVERSATION RECORD


DATE: JANUARY 19, 1990, 8:15 A.M.

FROM: SUSAN MCCAUSLIN, ENVIRONMENTAL SPECIALIST PHONE 216-297-3220

TO: TODD PARFITT, STATE FIRE MARSHALL'S OFFICE PHONE 1-800-686-2878

SUBJECT: TANK TEST FAILURE, TANK #23 BUILDING 1045

I called B.U.S.T. and spoke to Todd Parfitt to report the tank leak test failure of Tank #23. Todd took down all required information and informed me that the Fire Marshall's Office would be sending us a letter outlining our requirements with regard to corrective action.



Susan McCauslin

SM:ade



RAVENNA ARSENAL INC.

8451 STATE ROUTE 5
RAVENNA, OHIO 44266-9297

Telephone (216) 358-7111

cc: N. Wulff
B. Jenkins
D. Kanavy
T. Chanda
W. Carkido
File

Autovon 346-3210

January 19, 1990

THRU: Contracting Officer's Representative
Ravenna Army Ammunition Plant
8451 State Route 5
Ravenna, Ohio 44266-9297

TO: Commander
U. S. Army Armament, Munitions and Chemical Command
ATTN: AMSMC-PCG-B (Shirlene Wise)
Rock Island, IL 61299-6000

Subject: Corrective Action - Leaking Underground Storage Tank
Ref. RAI Letter January 16, 1990, Same Subject

Dear Sir:

The referenced letter advised you of the failure of a tank tightness test on Tank No. 33 during the testing of eight underground Storage Tanks at Ravenna AAP.

On the evening of January 18, 1990 a second tank at the #2 Fuel Oil Dispensing Station, Building 1045, failed the tightness test. The leakage rate was approximately 0.27 gallons per hour vs. criteria of 0.05 gallons per hour. Per Ohio guidelines for tanks failing a tightness test the 15,000 gallons of #2 Fuel Oil in the tank was removed to another tank thus eliminating the possibility of further loss.

As with the Deactivation Furnace tank discussed in the reference letter, we recommend removal of the tank rather than attempting to repair. This tank is steel construction and approximately 35 to 40 years old. The removal of the 15,000 gallon tank in accordance with Ohio EPA requirements is estimated to cost \$25,000 depending upon the extent of ground contamination and assuming no ground water contamination. We believe these are reasonable assumptions because the sub surface soil is mostly clay.

Request that additional funds in the amount of \$25,000 be provided in the same way as the \$10,000 requested in the referenced letter for the Deactivation Furnace Tank.

As explained in the referenced letter, the tank must be removed within 20 days from January 18, 1990 or by February 7, 1990. To complete the physical work prior to February 7, 1990, we must be authorized to proceed by January 29, 1990. Failure to complete the removal of this tank by February 7, 1990 will result in the plant being in non-compliance with Ohio regulations.

As a reminder, the funding requested in the referenced letter must be received by January 26, 1990 to avoid a non-compliance violation for that tank.

Of the original eight tanks to be tested only one remains to be tested next week.

Sincerely,

RAVENNA ARSENAL, INC.



H. R. Cooper
Plant Engineer

HRC/wt/hc90003

cf: AMCCOM
AMSMC-ISE (Ms. Ronnie DePorter)

OHIO DEPARTMENT OF COMMERCE
DIVISION OF STATE FIRE MARSHAL
BUREAU OF UNDERGROUND STORAGE TANK REGULATIONS

CORRECTIVE ACTION GUIDANCE
FOR PETROLEUM RELEASES

January 15, 1988

Section 3737.88 of the Ohio Revised Code requires that when the State Fire Marshal finds that a release of petroleum from an underground storage tank has occurred, he shall take actions necessary to protect human health and the environment.

This list of corrective action steps for petroleum releases from UST systems have been prepared to assist UST owners and operators in conducting the corrective action activities required by the State Fire Marshal when a release is discovered. Nothing in this guidance is intended to supercede any action taken by the Fire Marshal or any other local, state, or federal agency or regulation, nor does this list relieve the UST system owner or operator from compliance with any applicable local, state or federal regulations

General Requirements

These requirements apply to any suspected or confirmed release of petroleum from an underground storage tank. All owners and operators of UST systems, in response to a suspected or confirmed release of petroleum from an UST system, shall comply with these requirements.

Unless otherwise indicated, all reports required by the State Fire Marshal must be submitted in writing to:

Ohio Division of State Fire Marshal
Bureau of Underground Storage Tank Regulation
7510 East Main Street
P. O. Box 525
Reynoldsburg, OH 43068-3395

Suspected Release Confirmation

- (A) All suspected releases of petroleum from UST systems must be reported to the local fire department and the State Fire Marshal within 24 hours of their discovery. The report to the State Fire Marshal may be made by calling 614-752-8200 or 1-800-282-1927.

Any suspected release that effects surface or drinking water supplies

must be reported to the Ohio Environmental Protection Agency at 1-800-282-9378.

Any suspected release that threatens Ohio's wildlife must be reported to the Ohio Department of Natural Resources 614-265-4300.

- (B) Suspected releases must be immediately investigated and either confirmed or disproved by a method acceptable to the local fire department and the State Fire Marshal.
- (C) If a suspected release is confirmed, the owners and operators of the UST system must undertake all required corrective actions.

Initial Corrective Actions

The following steps must be taken at **all confirmed petroleum releases sites**:

- (A) Upon confirmation of an actual release, or discovery of a release in any other manner, the owners and operators of the UST system must:
 - (1) Report the confirmed releases to the local fire department and the State Fire Marshal within twenty-four hours.
 - (2) Stop any further release from the UST system;
 - (3) Mitigate all fire, explosion, and safety hazards;
 - (4) Remove and properly dispose of all visibly contaminated soil and any associated groundwater from the excavation zone. The disposal of contaminated soil or water must comply with all applicable local, state and federal regulations;
 - (5) Conduct an investigation to determine the possible presence of free product and initiate removal of any free product found as soon as practicable;
 - (6) Report all initial corrective action taken, including a verification of tank repair or closure if appropriate, to the local fire department and the State Fire Marshal within twenty days of the confirmation or discovery of the release.
 - (7) All UST system repairs, removals, abandonment, installation, and replacement must comply with the requirements of the Ohio Fire Code and all other local and state regulations. The Ohio Fire Code requires a permit from the fire official for all such actions.
- (B) Site investigation. The owner and operator must perform a site investigation for contaminated soil, groundwater, or free product and assemble from the investigation, or from other sources (e.g., USGS maps, SCS soil maps, Ohio Department of Natural Resources Division of Water, Ohio Environmental Protection Agency, and other agencies), any information

deemed necessary by the State Fire Marshal. The site investigation and information must include, but is not limited to, the following:

- (1) Data on the nature and estimated quantity of the released substance;
 - (2) Data from surface and subsurface soil sampling and analyses;
 - (3) Data from groundwater and/or surface water sampling and analyses;
and
 - (4) Data from available sources and/or site investigations concerning background levels prior to the release, water quality and use, well locations, subsurface soil conditions, climatological conditions, land use, and surrounding populations.
- (C) Reporting. The results of this site investigation and all required information must be reported to the State Fire Marshal within twenty days of the confirmation or discovery of the release unless otherwise directed by the fire marshal. The State Fire Marshal may request the collection and submission of additional information and/or a corrective action plan for additional soil, surface water, and groundwater cleanup.

Free Product Removal

The following steps must be taken at **all release sites where free product has been found**:

- (A) At sites where an owner or operator's investigations indicate the presence of a free product, the owner or operator must remove free floating product to the maximum extent practicable while continuing, as necessary, all other corrective action steps initiated, and while preparing for subsequent long term corrective actions. In meeting this requirement, the owner or operator shall:
 - (1) Conduct free product recovery in such a manner that such actions do not:
 - (a) spread contamination into previously uncontaminated areas through untreated discharge or improper disposal techniques, or
 - (b) produce vapors in the atmosphere at levels such that they pose a health and safety threat to previously uncontaminated areas.
 - (2) Handle any flammable products in a safe and competent manner to prevent fires or explosions.
- (B) Unless directed to do otherwise by the State Fire Marshal, prepare and submit, within thirty days of the confirmation or discovery of the release, a free product removal report to the State Fire Marshal. The report shall provide, but is not limited to, the following information:

- (1) The name of the person(s) responsible for implementing the plan;
- (2) The estimated quantity and type of product on site and the product thickness in wells, boreholes, and excavations;
- (3) Details of the product recovery system;
- (4) Whether any discharge will take place on or off site during the recovery operation;
- (5) The type of treatment and expected effluent quality from any discharge; and
- (6) The disposition of the recovered product.

Site Assessment

The following steps must be taken at all **release sites where remaining soil or ground water contamination has been found:**

- (A) Whenever an investigation indicates that there may be remaining soil contamination from the release, or that the released product or product from contaminated soil may have reached groundwater, or as otherwise directed by the State Fire Marshal, the owners and operators must:
 - (1) Conduct additional investigations of the release, the release site, and the surrounding area possibly affected by the release, to determine the full extent and location of the soils contaminated by the release; and
 - (2) Conduct additional investigations of the release, the release site, and the surrounding area possibly affected by the release to determine the presence of dissolved contamination due to the release in the ground water.
- (B) When directed by the State Fire Marshal, conduct an exposure assessment to determine the extent of exposure of, or potential exposure for exposure of, individuals to petroleum from the release. Such assessment shall be based on such factors as the nature and extent of contamination and the existence of or potential for pathways of human exposure, the size of the community within the likely pathways of exposure, and the comparison of expected human exposure levels to the short-term and long-term health effects associated with identified contaminants and any available recommended exposure or tolerance limits for such contaminants.
- (C) The information collected by the owners and operators during the course of this site assessment shall be submitted in accordance with a schedule established by the State Fire Marshal.
- (D) The State Fire Marshal may request the submission of a corrective action plan for additional soil and/or ground water cleanup.

Long Term Corrective Action

The following steps must be taken when **long term soil and/or ground water cleanup** is required by the State Fire Marshal:

- (A) Owners and operators must develop and submit a corrective action plan for responding to any contaminated soils, surface waters, or ground waters shall submit such a plan according to a schedule established by the State Fire Marshal.
- (B) The State Fire Marshal shall approve the corrective action plan only if it assures that implementation of the plan will provide adequate protection of human health, safety, and the environment. In making this determination, the State Fire Marshal shall consider:
 - (1) The physical and chemical characteristics of the petroleum substance, including its toxicity, persistence, and potential for migration;
 - (2) The hydrogeologic characteristics of the facility and the surrounding land;
 - (3) The proximity, quality, and current and future uses of ground water and surface waters; and
 - (4) The results of an exposure assessment when such an assessment is required.
- (C) Upon approval of the corrective action plan, the owners and operators shall implement the plan and monitor, evaluate, and report the results of implementation, as required by the State Fire Marshal.
- (D) Public participation.
 - (1) Prior to the approval of each long term corrective action plan submitted, the State Fire Marshal will provide an opportunity for public review and comment on the plan.
 - (2) If there is sufficient public interest, or for any other reason, the State Fire Marshal may hold a public meeting to consider comments on the corrective action plan. A public meeting will be conducted in any case where implementation of an approved corrective action plan does not achieve the established cleanup levels and termination of that plan is under consideration.
 - (3) In deciding whether to approve or modify the corrective action plan, the fire marshal will consider and respond to the comments from the public.

Cost Recovery

The owner or operator of an underground storage tank from which a release of petroleum has occurred is liable to the state for any costs incurred for any corrective or enforcement action undertaken by the State that is conducted pursuant to section 3737.88 Of the Ohio Revised Code.

Data Chart for Tank System Tightness Test

PLEASE PRINT

1. OWNER Property <input checked="" type="checkbox"/> Tank(s) <input checked="" type="checkbox"/>	REVENNA ARSENAL					
	Name	Address	Representative	Telephone		
2. OPERATOR	SAME					
	Name	Address	Representative	Telephone		
3. REASON FOR TEST (Explain Fully)	NEW LAWS					
4. WHO REQUESTED TEST AND WHEN	WAYNE CARLIDO					
	Name	Title	Company or Affiliation		Date	
5. TANK INVOLVED Use additional lines for manifolded tanks	Identify by Direction	Capacity	Brand/Supplier	Grade	Approx. Age	Steel/Fiberglass
	#11 R/R YARD	15,000		#2 Fuel Oil	49 YRS	STEEL
6. INSTALLATION DATA	Location	Cover	Fills	Vents	Siphones	Pumps
	North inside driveway, Rear of station, etc.	EARTH	2" + 3"	2"	N/A	suction
7. UNDERGROUND WATER	Is the water over the tank? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
	Depth to the Water table <u>725</u>					
8. FILL-UP ARRANGEMENTS	Tanks to be filled _____ hr. _____ Date Arranged by _____ Name _____ Telephone _____					
	Extra product to "top off" and run tank tester. How and who to provide? Consider NO Lead.					
9. CONTRACTOR, MECHANICS, any other contractor involved	Terminal or other contact for notice or inquiry _____ Company _____ Name _____ Telephone _____					
10. OTHER INFORMATION OR REMARKS						
	Additional information on any items above. Officials or others to be advised when testing is in progress or completed. Visitors or observers present during test, etc.					
11. TEST RESULTS	Tests were made on the above tank systems in accordance with test procedures prescribed for as detailed on attached test charts with results as follows:					
	Tank Identification	Tight	Leakage Indicated	Date Tested		
#11 R/R YARD	NO	- .353 G.P.H.	1-26-90			
12. SENSOR CERTIFICATION 3-89 Date 2408 Serial No. of Thermal Sensor	13. This is to certify that these tank systems were tested on the date(s) shown. Those indicated as "Tight" meet the criteria established by the National Fire Protection Association Pamphlet 329.					
	Technicians 1. <u>A.L. BEARS</u> Certification # <u>12U10645</u> 2. _____ Certification # _____			ALL OHIO PETRO TEST INC. Testing Contractor or Company. By: Signature <u>2507 4th ST. N.W. CANTON, OHIO 44708</u> Address		

1300	4	11.5	12	1.225	1.205	-0.020	2.53	+1	4.023	1.043	-2.15
1305	7	11.5	12	.985	.965	-0.020	2.53	+0	4.000	-0.020	-1.235
1310	8	11.4	12	.965	.940	-0.025	2.53	+0	4.000	-0.025	-1.260
1315	9	11.4	12	.940	.915	-0.025	2.54	+1	4.023	-0.048	-1.308
1320	10	11.4	12	.915	.890	-0.025	2.54	+0	4.000	-0.025	-1.333
1325	11	11.4	12	.890	.865	-0.025	2.55	+1	4.023	-0.048	-1.381
1330	12	11.4	12	.865	.840	-0.025	2.54	-1	4.023	-0.002	-1.383
1335	13	11.4	12	.840	.815	-0.025	2.55	+1	4.023	-0.048	-1.431
1340	14	11.4	12	.815	.790	-0.025	2.55	+0	4.000	-0.025	-1.456
1345	15	11.4	12	.790	.765	-0.025	2.56	+1	4.023	1.048	-1.504
1350	16	11.4	12	.765	.740	-0.025	2.56	+0	4.000	-0.025	-1.529
1355	17	11.4	12	.740	.715	-0.025	2.56	+0	4.000	-0.025	-1.554
1400	18	11.4	12	.715	.690	-0.025	2.55	-1	4.023	1.002	-1.556
1405	19	11.4	12	.690	.665	-0.025	2.55	+0	4.000	-0.025	-1.581
1410	20	11.4	12	.665	.640	-0.025	2.56	+1	4.023	-0.048	-1.629
1415	21	11.4	12	.640	.615	-0.025	2.56	+0	4.000	-0.025	-1.645
1420	22	11.4	12	.615	.590	-0.025	2.56	+0	4.000	-0.025	-1.679
1425	23	11.4	12	.590	.565	-0.025	2.56	+0	4.000	-0.025	-1.704
1430	24	11.4	12	.565	.540	-0.025	2.55	-1	4.023	-0.002	-1.706
		End Test								-1.353	GRN.

P-T Tank Test Data Chart
Additional Info

1. Net Volume Change at Conclusion of Precision Test -1.353 gph
 Signature of Tester: AL Sears
 Date: 1-26-90

2. Statement:
 Tank and product handling system has been tested tight according to the Precision Test Criteria as established by N.F.P.A. publication 329. This is not intended to indicate permission of a leak.
 OR
 Tank and product handling system has failed the tank tightness test according to the Precision Test Criteria as established by N.F.P.A. publication 329.

It is the responsibility of the owner and/or operator of this system to immediately advise state and local authorities of any implied hazard and the possibility of any reportable pollution to the environment as a result of the indicated failure of this system. Health Consultants Incorporated does not assume any responsibility or liability for any loss of product to the environment.

Tank Owner/Operator _____

Date _____

27.	28.	29.	30.	31.	32.	33.	34.	35.	36.	37.	38.	39.
	DATE 1-26-88 (24 hr.)	Reading No.	HYDROSTATIC PRESSURE CONTROL	VOLUME MEASUREMENTS (V) RECORD TO 1001 GAL.	Product in Graduate	Product Replaced (-)	TEMPERATURE COMPENSATION USE FACTOR (a)	Thermal Sensor Reading	Change Higher + Lower - (c)	Computation (c) x (a) = Expansion + Contraction -	TEMPERATURE CHANGING EACH READING	ACCUMULATED CHANGE
	Record details of setting up and running test. (Use full length of time if needed.)	Standpipe Level in inches	Level to which Restored	Before Reading	After Reading	Product Recovered (+)					Temperature Adjustment	At Low Level compute Change per Hour (MPa criteria)
12731	ARRIVE TEST LOCATION											
12730	MAKE MODIFICATION TO TANK TOP FOREQUIP.											
12729	CHECK FIVE GRADEWATER TABLE											
12728	SET UP SCAFFOLDING											
12727	SET UP EQUIP											
12726	FIL LEGUIP AND BLEED AIR FROM SYSTEM											
12725	START CIRCULATION											
12724	DRAW SAMPLES											
12723	START HIGH LEVEL TEST	1	12		800			222				
12722		2	12	800	570	-230		222	+1	4.023	-253	
12721		3	12	570	270	-300		223	+1	4.023	-323	
12720		4	12	1000	700	-300		226	+3	4.067	-369	
12719	Bleed AIR FROM SYSTEM	5	12	700	355	-345		228	+2	4.046	-391	
12718		6	12	355	070	-285		228	+0	4.000	-285	
12717		7	12	1000	755	-245		229	+1	4.023	-268	
12716		8	12	755	520	-235		232	+3	4.069	-294	
12715		9	12	520	285	-235		234	+2	4.046	-281	
12714		10	12	1000	800	-200		237	+3	4.067	-269	
12713		11	12	800	600	-200		239	+2	4.046	-246	
12712		12	12	1600	400	-200		241	+2	4.046	-246	
12711	PROPAGATE LOW LEVEL TEST											
12710	PRELIM READING	13	12					245				
12709	" "	14	12					248				
12708	START LOW LEVEL TEST	1	12	305	300	-005		249	+1	4.023	-028	
12707		2	12	300	285	-015		251	+2	4.046	-061	
12706		3	12	285	265	-020		251	+0	4.000	-020	
12705		4	12	265	245	-020		252	+1	4.023	-043	
12704		5	12	245	225	-020		252	+0	4.000	-020	

14. RUSSIA ARSENAL SK 5 KR. 11/19/19 DD12 1-20-19
 Name of Supplier, Owner or Dealer Address No and Street(s) City State Date of Test

15. TANK TO TEST #11 R/E yard
 Identify by position #2 fuel oil
 Brand and Grade

15a. BRIEF DIAGRAM OF TANK FIELD

16. CAPACITY
 Nominal Capacity 15,000 Gallons
 By most accurate capacity chart available 15,540 Gallons

From Station Chart Tank Manufacturer's Chart
 Company Engineering Data
 Charts supplied with Other

17. FILL-UP FOR TEST
 Suck Water Bottom before fill-up 0 in. 0 Gallons
 Tank Diameter 12 1/2 in. Inventory 15,540
 Total Gallons as Reading 20

TOTAL 15,560
 Transfer total to line 25a

18. SPECIAL CONDITIONS AND PROCEDURES TO TEST THIS TANK
 High water table in tank excavation
 Water in tank
 Line(s) being tested with LVLLT

19. TANK MEASUREMENTS FOR TST ASSEMBLY
 Bottom of tank to grade 247 in.
 Add 30" for "T" probe assy. 30 in.
 Total tubing to assemble - approximate 277 in.


20. EXTENSION HOSE SETTING
 Tank top to grade 121 in.
 Extend hose on suction tube 6" or more below tank top 0 in.

21. VAPOR RECOVERY SYSTEM
 21b. COEFFICIENT OF EXPANSION RECIPROCAL METHOD
 Type of Product #2 fuel oil
 Hydrometer Employed 4
 Temperature in Tank 46.4 °F
 After Circulation 41.0 °F
 Temperature of Sample -5 °F
 Difference (t'-t) 34.9 °F
 Observed A.P.L. Gravity 2159
 Reciprocal 2159 Page 38
 Total quantity in full tank (16 or 17) 15,560
 Reciprocal 2159
 Volume change in this tank per °F 2,209.8193
 Transfer to Line 25a

22. Thermal Sensor reading after circulation 3221 digits
 23. Digits per °F in range of expected change 46/47 digits
 342 °F

COEFFICIENT OF EXPANSION (Complete after circulation)
 24a. Corrected A.P.L. Gravity
 Observed A.P.L. Gravity
 Hydrometer employed
 Observed Sample Temperature °F
 Corrected A.P.L. Gravity @ 60°F, From Table A
 Coefficient of Expansion for Involved Product
 From Table B
 Transfer COE to Line 25b

24c. FOR TESTING WITH WATER see Table C & D
 Water Temperature after Circulation
 Table C
 Coefficient of Water
 Table D
 Added Surfactant? Yes No Transfer COE to Line 25b



The above calculations are to be used for dry soil conditions to establish a positive pressure advantage, or when using the four pound rule to compensate for the presence of subsurface water in the tank area.

Refer to N.F.P.A. 30, Sections 2-3.2.4 and 2-7.2 and the tank manufacturer regarding allowable system test pressures.

25. (a) Total quantity in full tank (16 or 17) 15,560
 (b) Coefficient of expansion for involved product 31K
 Volume change per °F (23 or 24) 2,209.8193
 Digits per °F in test Range (23)

= (a) x (b) = Volume change in this tank per °F 15,560 x 31K = 483,518.83
 Volume change per digit = 483,518.83 / 2159 = 223.5883
 This is test factor (a) 223.5883

Data Chart for Tank System Tightness Test

PLEASE PRINT

1. OWNER Property <input checked="" type="checkbox"/> Tank(s) <input checked="" type="checkbox"/>	REJUNKA ARSENAL Name Address Representative Telephone Name Address Representative Telephone																					
2. OPERATOR	SAME Name Address Telephone																					
3. REASON FOR TEST (Explain Fully)	NEW LAWS																					
4. WHO REQUESTED TEST AND WHEN	WAYNE CARLIDO ENG. Name Title Company or Affiliation Date Address Telephone																					
5. TANK INVOLVED Use additional lines for manifolded tanks	Identify by Direction #23 B. 1045	Capacity 15,000	Brand/Supplier	Grade #2 FUEL OIL	Approx. Age 41 YRS	Steel/Fiberglass STEEL																
6. INSTALLATION DATA	Location Southeast corner of Building 1045 North inside driveway, Rear of station, etc.	Cover EARTH Concrete, Black Top, Earth, etc.	Fills 4"	Vents 2"	Siphons N/A	Pumps Suction Suction, Remote. Make if known																
7. UNDERGROUND WATER	Depth to the Water table 34 is the water over the tank? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No																					
8. FILL-UP ARRANGEMENTS	Tanks to be filled _____ hr. _____ Date Arranged by _____ Name Telephone Extra product to "top off" and run tank tester. How and who to provide? Consider NO Lead. Terminal or other contact for notice or inquiry _____ Company Name Telephone																					
9. CONTRACTOR, MECHANICS, any other contractor involved	_____ _____ _____																					
10. OTHER INFORMATION OR REMARKS	Suction Line disconnected for test with STATE FIRE MARSHALL Additional information on any items above. Officials or others to be advised when testing is in progress or completed. Visitors or observers present during test, etc.																					
11. TEST RESULTS	Tests were made on the above tank systems in accordance with test procedures prescribed for as detailed on attached test charts with results as follows: <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 30%;">Tank Identification</th> <th style="width: 15%;">Tight</th> <th style="width: 35%;">Leakage Indicated</th> <th style="width: 20%;">Date Tested</th> </tr> </thead> <tbody> <tr> <td>#23 B. 1045</td> <td>NO</td> <td>- .3005 G.P.H.</td> <td>1-18-90</td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>						Tank Identification	Tight	Leakage Indicated	Date Tested	#23 B. 1045	NO	- .3005 G.P.H.	1-18-90								
Tank Identification	Tight	Leakage Indicated	Date Tested																			
#23 B. 1045	NO	- .3005 G.P.H.	1-18-90																			
12. SENSOR CERTIFICATION 3-89 Date 2408 Serial No. of Thermal Sensor	13. This is to certify that these tank systems were tested on the date(s) shown. Those indicated as "Tight" meet the criteria established by the National Fire Protection Association Pamphlet 329. Technicians 1. AL SEARS ALL OHIO PETERS TEST INC. Certification # 122110645 Testing Contractor or Company. By: Signature 2507 4th ST. N.W. CANTON, OHIO 44708 Address Certification # _____																					

1730		6	13.0	12	270	305	4,035	477	-1	7,022	4,057	
1735	START LOW LEVEL TEST	1		12				476				
1740		2	11.9	12	315	310	7,005	476	+0	4,000	7,005	
1745		3	11.7	12	310	300	7,010	477	+1	4,022	7,032	7,037
1750		4	11.7	12	300	290	7,010	477	+0	4,000	7,010	7,047
1755		5	11.5	12	290	270	7,020	478	+1	4,022	7,042	7,059
1800		6	11.5	12	270	250	7,020	478	+0	4,000	7,020	7,109
1805		7	11.5	12	270	250	7,020	478	+0	4,000	7,020	7,129
1810		8	11.5	12	270	250	7,020	479	+1	4,022	7,042	7,171
1815		9	11.5	12	250	230	7,020	480	+1	4,022	7,042	7,213
1820		10	11.5	12	230	210	7,020	480	+0	4,000	7,020	7,233
1825		11	11.5	12	210	190	7,020	480	+0	4,000	7,020	7,253
1830		12	11.5	12	190	170	7,022	480	+0	4,000	7,020	7,273
1835		13	11.5	12	170	150	7,020	481	+1	4,022	7,042	7,315
1840		14	11.5	12	150	130	7,020	482	+1	4,022	7,042	7,357
1845		15	11.5	12	130	110	7,020	482	+0	4,000	7,020	7,377
1850		16	11.5	12	110	90	7,020	482	+0	4,000	7,020	7,397
1855		17	11.5	12	90	70	7,020	481	-1	4,022	4,002	7,395
1900		18	11.5	12	70	50	7,020	481	+0	4,000	7,020	7,415
1905		19	11.5	12	50	30	7,020	482	+1	4,022	7,042	7,457
1910		20	11.5	12	30	10	7,020	483	+1	4,022	7,042	7,499
1915		21	11.5	12	10	0	7,020	483	+0	4,000	7,020	7,519
1920		22	11.5	12	0	0	7,020	484	+1	4,022	7,042	7,561
1925		23	11.5	12	0	0	7,020	484	+0	4,000	7,020	7,581
1930		24	11.5	12	0	0	7,020	484	+0	4,000	7,020	7,601

P-T Tank Test Data Chart

Additional Info

1. Net Volume Change at Conclusion of Precision Test 3005 gph

Signature of Tester: H. L. Spawo

Date: 1-18-90

2. Statement:
 Tank and product handling system has been tested tight according to the Precision Test Criteria as established by N.F.P.A. publication 329. This is not intended to indicate permission of a leak.

OR

Tank and product handling system has failed the tank tightness test according to the Precision Test Criteria as established by N.F.P.A. publication 329.

It is the responsibility of the owner and/or operator of this system to immediately advise state and local authorities of any implied hazard and the possibility of any reportable pollution to the environment as a result of the indicated failure of this system. Health Consultants Incorporated does not assume any responsibility or liability for any loss of product to the environment.

Tank Owner/Operator _____

Date _____

14. REUSWAH ARSUAL SR. 5 REUSWAH DND 1-18-70
 Name of Supplier, Owner or Dealer Address No and Street(s) City State Date of Test

15. TANK TO TEST
#23 B, 1045
 Identify by position
#2 FUEL OIL
 Brand and Grade

15a. BRIEF DIAGRAM OF TANK FIELD

16. CAPACITY
 Nominal Capacity 15000 Gallons
 By most accurate capacity chart available 15,546 Gallons
 From Station Chart
 Tank Manufacturer's Chart
 Company Engineering Data
 Charts supplied with
 Other

17. FILL-UP FOR TEST
 Slick Water Bottom 241 in. 62 Gallons
 before fill-up to 3/4" Tank Diameter 126 in. Inventory
 Total Gallons as Reading 15,546

18. SPECIAL CONDITIONS AND PROCEDURES TO TEST THIS TANK
 See manual sections applicable. Check below and record procedure in log (27).
 High water table in tank excavation
 Water in tank (EO line(s) being tested with LWLT

19. TANK MEASUREMENTS FOR TST ASSEMBLY
 Bottom of tank to grade 156 in.
 Add 30" for "T" probe assembly 186 in.
 Total tubing to assemble - approximate 186 in.

20. EXTENSION HOSE SETTING
 Tank top to grade 324 in.
 Extend hose on suction tube 6" or more 10 in.
 below tank top


21. VAPOR RECOVERY SYSTEM Stage II
 24b. COEFFICIENT OF EXPANSION RECIPROCAL METHOD
 Type of Product #2 FUEL OIL
 Hydrometer Employed 4 H
 Temperature in Tank 44.0 °F
 After Circulation 43 °F
 Temperature of Sample -1 °F
 Difference (t-t') 34.0 °F
 Observed A.P.I. Gravity 38
 Reciprocal 2179 Page # 38
 Total quantity in full tank (16 or 17) 15,504 Reciprocal 2179
 Volume change in this tank per °F 71151904
 Transfer to Line 26a.

22. Thermal Sensor reading after circulation 7480
 23. Digits per °F in range of expected change Between 49/45 digits

24a. COEFFICIENT OF EXPANSION (Complete after circulation)
 Corrected A.P.I. Gravity 320
 Observed A.P.I. Gravity 320
 Hydrometer employed 49/45 H
 Observed Sample Temperature 49/45 °F
 Corrected A.P.I. Gravity 320
 @ 60° F. From Table A.

24c. FOR TESTING WITH WATER see Table C & D
 Water Temperature after Circulation
 Table C
 Coefficient of Water
 Table D
 Added Surfactant? Yes No Transfer COE to Line 25b.

25. (a) 71151904 x (b) 320 = (c) 2222349 gallons
 Total quantity in full tank (16 or 17) Coefficient of expansion for involved product
 Digit per °F in test Range (23) Volume change per °F in test Compute to 4 decimal places. This is test factor (a)



The above calculations are to be used for dry soil conditions to establish a positive pressure advantage, or when using the four pound rule to compensate for the presence of subsurface water in the tank area.

Refer to N.F.P.A. 30, Sections 2-3.2.4 and 2-7.2 and the tank manufacturer regarding allowable system test pressures.

26. Volume change per °F (25 or 24b) 71151904 + Digit per °F in test 320 = Volume change per digit 2222349
 Compute to 4 decimal places. This is test factor (a)

27. Sensor Calibration 16730 16732

LOG OF TEST PROCEDURES

28. DATE TIME (24 hr.)	Record details of setting up and running test (use full length of line if needed)	29. Reading No.	30. HYDROSTATIC PRESSURE CONTROL	31. VOLUME MEASUREMENTS (V) RECORD TO 0.01 GAL.	32. Standpipe Level in Inches	33. Product Replaced (-) / Product Recovered (+)	34. TEMPERATURE COMPENSATION USE FACTOR (a)	35. Thermal Sensor Reading	36. Change Higher + Lower - (c)	37. Computation (c) * (a) = Expansion + Contraction -	38. NET VOLUME CHANGING EACH READING	39. ACCUMULATED CHANGE
------------------------------	---	-----------------	----------------------------------	---	-------------------------------	--	---	----------------------------	---------------------------------	---	--------------------------------------	------------------------

815 ARRIVE TEST LOCATION STICK TAKE FOR BU BIPOL DEPTH AND WHITE

WAIT FOR TANK TO BE TOPPED OFF CHECK FOR GRAVIMETER

1030 SETUP SCARFOLDING

SETUP 2 SETS OF GAUGES

FILE GAUGE AND BLEED AIR FROM SYSTEM

1130 START CIRCULATION

229 TAKE SAMPLE

1230 START HIGH LEVEL TEST

1245

1300

1315 BLEED HIR FROM SYSTEM

1330

1345

1400

1415

1430

1445

500

1515

1517 DROP TO LOW LEVEL TEST

REPLED MAINWAY

1600 RETURN HOUR HIGH LEVEL

1615

1630

1645

1700

1702 DROP TO LOW LEVEL TEST

1715

Data Chart for Tank System Tightness Test

PLEASE PRINT

1. OWNER Property <input checked="" type="checkbox"/> Tank(s) <input checked="" type="checkbox"/>	REYNOLDS ARSENAL Name Address Representative Telephone Name Address Representative Telephone					
2. OPERATOR	SIME Name Address Telephone					
3. REASON FOR TEST (Explain Fully)	LEAKS					
4. WHO REQUESTED TEST AND WHEN	WELLS CHECKED ENG. Name Title Company or Affiliation Date Address Telephone					
5. TANK INVOLVED Use additional lines for manifolded tanks	Identify by Direction #33 DEAC FURNACE	Capacity 2000	Brand/Supplier	Grade #2 FUEL OIL	Approx. Age	Steel/Fiberglass STEEL
6. INSTALLATION DATA	Location EAST SIDE OF BURN JAIL North inside driveway, Rear of station, etc.	Cover EARTH Concrete, Black Top, Earth, etc.	Fills 3" Size, Titefill make, Drop tubes, Remote Fills	Vents 2" Size, Manifolded	Siphones N/A Which tanks?	Pumps SUCTION Suction, Remote, Make if known
7. UNDERGROUND WATER	Depth to the Water table <u>69</u> Is the water over the tank? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
8. FILL-UP ARRANGEMENTS	Tanks to be filled _____ hr. _____ Date Arranged by _____ Name Telephone Extra product to "top off" and run tank tester. How and who to provide? Consider NO Lead. Terminal or other contact for notice or inquiry _____ Company Name Telephone					
9. CONTRACTOR, MECHANICS, any other contractor involved	_____ _____ _____					
10. OTHER INFORMATION OR REMARKS	Additional information on any items above. Officials or others to be advised when testing is in progress or completed. Visitors or observers present during test, etc.					
11. TEST RESULTS	Tests were made on the above tank systems in accordance with test procedures prescribed for as detailed on attached test charts with results as follows:					
	Tank Identification #33 DEAC FURNACE	Tight NO	Leakage Indicated 7.0825 G.P.H.	Date Tested 1-15-90		
12. SENSOR CERTIFICATION 3-89 Date 2458 Serial No. of Thermal Sensor	13. This is to certify that these tank systems were tested on the date(s) shown. Those indicated as "Tight" meet the criteria established by the National Fire Protection Association Pamphlet 329. Technicians 1. <u>A.L. SEARS</u> Certification # <u>122110645</u> 2. _____ Certification # _____ ALL OHIO PETRO TEST INC. Testing Contractor or Company. By: Signature <u>2507 4TH ST. W. CANTON, OHIO</u> Address <u>44708</u>					

1415	12	12.5	12	1265	1285	7.020	686	77	7.022	-1.002	7.061
1450	13	12.5	12	1245	1305	7.020	696	710	7.032	-1.012	7.073
1455	14	12.5	12	1305	1325	7.020	704	78	7.026	-1.006	7.079
1500	15	12.5	12	1325	1345	7.020	711	77	7.022	-1.002	7.081
1505	16	12.5	12	1345	1365	7.020	721	710	7.032	-1.012	7.093
1510	17	12.5	12	1365	1385	7.020	731	710	7.032	-1.012	7.105
1515	18	12.5	12	1385	1405	7.020	739	78	7.026	-1.006	7.111
1520	19	12.5	12	1405	1425	7.020	749	710	7.032	-1.012	7.123
1525	20	12.5	12	1425	1445	7.020	757	78	7.026	-1.006	7.129
1530	21	12.5	12	1445	1465	7.020	765	78	7.026	-1.006	7.135
1535	22	12.5	12	1465	1485	7.020	774	79	7.029	-1.009	7.144
1540	23	12.5	12	1485	1505	7.020	783	79	7.029	-1.009	7.153
1545	24	12.5	12	1505	1525	7.020	793	710	7.032	-1.012	7.165
DROP PRODUCT DISCONNECT COPPER PRODUCT LINE AND RE TEST TANK ONLY											

P-T Tank Test Data Chart
Additional Info

1. Net Volume Change at Conclusion of Precision Test 10825 gph
 Signature of Tester: AL Seano
 Date: 1-15-90

2. Statement:
 Tank and product handling system has been tested tight according to the Precision Test Criteria as established by N.F.P.A. publication 329. This is not intended to indicate permission of a leak.
 OR
 Tank and product handling system has failed the tank tightness test according to the Precision Test Criteria as established by N.F.P.A. publication 329.

It is the responsibility of the owner and/or operator of this system to immediately advise state and local authorities of any implied hazard and the possibility of any reportable pollution to the environment as a result of the indicated failure of this system. Health Consultants Incorporated does not assume any responsibility or liability for any loss of product to the environment.

Tank Owner/Operator _____

Date _____

14. REUNION APPROPRIAL SPS KEONURY DD10 1-12-80
 Name of Supplier, Owner or Dealer Address No and Street(s) City State Date of Test

15. TANK TO TEST
 # 33 DINAC FURNACE
 Identify by position
 # 2 FUEL OIL
 Brand and Grade

15a. BRIEF DIAGRAM OF TANK FIELD

16. CAPACITY
 Nominal Capacity 2000 Gallons
 By most accurate capacity chart available 2005 Gallons

From
 Station Chart
 Tank Manufacturer's Chart
 Company Engineering Data
 Charts supplied with Petro-Tite Equip
 Other SLIDESHARE

17. FILL-UP FOR TEST
 Slick Water Bottom 1/8 in. 1 Gallons
 before fill-up to 1/8 in. Tank Diameter 64 in. Inventory 64 in.

Total Gallons as Reading
64 in. 2005
2005
7 5
1
2009

18. SPECIAL CONDITIONS AND PROCEDURES TO TEST THIS TANK
 See manual sections applicable. Check below and record procedure in log (27).
 Use maximum allowable test pressure for all tests. Four pound rule does not apply to doublewalled tanks.
 Complete section below:
 1. Is four pound rule required? Yes No
 2. Height to 12" mark from bottom of tank 100 in.
 3. Pressure at bottom of tank 3,100 P.S.I.
 4. Pressure at top of tank 1,116 P.S.I.


21. VAPOR RECOVERY SYSTEM Stage II
 24b. COEFFICIENT OF EXPANSION RECIPROCAL METHOD
 Type of Product #2 Fuel Oil
 Hydrometer Employed 4 H
 Temperature in Tank 34.2 °F
 After Circulation 37 °F
 Temperature of Sample 43 °F
 Difference (+/-) 34.4 °F
 Observed A.P.I. Gravity 21.78 Page # 38
 Reciprocal 2178 Reciprocal 2178
 Total quantity in full tank (16 or 17) 2009 Volume change in this tank per °F Transfer to Line 25a.

19. TANK MEASUREMENTS FOR TSTT ASSEMBLY
 Bottom of tank to grade 69 in. 30 in.
 Add 30" for "T" probe assy. 99 in.
 Total tubing to assemble - approximate 99 in.

20. EXTENSION HOSE SETTING
 Tank top to grade 6 in.
 Extend hose on suction tube 6" or more below tank top 20 in.
 *If fill pipe extends above grade, use top of fill.
 22. Thermal Sensor reading after circulation 49.72 digits 34.735 °F
 23. Digits per °F in range of expected change 284 digits

COEFFICIENT OF EXPANSION (Complete after circulation)
 24a. Corrected A.P.I. Gravity
 Observed A.P.I. Gravity
 Hydrometer employed
 Observed Sample Temperature
 Corrected A.P.I. Gravity
 @ 60°F. From Table A
 Coefficient of Expansion for Involved Product
 From Table B
 Transfer COE to Line 25b.

24c. FOR TESTING WITH WATER see Table C & D
 Water Temperature after Circulation
 Table C
 Coefficient of Water
 Table D
 Added Surfactant? Yes No Transfer COE to Line 25b.



NOTES:
 The above calculations are to be used for dry soil conditions to establish a positive pressure advantage, or when using the four pound rule to compensate for the presence of subsurface water in the tank area.
 Refer to N.F.P.A. 30, Sections 2-3.2.4 and 2-7.2 and the tank manufacturer regarding allowable system test pressures.

25. (a) Total quantity in full tank (16 or 17) 7224058
 Volume change per °F (25 or 24b) 288
 (b) Coefficient of expansion for involved product 288
 Digits per °F in test Range (23)

(c) Volume change in this tank per °F 1,032.027
 Volume change per digit 1,0032
 Compute to 4 decimal places. This is test factor (a)

27. Sensor Calibration 16230, 16232 LOG OF TEST PROCEDURES		30. HYDROSTATIC PRESSURE CONTROL		31. VOLUME MEASUREMENTS (V) RECORD TO .001 GAL.		34. TEMPERATURE COMPENSATION USE FACTOR (a)		38. NET VOLUME CHANGING EACH READING		39. ACCUMULATED CHANGE	
28. DATE 1-15-70 (24 hr.)	Record details of setting up and running test (Use full length of line if needed.)	29. Reading No.	32. Product in Graduate		33. Product Replaced (-) Product Recovered (+)	35. Thermal Sensor Reading	36. Change Higher - Lower (C)	37. Compensation (C) x (a) = Expansion + Contraction -	Temperature Adjustment Volume Minus Expansion (+) or Contraction (-) (23(V) - 23(T))	At Low level compute Change per Hour (NFA criteria)	
			Beginning of Reading	Level to which Restored							Before Reading
1/30	ARRIVE TEST SITE WAIT FOR PERSON TO UNLOCK AREA TO TRUCK TO TEST										
1/30	WAIT FOR MAINT. TO COMPLETE TURN ON ELECT.										
1/30	REMOVE 4" BUSHINGS FROM TRUCK CLEAN AND REPEL REINSTALL										
1/30	START CIRCULATION	1									
1/30	START HIGH LEVEL TEST	1									
12/15		2	13.1	42	245	295	1050	438	226	1083	033
12/30	TIGHTEN 4" BUSHING	3	13.1	42	295	340	1045	464	226	1083	038
12/45		4	13.1	42	340	390	1050	490	226	1083	033
13/00		5	13.1	42	350	440	1050	516	226	1083	033
13/15		6	12.9	42	440	475	1035	543	227	1086	051
13/17	DROP TO LOW LEVEL TEST										
13/30		7	13.7	12	475	540	1065	567	224	1077	012
13/45		8	13.2	12	540	580	1040	590	223	1074	034
13/50		1	12.5	12	580	600	1020	597	19	1022	002
13/55		2	12.5	12	600	620	1020	604	17	1022	002
14/00		3	12.5	12	620	640	1020	613	19	1029	009
14/05		4	12.5	12	640	660	1020	620	17	1022	002
14/10		5	12.5	12	620	640	1020	628	18	1026	006
14/15		6	12.5	12	640	660	1020	637	19	1029	009
14/20		7	12.5	12	660	680	1020	647	10	1032	012
14/25		8	12.5	12	680	700	1020	656	19	1029	009
14/30		9	12.5	12	700	720	1020	663	19	1022	002
14/35		10	12.5	12	720	745	1025	672	19	1029	009
14/40		11	12.5	12	745	765	1020	679	19	1022	002

Data Chart for Tank System Tightness Test

PLEASE PRINT

1. OWNER Property <input checked="" type="checkbox"/> Tank(s) <input checked="" type="checkbox"/>	REXINA ARSENAL					
	Name	Address	Representative	Telephone		
2. OPERATOR	SAME					
	Name	Address	Representative	Telephone		
3. REASON FOR TEST (Explain Fully)	RETEST AFTER DISCONNECTING COOPER LINE					
4. WHO REQUESTED TEST AND WHEN	WAYNE CARLSON		ENG.		SAME	1-15-90
	Name	Title	Company or Affiliation		Date	
5. TANK INVOLVED Use additional lines for manifolded tanks	Identify by Direction	Capacity	Brand/Supplier	Grade	Approx. Age	Steel/Fiberglass
	#33 DEAC. FURNACE	2000		#2 FUEL OIL		STEEL
6. INSTALLATION DATA	Location	Cover	Fills	Vents	Siphones	Pumps
	EAST SIDE OF BURN UNIT	EARTH	8"	2"	N/A	DISCONNECTS
7. UNDERGROUND WATER	Depth to the Water table <u>6 FT</u>					Is the water over the tank? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
	Tanks to be filled _____ hr. _____ Date Arranged by _____ Name _____ Telephone _____ Extra product to "top off" and run tank tester. How and who to provide? Consider NO LEAD.					
8. FILL-UP ARRANGEMENTS	Terminal or other contact for notice or inquiry _____ Company _____ Name _____ Telephone _____					
	9. CONTRACTOR, MECHANICS, any other contractor involved					
10. OTHER INFORMATION OR REMARKS	DISCONNECTED PRODUCT LINE TEST TANK ONLY					
	Additional information on any items above. Officials or others to be advised when testing is in progress or completed. Visitors or observers present during test, etc.					
11. TEST RESULTS	Tests were made on the above tank systems in accordance with test procedures prescribed for as detailed on attached test charts with results as follows:					
	Tank Identification	Tight	Leakage Indicated	Date Tested		
#33 DEAC FURNACE	NO	- .065 G.P.H.	1-15-90			
12. SENSOR CERTIFICATION 3-89 Date 2428 Serial No. of Thermal Sensor						
13. This is to certify that these tank systems were tested on the date(s) shown. Those indicated as "Tight" meet the criteria established by the National Fire Protection Association Pamphlet 328.						
Technicians 1. AL SCARS			ALL OHIO PETRO TEST INC. Testing Contractor or Company. By: Signature			
Certification # 122110645			2507 4TH ST. N.W. CANTON, OHIO 44708 Address			
2. _____ Certification # _____						

1940		14	12.2	12	1,270	1,280	4.010	058	45	4.016	1,006	1067
1945		15	12.2	12	1,280	1,290	4.010	014	46	4.019	1,019	1076
1950		16	12.2	12	1,290	1,300	4.010	018	44	4.013	1,003	1079
1955		17	12.2	12	1,300	1,310	4.010	024	46	4.019	1,009	1088
2000		18	12.2	12	1,310	1,320	4.010	028	44	4.013	1,003	1091
2005		19	12.2	12	1,320	1,330	4.010	033	45	4.016	1,006	1097
2010		20	12.2	12	1,330	1,340	4.010	037	44	4.013	1,003	1100
2015		21	12.2	12	1,340	1,350	4.010	043	46	4.019	1,009	1109
2020		22	12.2	12	1,350	1,360	4.010	049	46	4.019	1,009	1118
2025		23	12.2	12	1,360	1,370	4.010	055	46	4.017	1,017	1127
2030		24	12.2	12	1,370	1,380	4.010	059	44	4.013	1,003	1130
	End Test											
	Tank only does NOT Pass Test											

P-T Tank Test Data Chart
Additional Info

1. Net Volume Change at Conclusion of Precision Test: 7065 gph

Signature of Tester: A.L. Sears

Date: 1-15-90

2. Statement:
 Tank and product handling system has been tested tight according to the Precision Test Criteria as established by N.F.P.A. publication 329. This is not intended to indicate permission of a leak.

OR

Tank and product handling system has failed the tank tightness test according to the Precision Test Criteria as established by N.F.P.A. publication 329.

It is the responsibility of the owner and/or operator of this system to immediately advise state and local authorities of any implied hazard and the possibility of any reportable pollution to the environment as a result of the indicated failure of this system. Health Consultants Incorporated does not assume any responsibility or liability for any loss of product to the environment.

Tank Owner/Operator _____

Date _____

7065 G.P.H.

14. RESURVA APRESSUAL SRS RESURVA OHIO 410-70
 Name of Supplier, Owner or Dealer Address No. and Street(s) City State Date of Test

15. TANK TO TEST
 #33 Day FURNACE
 Identity by position
#2 FUEL DIL
 Brand and Grade

15a. BRIEF DIAGRAM OF TANK FIELD

16. CAPACITY
 Nominal Capacity 2000 Gallons
 By most accurate capacity chart available 2005 Gallons

From Station Chart Tank Manufacturer's Chart
 Company Engineering Data
 Charts supplied with REPORTERSHIP
 Other SLIDE CHART

17. FILL-UP FOR TEST
 Stick Water Bottom before fill-up 18' in 1 Gallons
 Tank Diameter 64 in. Inventory 64 Gallons
 Total Gallons as Filling 2005 Gallons

18. SPECIAL CONDITIONS AND PROCEDURES TO TEST THIS TANK
 Water in tank WD (w/le) being tested with LVLT
 High water table in tank excavation

19. TANK MEASUREMENTS FOR TSTT ASSEMBLY
 Bottom of tank to grade 69 in. 30 in.
 Add 30" for "T" probe assy. 99 in.
 Total tubing to assemble - approximate 99 in.

20. EXTENSION HOSE SETTING
 Tank top to grade 4 in.
 Extend hose on suction tube 6" or more below tank top 20 in.

21. VAPOR RECOVERY SYSTEM
 Stage I
 Stage II


24b. COEFFICIENT OF EXPANSION RECIPROCAL METHOD
 Type of Product #2 SUELOIC
 Hydrometer Employed 2
 Temperature in Tank After Circulation 354 °F
 Temperature of Sample 39 °F
 Difference (t/t) +3 °F
 Observed A.P.I. Gravity 2176
 Reciprocal 2176 Page 38
 Total quantity in full tank (16 or 17) 2007 Reciprocal 2176 Volume change in full tank per °F 1223345
 Transfer to Line 25a.

22. Thermal Sensor reading after circulation 48.31 °F
 Between 35.36 °F and 29.22 digits

23. (Digits per °F in range of expected change) 2922 digits

COEFFICIENT OF EXPANSION (Complete after circulation)
 24a. Corrected A.P.I. Gravity
 Observed A.P.I. Gravity 29.22
 Hydrometer employed 2
 Observed Sample Temperature 39 °F
 Corrected A.P.I. Gravity @ 60°F From Table A 29.22
 Coefficient of Expansion for Involved Product From Table B 2922
 Transfer COE to Line 25b.

24c. FOR TESTING WITH WATER see Table C & D
 Water Temperature after Circulation 39 °F
 Coefficient of Water Table D 2922
 Added Surfactant? Yes No Transfer COE to Line 25b.



NOTES:
 The above calculations are to be used for dry soil conditions to establish a positive pressure advantage, or when using the four pound rule to compensate for the presence of subsurface water in the tank area.

Refer to N.F.P.A. 30, Sections 2-3.2.4 and 2-7.2 and the tank manufacturer regarding allowable system test pressures.

25. (a) 1223345 x (b) 2922 = (c) 35861586 gallons
 Total quantity in full tank (16 or 17) full tank (16 or 17) Coefficient of expansion for Involved Product Digits per °F in test Range (23)
 Volume change per °F (25 or 24b) + Digits per °F in test Range (23)
 Volume change in this tank per °F 35861586 (10032)
 This is 10032 gallons
 Volume change per digit Compute to 4 decimal places. factor (a)

27.	Sensor Calibration <u>16730</u> <u>16731</u>		30.	HYDROSTATIC PRESSURE CONTROL		31.	VOLUME MEASUREMENTS (V) RECORD TO .001 GAL.		34.	TEMPERATURE COMPENSATION USE FACTOR (a)			35.	NET VOLUME CHANGING EACH READING		39.	ACCUMULATED CHANGE
28.	DATE	Record details of setting up and running test. (Use full length of time if needed.)	29.	Reading No.	Standpipe Level in Inches	Product in Graduate	Product Replaced (-)	Thermal Sensor Reading	Change Higher * Lower - (c)	Computation (c) * (a) = Expansion * Contraction -	Temperature Adjustment	Volume Minus Expansion (+) or Contraction (-) (K39V) - (K37I)	Allow Level computer Change per Hour (NFPA criteria)				
	1-15-90	DISCONNECT COPPER PRODUCT LINE PLUG OFF TO RE-TEST TANK ONLY															
		FIL LEGUIP BLEEDAIR FROM SYSTEM															
		RESTART CIRCUITRY															
		START HIGH LEVEL TEST		1	4/2	540		4831									
				2	4/2.7	540	4030	857	+26	4.083	-0.048						
				3	4/2.6	570	4025	868	+11	4.035	-0.10						
				4	4/2.6	595	4025	884	+10	4.051	-0.26						
		CHANGE SET TUBE DIRECTION		5	4/2.4	620	4020	902	+18	4.058	-0.38						
				6	4/2.4	640	4020	917	+15	4.048	-0.28						
		DRY TO LOW LEVEL TEST		7													
				7	13.6	12	1660	1730	4070	929	+12	4.038	4.032				
				8	13.0	12	1095	1335	4090	942	+13	4.042	-0.02				
				1	12.3	12	135	150	4015	948	+6	4.019	-0.04				
		START LOW LEVEL TEST		2	12.2	12	150	160	4010	951	+3	4.010	4.000				
				3	12.2	12	160	170	4010	955	+4	4.013	-0.03				
				4	12.2	12	170	180	4010	960	+5	4.016	-0.06				
				5	12.2	12	180	190	4010	965	+5	4.016	-0.06				
				6	12.2	12	190	200	4010	970	+5	4.016	-0.06				
				7	12.2	12	200	210	4010	974	+4	4.013	-0.03				
				8	12.2	12	210	220	4020	981	+7	4.022	-0.12				
				9	12.2	12	220	230	4010	986	+5	4.016	-0.06				
				10	12.2	12	230	240	4010	989	+3	4.010	4.000				
				11	12.2	12	240	250	4010	993	+4	4.013	-0.03				
				12	12.2	12	250	260	4010	998	+5	4.016	-0.06				
				13	12.2	12	260	270	4010	1003	+5	4.016	-0.06				