

OCB
TRANSFORMER RECORDS

LOCATION EAST SUB - CAPACITOR BANK TAG NUMBER NONE
 POLE NUMBER _____ KV/CAPACITY 2.5 SERIAL NUMBER 300 687
 SERVICE TO: _____ MANUFACTURER WESTINGHOUSE STYLE _____
 TYPE F-11 FORM _____ PHASE _____ CYCLE _____ % IMP. _____ PRIV. _____
 SEC. V _____ KIND OF SERVICE _____ OUTDOOR _____ INDOOR X SUBWAY _____
 ACCESSORIES: _____ SEMAPHORE _____ OIL GAGE _____ THERMOMETER _____ DRAIN VALVE _____

QUARTERLY INSPECTIONS:

	1993	1994	1995	1996	1997	1998
FEBRUARY	<u>2-12-93</u> <u>87</u>					
MAY	<u>5-13-93</u> <u>87</u>					
AUGUST						
NOVEMBER						

DATE	DEFICIENCIES	DATE	CORRECTIVE ACTION
<u>8-13-93</u>	<u>oil only at 854</u>	<u>8-12-93</u>	<u>OIL DRAINED + SAMPLED 3.5 GAL.</u>
	<u>By BH</u>		<u>SAMPLE ID NO 08129301</u>
		<u>8-12-93</u>	<u>REFILLED WITH CERTIFIED</u>
			<u>ND OIL FROM S.D. MYERS 3.5 GAL.</u>
	<u>OUT OF SERVICE</u>		<u>IN SERVICE</u>
			<u>By BR + JF</u>