



Ohio Department of Commerce

George V. Voinovich, Governor

Division of State Fire Marshal • Bureau of Underground Storage Tank Regulations
8895 E. Main St., P.O. Box 687 • Reynoldsburg, OH 43068-0687
(614) 752-7938 • FAX (614) 752-7942

Nancy Chiles Dix, Director

RECEIVED

SEP 13 1993

SEP 09 1993

ENGINEERING

H.R. Cooper
Engineering Manager
Ravenna Arsenal, Inc.
8451 State Route 5
Ravenna, Ohio 44266-9297

RE: Ravenna Army Ammunition Plant
1,000 gallon diesel UST;
Eastside of power plant #6
8451 State Route 5
Ravenna, Ohio 44266-9297
Portage County
Incident #679298-14

Dear Mr. Cooper:

The State Fire Marshal, Bureau of Underground Storage Tank Regulations (SFM, BUSTR) has received your letter dated July 30, 1993 requesting approval to over excavate your underground storage tank (UST) cavity to no more than five (5) feet beyond the tank cavity sidewalls and to no more than two (2) feet below the tank cavity bottom. Your justification for this request was based on test pits that were dug around the UST cavity. You stated that soils in the test pits were visually examined and were field screened with a PID field screening instrument in which both methods showed no evidence of fuel contamination.

Based on this information, SFM, BUSTR grants approval of overexcavation of the UST cavity.

If you have any questions regarding this matter, please contact Kelly Gill at (614) 752-7095.

Sincerely,

Andrew E. Lyles
Bureau Chief

AEL:KG:kkm

cc: File #679298-14
Susan McCauslin, Ravenna Arsenal, Inc.

COR
Wolff

Sue



Ohio Department of Commerce

George V. Voinovich, Governor

Division of State Fire Marshal • Bureau of Underground Storage Tank Regulations
8895 E. Main St., P.O. Box 687 • Reynoldsburg, OH 43068-0687
(614) 752-7938 • FAX (614) 752-7942

Nancy Chiles Dix, Director

SEP 09 1993

H.R. Cooper
Engineering Manager
Ravenna Arsenal, Inc.
8451 State Route 5
Ravenna, Ohio 44266-9297

RE: Ravenna Army Ammunition Plant
1,000 gallon diesel UST;
Eastside of power plant #6
8451 State Route 5
Ravenna, Ohio 44266-9297
Portage County
Incident #679298-14

Dear Mr. Cooper:

The State Fire Marshal, Bureau of Underground Storage Tank Regulations (SFM, BUSTR) has received your letter dated July 30, 1993 requesting approval to over excavate your underground storage tank (UST) cavity to no more than five (5) feet beyond the tank cavity sidewalls and to no more than two (2) feet below the tank cavity bottom. Your justification for this request was based on test pits that were dug around the UST cavity. You stated that soils in the test pits were visually examined and were field screened with a PID field screening instrument in which both methods showed no evidence of fuel contamination.

Based on this information, SFM, BUSTR grants approval of overexcavation of the UST cavity.

If you have any questions regarding this matter, please contact Kelly Gill at (614) 752-7095.

Sincerely,

A handwritten signature in cursive script that reads "Andrew E. Lyles".

Andrew E. Lyles
Bureau Chief

AEL:KG:kkm

cc: File #679298-14
Susan McCauslin, Ravenna Arsenal, Inc.