

OIL CIRCUIT BREAKER
 TRANSFORMER RECORDS "3" RA

LOCATION NEWTON FALLS TANK #3 TAG NUMBER 21159 3
 POLE NUMBER _____ KVA CAPACITY _____ SERIAL NUMBER 250789
 SERVICE TO: _____ MANUFACTURER ALLIS CHALMERS STYLE _____
 TYPE _____ FORM _____ PHASE _____ CYCLE 60 % IMP. _____ PRIV. 24000
 SEC. V _____ KIND OF SERVICE _____ OUTDOOR _____ INDOOR _____ SUBWAY _____
 ACCESSORIES: _____ SEMAPHORE _____ OIL GAGE THERMOMETER _____ DRAIN VALVE _____

QUARTERLY INSPECTIONS:

	1993	1994	1995	1996	1997	1998
FEBRUARY	<u>2-11-93 RA</u>					
MAY	<u>5-12-93 RA</u>					
AUGUST						
NOVEMBER						

DATE	DEFICIENCIES	DATE	CORRECTIVE ACTION
<u>8-19-93</u>	<u>oil drained, taken to Bldg 854 Drum # 120 24 gal RA</u>	<u>12-5-81</u>	<u>PCB TEST 27.56 PPM T.T.I # 71 27.56 PPM RA Tank # 3</u>
	<u>OUT OF SERVICE</u>		<u>IN SERVICE</u>
<u>8-19-93</u>	<u>OIL DRAINED, TAKEN TO BLDG. 854 - DRUM 119 52 gal.</u>		

OIL CIRCUIT BREAKER
TRANSFORMER RECORDS

LOCATION PARRETSVILLE SUB #3 TANK A TAG NUMBER ROP 21160
 POLE NUMBER _____ KVA CAPACITY _____ SERIAL NUMBER 250799 4
 SERVICE TO: _____ MANUFACTURER ALLIS CHALMERS STYLE _____
 TYPE _____ FORM _____ PHASE _____ CYCLE 60 % IMP. _____ PRIV. 24000
 SEC. V _____ KIND OF SERVICE _____ OUTDOOR INDOOR _____ SUBWAY _____
 ACCESSORIES: _____ SEMAPHORE _____ OIL GAGE THERMOMETER _____ DRAIN VALVE

QUARTERLY INSPECTIONS:

	1993	1994	1995	1996	1997	1998
FEBRUARY	2-11-93 <i>JF</i>					
MAY	5-12-93 <i>JF</i>					
AUGUST						
NOVEMBER						

DATE	DEFICIENCIES	DATE	CORRECTIVE ACTION
8-20-93	OIL DRAINED & TAKEN TO BLDG 854 DRUM 120 30 GAL tank #1	12-5-81	PCB TEST 34.64 PPM ITI # 72 <i>RJ</i> 34.64 PPM tank #1
OUT OF SERVICE		IN SERVICE	
8-20-93	OIL DRAINED & TAKEN TO BLDG 854 - DRUM 115 52 gal tank #1		

OIL CIRCUIT BREAKER
 OIL SWITCH
 TRANSFORMER RECORDS

LOCATION SUB STATION #3 TAG NUMBER 21164
 POLE NUMBER _____ KVA CAPACITY _____ SERIAL NUMBER S-94506
 SERVICE TO: _____ MANUFACTURER WESTING HOUSE STYLE _____
 TYPE F0-22-A FORM _____ PHASE 3 CYCLE 60 % IMP. _____ PRIV. 7500
 SEC. V 400 KIND OF SERVICE _____ OUTDOOR _____ INDOOR _____ SUBWAY _____
 ACCESSORIES: _____ SEMAPHORE _____ OIL GAGE _____ THERMOMETER _____ DRAIN VALVE _____

QUARTERLY INSPECTIONS:

	1993	1994	1995	1996	1997	1998
FEBRUARY	<u>2-11-93 J.F.</u>					
MAY	<u>5-12-93 J.F.</u>					
AUGUST						
NOVEMBER						

DATE	DEFICIENCIES	DATE	CORRECTIVE ACTION
		<u>8-4-93</u>	<u>OIL SAMPLE ID 08049301 J.F.</u>
	<u>OUT OF SERVICE</u>		<u>IN SERVICE</u>
<u>8-18-93</u>	<u>OIL DRAINED + TAKEN</u>		
	<u>TO BLDG. 854 - DRUM</u>		
	<u>114 15 gals</u>		

OIL CIRCUIT BREAKER
TRANSFORMER RECORDS

27
"3"

LOCATION CORRETTVILLE SUB #3 TANK TAG NUMBER 21160

POLE NUMBER _____ KVA CAPACITY _____ SERIAL NUMBER 250799

SERVICE TO: _____ MANUFACTURER ALLIS CHALMERS STYLE _____

TYPE _____ FORM _____ PHASE _____ CYCLE 60 % IMP. _____ PRIV. 24000

SEC. V _____ KIND OF SERVICE _____ OUTDOOR INDOOR _____ SUBWAY _____

ACCESSORIES: _____ SEMAPHORE _____ OIL GAGE THERMOMETER _____ DRAIN VALVE

QUARTERLY INSPECTIONS:

	1993	1994	1995	1996	1997	1998
FEBRUARY	<u>2-11-93 J.F.</u>					
MAY	<u>5-12-93 J.F.</u>					
AUGUST						
NOVEMBER						

DATE	DEFICIENCIES	DATE	CORRECTIVE ACTION
		<u>12-5-81</u>	<u>PCB TEST 23.97 PPM</u>
			<u>ITI #74 23.97 PPM</u>
			<u>Tank #3</u>
	OUT OF SERVICE		IN SERVICE
<u>8-20-93</u>	<u>OIL DRAINED & TAKEN</u>		
	<u>TO BLDG 854 - DRUM</u>		
	<u>116 46 gals</u>		