

OIL CIRCUIT BREAKER

TRANSFORMER RECORDS

LOCATION *OIL SWITCH*
POD SUB STATION

TAG NUMBER *2831 POS*

POLE NUMBER *PT 44* KVA CAPACITY _____ SERIAL NUMBER *945-067*

SERVICE TO: _____ MANUFACTURER *WESTINGHOUSE* STYLE _____

TYPE _____ FORM *FO-22A* PHASE *3* CYCLE *60* % IMP. _____ PRIV. _____

AMP
SEC. *1000* KIND OF SERVICE _____ OUTDOOR INDOOR _____ SUBWAY _____

ACCESSORIES: _____ SEMAPHORE _____ OIL GAGE _____ THERMOMETER _____ DRAIN VALVE _____

QUARTERLY INSPECTIONS:

	1993	1994	1995	1996	1997	1998
FEBRUARY	<i>2-11-93 J.F.</i>					
MAY	<i>5-12-93 J.F.</i>					
AUGUST						
NOVEMBER						

DATE	DEFICIENCIES	DATE	CORRECTIVE ACTION
------	--------------	------	-------------------

		<i>8-4-93</i>	<i>OIL SAMPLE ID 08049301 J.F.</i>

OUT OF SERVICE	IN SERVICE
----------------	------------

NOT IN USE

8-18-93 OIL DRAINED & TAKEN TO BLDG. 854 DRUM 114 15 gal